

HERAKLION, Greece

WMO: 167540

Lat: 35.340N

Lon: 25.180E

Elev: 35

StdP: 100.90

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.8	7.0	-2.1	3.2	11.1	-0.2	3.7	10.9	15.5	11.2	14.3	11.4	5.6	170	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.2	32.0	21.7	30.8	22.3	29.8	22.4	25.2	29.3	24.5	28.7	23.8	28.2	4.7	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	18.8	28.4	23.0	17.9	28.0	22.2	16.9	27.5	77.1	29.0	74.4	28.8	71.7	28.3	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.7	11.1	9.9	DB	3.7	36.8	1.7	2.4	2.5	38.5	1.5	39.9	0.5	41.2	-0.7	42.9	
			WB	1.8	26.4	1.6	1.1	0.6	27.2	-0.3	27.9	-1.2	28.5	-2.3	29.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.8	12.3	12.4	13.7	16.2	19.7	23.5	26.0	26.1	23.7	20.5	17.1	13.9
	DBStd	5.51	2.52	2.65	2.66	2.83	2.54	2.33	1.60	1.44	1.82	2.47	2.70	2.65
	HDD10.0	19	8	7	2	0	0	0	0	0	0	0	0	2
	HDD18.3	788	186	166	147	77	12	0	0	0	0	8	53	139
	CDD10.0	3236	81	75	117	187	302	406	496	498	412	325	214	124
	CDD18.3	963	1	1	3	13	55	156	238	240	162	75	17	2
	CDH23.3	7659	1	3	16	84	267	1153	2370	2376	1074	269	42	3
(14) Wind	WSAvg	4.7	5.1	5.2	4.9	4.4	3.9	4.2	5.1	5.1	4.4	4.4	4.5	5.0
	PrecAvg	477	89	71	60	27	14	3	1	1	16	57	59	85
	PrecMax	794	235	186	405	120	85	42	13	25	163	273	154	228
	PrecMin	262	4	7	1	0	0	0	0	0	0	0	4	8
	PrecStd	119	48	45	61	26	16	6	2	5	31	60	44	47
	DB	20.8	22.2	25.1	29.9	32.0	34.2	34.2	33.2	32.2	30.8	27.1	23.0	
	MCWB	13.8	13.8	14.5	15.9	18.3	22.0	21.6	22.2	21.6	19.6	18.0	16.0	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	18.8	19.8	22.0	25.3	28.1	30.8	31.8	31.1	29.7	27.5	24.2	20.8	
	MCWB	13.6	13.6	13.7	14.3	17.5	21.2	22.4	23.1	22.0	19.8	17.6	15.5	
	DB	17.2	18.1	19.9	23.1	26.0	29.0	30.2	30.1	28.2	25.9	22.8	19.2	
	MCWB	13.0	12.9	13.7	14.6	18.3	21.4	22.7	23.3	22.3	20.3	17.2	14.7	
	DB	16.2	16.9	18.2	21.1	24.2	27.9	29.5	29.2	27.4	24.8	21.2	18.0	
	MCWB	12.6	12.8	13.6	15.2	18.1	21.2	22.5	23.1	21.9	19.8	16.8	13.9	
	WB	15.2	15.5	16.7	19.5	22.5	25.1	25.9	26.2	25.2	22.7	20.2	17.4	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	18.8	19.2	20.7	24.3	25.9	29.6	29.8	29.9	28.7	26.2	24.1	21.2	
	WB	14.2	14.4	15.5	17.7	20.9	23.7	25.0	25.3	24.1	21.6	18.9	16.1	
	MCDB	17.4	18.4	19.3	21.5	24.5	28.2	29.2	29.3	27.8	25.4	22.5	19.8	
	WB	13.4	13.6	14.7	16.6	19.9	22.8	24.2	24.6	23.2	20.8	17.9	15.1	
	MCDB	16.6	17.3	18.5	20.4	23.8	27.4	28.7	28.8	27.2	24.7	21.7	18.6	
	WB	12.7	12.8	13.9	15.7	19.1	22.0	23.6	24.0	22.4	19.9	17.1	14.2	
	MCDB	15.8	16.2	17.6	19.6	23.0	26.6	28.3	28.3	26.6	23.8	20.6	17.5	
(35) Mean Daily Temperature Range	MDBR	5.9	6.4	7.0	7.7	7.8	7.3	6.4	6.2	6.7	6.4	6.4	5.8	
	5% DB	7.3	8.0	9.6	10.7	10.3	8.8	8.0	7.4	8.0	8.4	7.9	7.4	
	MCWBR	4.8	5.1	5.9	6.6	6.4	6.6	6.1	6.0	6.2	5.4	4.7	4.8	
	5% WB	6.9	7.6	8.2	9.0	8.5	7.7	7.3	7.1	7.7	7.6	7.3	7.1	
	MCWBR	4.9	5.5	6.1	6.6	6.4	6.6	6.3	6.2	6.4	5.5	5.0	5.0	
(40) Clear-Sky Solar Irradiance	taub	0.365	0.392	0.436	0.476	0.463	0.418	0.414	0.421	0.428	0.413	0.391	0.376	
	taud	2.390	2.293	2.146	2.052	2.146	2.326	2.340	2.318	2.302	2.314	2.341	2.358	
	Ebn at Noon	824	840	830	815	830	866	866	855	829	806	784	782	
	Edh at Noon	93	114	144	166	153	128	125	126	122	111	97	91	
(44) All-Sky Solar Radiation	RadAvg	2.34	3.12	4.55	5.89	6.88	7.79	7.75	6.96	5.63	4.02	2.78	2.06	
	RadStd	0.19	0.30	0.29	0.35	0.29	0.21	0.11	0.13	0.25	0.21	0.21	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.34	N/A	+1.75	N/A	+0.93	+1.02	N/A	-65	+122	N/A
(47)	Regional (5 neighbors)	+0.30	N/A	+1.20	N/A	+0.70	+0.75	N/A	-64	+107	N/A

Nomenclature: See separate page