

KARPATOS, Greece

WMO: 167650

Lat: 35.428N

Lon: 27.147E

Elev: 6

StdP: 101.25

Time Zone: 2.00 (EUE)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.2	7.8	-3.1	2.9	8.0	-1.0	3.5	8.8	18.2	11.2	16.5	10.9	8.5	340	0.640

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	30.9	23.1	29.9	23.2	29.1	22.9	24.7	28.3	24.2	27.8	23.8	27.3	8.2	310

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.8	18.6	26.7	23.1	17.8	26.5	22.7	17.5	26.3	75.1	28.4	73.2	27.9	71.4	27.6	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
16.8	15.0	14.0	DB	3.7	34.7	2.3	1.6	2.0	35.8	0.7	36.7	-0.6	37.6	-2.3	38.8	
			WB	1.2	26.0	1.5	0.8	0.1	26.6	-0.7	27.0	-1.6	27.5	-2.7	28.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	13.0	13.5	14.6	17.1	20.3	24.1	26.2	26.7	24.8	21.7	18.1	14.7	
	DBStd	5.25	2.71	2.39	2.16	1.79	1.83	1.66	1.22	0.98	1.54	1.78	2.35	2.41	
	HDD10.0	16	9	4	2	0	0	0	0	0	0	0	0	2	
	HDD18.3	610	164	135	115	47	3	0	0	0	0	2	31	114	
	CDD10.0	3524	103	102	146	212	319	424	503	518	443	363	243	147	
	CDD18.3	1076	0	0	1	8	64	174	245	260	193	106	24	1	
	CDH23.3	6639	0	0	0	9	124	940	1948	2220	1154	238	6	0	
CDH26.7	1308	0	0	0	0	0	16	149	453	514	169	6	0	0	
Wind	WSAvg	7.4	6.8	6.6	6.4	6.1	7.0	8.5	10.3	10.2	7.7	6.6	5.5	6.4	
Precipitation	PrecAvg	536	98	83	51	30	21	7	6	6	16	45	70	103	
	PrecMax	729	220	162	123	65	44	13	15	11	57	143	127	174	
	PrecMin	315	32	25	11	5	7	2	3	3	4	7	27	16	
	PrecStd	113	44	36	29	15	11	3	2	2	13	34	31	39	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.0	19.1	21.1	24.2	28.6	31.2	33.0	32.1	31.1	27.2	24.1	20.4	
		MCWB	16.0	16.0	15.5	16.5	18.5	21.7	22.0	23.5	22.7	21.1	19.7	16.7	
	2%	DB	18.0	18.1	19.2	22.9	26.1	29.2	30.9	30.8	29.2	26.1	23.1	19.8	
		MCWB	14.6	14.6	15.1	16.7	19.0	22.0	23.0	23.7	22.7	21.0	18.7	16.2	
	5%	DB	17.2	17.2	18.7	21.2	24.8	28.1	29.8	29.9	28.2	25.2	22.2	19.0	
		MCWB	14.0	14.0	14.9	16.5	19.0	21.8	22.9	23.8	22.3	20.6	18.2	15.5	
	10%	DB	16.8	16.9	17.9	20.1	23.2	27.2	29.0	29.1	27.5	24.9	21.3	18.2	
		MCWB	13.8	13.9	14.3	15.8	18.4	21.3	22.7	23.4	22.1	20.4	17.7	14.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.6	17.1	16.7	18.7	21.0	24.1	25.2	25.7	25.1	23.5	20.6	18.1
			MCDB	18.3	18.6	19.1	22.2	24.6	28.3	29.0	28.9	28.2	25.2	22.9	19.8
2%		WB	15.4	15.7	16.1	17.7	20.3	23.3	24.5	24.9	24.0	22.5	19.7	16.8	
		MCDB	17.3	17.1	18.3	20.9	23.8	27.0	28.2	28.6	27.3	24.7	21.9	19.1	
5%		WB	14.5	15.0	15.5	17.1	19.7	22.7	24.0	24.4	23.5	21.7	19.2	15.9	
		MCDB	16.7	16.7	17.8	19.8	23.1	26.2	27.6	28.0	26.8	24.3	21.5	18.3	
10%		WB	13.8	14.2	14.9	16.5	19.2	22.2	23.5	24.0	22.9	20.9	18.5	15.1	
		MCDB	16.3	16.4	17.3	19.1	22.5	26.0	27.2	27.6	26.2	23.9	21.1	17.9	
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.6	4.9	5.4	5.6	5.9	5.4	5.0	5.1	5.1	5.1	4.5	
		MCDBR	4.8	4.7	5.5	6.9	7.2	7.0	6.5	5.9	5.8	5.6	5.3	4.8	
		MCWBR	3.6	3.6	3.8	4.1	3.4	3.4	3.0	2.6	3.3	3.5	3.4	3.4	
	5% WB	MCDBR	4.5	4.0	5.0	6.1	6.3	6.4	5.7	5.4	5.6	5.3	4.9	4.4	
		MCWBR	3.9	3.5	3.8	4.0	3.5	3.4	3.2	2.8	3.7	4.3	3.9	3.5	
Clear-Sky Solar Irradiance	taub	0.364	0.395	0.430	0.465	0.454	0.412	0.409	0.419	0.413	0.407	0.385	0.367		
	taud	2.413	2.300	2.184	2.109	2.200	2.372	2.381	2.350	2.370	2.361	2.383	2.420		
	Ebn at Noon	826	836	836	825	838	871	871	856	844	814	793	797		
	Edh at Noon	91	114	139	157	145	122	120	122	114	106	94	86		
All-Sky Solar Radiation	RadAvg	2.49	3.29	4.78	6.07	7.09	7.90	7.82	7.01	5.80	4.25	2.95	2.25		
	RadStd	0.19	0.25	0.27	0.33	0.29	0.18	0.09	0.09	0.18	0.19	0.20	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.32	N/A	N/A	N/A	+0.40	+0.34	N/A	-60	+110	N/A

Nomenclature: See separate page