

INEBOLU, Turkey

WMO: 170240

Lat: 41.9789N

Lon: 33.7629E

Elev: 64

StdP: 100.56

Time Zone: 3.00 (E03)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.7	-0.6	-6.3	2.2	1.2	-4.8	2.5	1.8	14.5	9.0	12.9	7.1	5.1	160	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.3	29.2	23.9	28.2	23.0	27.3	22.4	24.8	28.4	23.9	27.5	23.0	26.6	2.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.6	18.6	27.9	22.6	17.4	27.0	21.7	16.5	26.0	75.9	28.5	72.2	27.5	68.6	26.6	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.1	7.9	DB	-4.5	31.1	1.7	2.1	-5.7	32.6	-6.7	33.8	-7.6	35.0	-8.8	36.5	(4)
(5)			WB	-5.5	25.3	1.5	0.8	-6.5	25.8	-7.4	26.3	-8.3	26.8	-9.3	27.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	6.5	6.0	7.7	10.7	15.4	19.6	22.4	23.0	19.4	15.3	11.3	7.6	(6)	
	DBStd	6.79	3.87	3.99	3.92	3.47	3.09	2.16	1.73	1.73	2.31	3.12	3.40	4.05	(7)	
	HDD10.0	492	122	123	97	28	1	0	0	0	0	2	23	97	(8)	
	HDD18.3	2046	366	344	331	232	101	11	0	0	16	102	213	332	(9)	
	CDD10.0	1875	14	12	24	48	169	287	383	403	281	167	62	23	(10)	
	CDD18.3	388	0	0	1	3	10	48	125	144	47	9	1	1	(11)	
	CDH23.3	2177	0	0	2	12	48	187	778	958	164	23	3	2	(12)	
	CDH26.7	341	0	0	0	2	9	18	108	192	7	4	0	0	(13)	
(14) Wind	WSAvg	3.6	3.8	3.7	3.5	2.9	2.9	3.4	3.6	3.6	3.9	3.6	4.0	4.2	(14)	
(15) Precipitation	PrecAvg	1007	119	86	72	51	51	45	43	67	84	124	127	139	(15)	
	PrecMax	1352	260	316	152	115	114	96	206	218	201	295	251	286	(16)	
	PrecMin	624	17	9	11	2	10	9	1	5	1	25	43	63	(17)	
	PrecStd	187	59	57	38	28	29	23	47	57	55	71	56	55	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.1	19.2	21.6	25.2	27.9	28.2	30.0	31.0	27.7	26.0	23.1	20.7	(19)	
		MCWB	10.9	11.0	12.5	15.0	18.4	21.1	24.7	25.7	22.4	17.7	14.2	13.1	(20)	
	2%	DB	16.5	16.3	17.7	21.2	24.1	26.5	28.7	29.6	26.2	23.2	20.1	18.1	(21)	
		MCWB	9.9	9.5	10.7	14.2	17.5	21.3	23.8	24.6	21.1	18.2	13.6	11.8	(22)	
	5%	DB	14.6	14.2	15.6	17.9	22.1	25.3	27.8	28.6	25.2	21.7	17.9	15.9	(23)	
		MCWB	9.0	8.8	10.1	12.6	17.1	20.5	23.1	23.7	20.7	17.5	13.2	10.4	(24)	
	10%	DB	12.0	11.9	13.7	15.5	20.3	24.2	27.0	27.7	24.1	20.2	16.2	13.8	(25)	
		MCWB	8.1	8.1	9.4	11.7	16.3	19.9	22.7	22.9	20.0	16.7	12.8	9.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	12.0	13.1	15.9	19.9	23.5	25.7	26.7	23.4	20.4	16.1	13.6	(27)	
		MCDB	17.4	18.3	19.8	22.9	25.0	26.7	29.1	30.3	26.6	23.4	19.2	18.5	(28)	
	2%	WB	10.3	10.2	11.5	14.3	18.4	22.2	24.6	25.4	22.2	19.1	15.0	12.3	(29)	
		MCDB	15.0	14.8	16.7	20.2	22.5	25.4	28.0	29.0	25.2	22.2	17.9	16.8	(30)	
	5%	WB	9.4	9.2	10.5	13.1	17.5	21.2	23.8	24.2	21.3	18.0	14.0	11.1	(31)	
		MCDB	13.2	13.2	14.7	17.2	21.3	24.4	27.2	28.0	24.3	21.1	17.0	14.6	(32)	
	10%	WB	8.6	8.2	9.7	12.1	16.7	20.2	23.0	23.3	20.3	17.0	13.0	10.0	(33)	
		MCDB	11.5	11.5	13.1	15.0	19.9	23.6	26.5	27.2	23.5	19.5	15.7	13.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.6	5.9	6.0	6.0	6.7	7.7	8.3	8.3	7.7	6.7	6.7	6.0	(35)	
		MCDBR	8.5	9.0	9.3	9.8	9.1	9.2	9.3	9.7	9.2	8.3	8.7	8.2	(36)	
	5% WB	MCWBR	4.6	4.7	4.7	4.8	5.5	6.7	7.1	7.6	6.8	5.9	5.7	4.8	(37)	
		MCWBR	7.3	8.1	8.1	8.2	7.7	8.3	8.5	9.1	8.5	7.6	7.1	7.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.364	0.400	0.445	0.489	0.456	0.433	0.443	0.449	0.426	0.410	0.373	0.359	(40)	
		taud	2.282	2.175	2.069	1.996	2.169	2.293	2.283	2.255	2.294	2.281	2.329	2.317	(41)	
	Ebn at Noon		756	782	790	785	826	845	832	813	804	765	741	726	(42)	
		Edh at Noon	91	118	147	170	147	130	130	130	117	105	87	82	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.56	2.32	3.52	4.81	5.88	6.78	6.97	6.11	4.54	2.99	1.98	1.37	(44)	
	RadStd		0.16	0.32	0.28	0.52	0.57	0.52	0.37	0.39	0.40	0.29	0.22	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.46	N/A	N/A	N/A	N/A	N/A	-97	-131	N/A	+52

Nomenclature: See separate page