

EDIRNE, Turkey

WMO: 170500

Lat: 41.6766N

Lon: 26.5506E

Elev: 51

StdP: 100.71

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.2	-5.0	-12.2	1.3	-6.0	-9.7	1.7	-3.5	7.2	6.8	6.2	4.6	2.2	340	0.396

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.4	35.9	21.2	34.4	21.1	32.9	20.7	23.1	32.3	22.3	31.4	21.5	30.4	2.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.1	26.4	19.4	14.2	25.5	18.6	13.6	25.0	68.6	32.5	65.5	31.5	62.9	30.4	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.6	4.8	4.2	DB	-9.1	38.2	2.3	2.2	-10.8	39.8	-12.2	41.1	-13.5	42.3	-15.2	43.9	(4)
(5)			WB	-9.6	24.4	2.2	1.3	-11.2	25.3	-12.5	26.0	-13.8	26.8	-15.4	27.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.5	3.4	5.6	8.8	13.5	18.9	22.9	25.5	25.5	20.8	14.8	9.7	4.4	(6)	
	DBStd	8.69	4.62	4.58	4.12	3.58	3.20	2.97	2.28	2.54	3.41	3.79	4.23	4.94	(7)	
	HDD10.0	676	211	133	74	11	0	0	0	0	0	7	56	184	(8)	
	HDD18.3	2129	464	356	297	148	32	2	0	0	0	121	261	432	(9)	
	CDD10.0	2328	6	11	36	116	277	388	480	482	323	154	46	11	(10)	
	CDD18.3	739	0	0	0	3	51	141	222	223	91	9	1	0	(11)	
	CDH23.3	7957	0	0	2	46	518	1494	2536	2474	815	70	2	0	(12)	
	CDH26.7	3612	0	0	0	8	137	642	1267	1257	291	11	0	0	(13)	
(14) Wind	WSAvg	1.8	1.7	2.1	2.1	1.9	1.8	1.7	1.8	1.8	1.6	1.6	1.6	1.7	(14)	
(15) Precipitation	PrecAvg	602	65	55	54	47	52	46	34	24	38	56	68	72	(15)	
	PrecMax	864	183	186	148	111	171	160	107	116	135	157	218	166	(16)	
	PrecMin	385	0	3	4	3	3	4	0	0	0	0	0	4	(17)	
	PrecStd	116	45	39	37	25	33	36	28	23	39	42	46	41	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.6	18.8	22.4	28.1	31.9	36.3	38.4	37.7	34.2	28.1	23.0	18.7	(19)	
		MCWB	13.2	13.1	14.2	16.8	19.5	21.5	21.9	20.9	20.3	19.7	17.3	15.8	(20)	
	2%	DB	14.5	16.5	19.8	24.7	29.8	34.0	36.0	35.9	31.9	25.2	19.9	15.7	(21)	
		MCWB	12.1	11.8	13.3	15.5	18.8	20.9	21.3	21.1	19.8	17.8	15.5	13.6	(22)	
	5%	DB	12.4	14.7	17.8	22.5	28.1	32.2	34.3	34.5	30.0	23.2	17.9	13.6	(23)	
		MCWB	10.3	11.1	12.1	14.5	18.0	20.5	21.0	21.2	19.3	17.0	14.6	11.7	(24)	
	10%	DB	10.1	12.6	15.6	20.5	26.4	30.5	32.7	32.9	28.2	21.3	16.0	11.5	(25)	
		MCWB	8.7	9.9	11.0	13.6	17.5	20.0	20.6	20.7	18.7	16.2	13.1	10.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.9	14.3	15.3	17.6	21.2	23.3	23.9	24.7	22.2	20.7	18.5	15.9	(27)	
		MCDB	15.7	17.6	20.6	25.4	29.3	32.4	34.4	33.2	30.3	25.6	20.8	18.2	(28)	
	2%	WB	12.2	12.7	13.8	16.3	19.9	22.1	22.9	23.3	21.0	19.0	16.3	13.7	(29)	
		MCDB	14.1	15.4	18.3	23.2	27.4	31.1	32.3	32.3	28.1	23.4	19.3	15.5	(30)	
	5%	WB	10.6	11.4	12.7	15.2	18.9	21.3	22.2	22.2	20.1	17.8	15.0	12.0	(31)	
		MCDB	12.2	14.2	16.6	21.2	26.0	30.2	31.5	31.5	27.2	21.6	17.5	13.4	(32)	
	10%	WB	8.7	9.9	11.6	14.2	18.0	20.6	21.5	21.4	19.4	16.7	13.7	10.2	(33)	
		MCDB	10.0	12.4	15.1	19.4	24.8	29.0	30.5	30.4	26.6	20.5	15.6	11.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	8.5	9.7	11.0	12.6	13.0	13.4	13.4	12.2	10.0	8.4	6.5	(35)	
		MCDBR	9.5	11.9	12.8	14.1	15.5	15.5	15.9	15.7	15.2	12.8	11.0	8.1	(36)	
	5% WB	MCWBR	7.0	7.5	7.1	6.7	6.5	5.6	5.2	5.1	5.7	6.5	6.8	6.3	(37)	
		MCWBR	9.0	10.6	11.5	12.3	13.7	14.3	13.9	14.2	13.2	11.4	9.8	7.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.352	0.383	0.426	0.473	0.447	0.447	0.446	0.453	0.435	0.405	0.377	0.358	(40)	
		taud	2.328	2.228	2.125	2.006	2.159	2.200	2.211	2.189	2.211	2.274	2.301	2.301	(41)	
	Ebn at Noon		777	806	812	800	833	833	828	810	795	771	737	729	(42)	
		Edh at Noon	88	112	139	169	148	143	140	139	127	106	90	83	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.59	2.39	3.54	4.87	6.12	6.67	6.92	6.20	4.60	2.99	1.87	1.40	(44)	
	RadStd		0.19	0.24	0.31	0.50	0.40	0.50	0.37	0.27	0.32	0.29	0.20	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47) Regional (21 neighbors)		+0.47	N/A	N/A	N/A	+0.62	+0.71	-80	-125	+99	+53	(47)	

Nomenclature: See separate page