

TEKIRDAG, Turkey

WMO: 170560

Lat: 40.9580N

Lon: 27.4960E

Elev: 10

StdP: 14.69

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.7	28.8	17.4	13.2	27.6	21.4	16.1	30.5	21.6	49.2	19.1	47.5	6.8	320	0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.8	87.6	74.5	85.5	73.5	83.7	73.2	78.1	84.2	76.5	82.8	74.9	81.5	8.8	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.2	137.0	82.9	74.4	128.5	81.5	72.7	121.3	79.9	41.6	84.4	40.0	82.9	38.5	81.7	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	15.9	13.9	DB	20.7	93.5	4.3	4.9	17.6	97.0	15.1	99.9	12.7	102.7	9.6	106.3	(4)
(5)			WB	19.1	80.3	4.2	2.5	16.1	82.1	13.6	83.6	11.2	85.0	8.2	86.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.6	41.9	43.3	47.5	54.2	63.1	71.2	75.8	76.7	69.5	61.0	52.9	45.2	(6)
(7)		DBStd	13.51	6.96	7.00	6.55	5.90	5.14	4.38	3.29	3.67	4.58	5.64	6.48	7.50	(7)
(8)		HDD50	854	262	206	129	25	0	0	0	0	0	3	45	184	(8)
(9)		HDD65	3436	717	608	545	325	96	4	0	0	16	146	366	613	(9)
(10)		CDD50	3995	10	18	50	152	407	636	800	826	585	345	130	36	(10)
(11)		CDD65	1101	0	0	1	2	38	190	335	361	150	22	2	0	(11)
(12)		CDH74	7607	0	0	3	6	96	1075	2715	3058	608	45	1	0	(12)
(13)		CDH80	1665	0	0	0	0	13	183	613	798	54	4	0	0	(13)
(14)	Wind	WSAvg	5.6	5.7	5.9	5.7	4.8	5.0	5.4	6.1	6.6	5.5	5.6	5.5	5.7	(14)
(15)	Precipitation	PrecAvg	22.3	2.8	1.9	2.1	1.7	1.5	1.5	0.8	0.6	1.2	1.9	2.9	3.4	(15)
(16)		PrecMax	30.7	6.2	4.9	5.0	4.5	3.4	4.5	3.4	3.1	5.2	5.4	7.9	7.2	(16)
(17)		PrecMin	15.9	0.0	0.4	0.1	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.8	0.0	(17)
(18)		PrecStd	4.3	1.8	1.3	1.2	1.0	0.9	1.1	0.7	0.7	1.5	1.3	1.8	2.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.1	64.4	69.7	73.7	81.2	89.1	90.8	90.9	84.8	78.3	70.7	66.5	(19)
MCWB			55.1	55.7	57.6	61.3	66.0	72.3	73.7	76.2	71.7	68.9	63.4	59.0	(20)	
2%		DB	56.5	59.2	63.7	69.2	76.3	84.5	87.0	88.0	81.0	74.4	67.0	62.1	(21)	
		MCWB	52.7	53.4	55.5	59.9	66.9	73.0	74.2	75.5	71.5	68.2	62.0	57.3	(22)	
5%		DB	53.2	55.3	59.5	65.5	73.7	81.7	85.0	86.0	79.3	71.9	64.4	58.2	(23)	
		MCWB	50.5	51.4	53.9	58.5	65.7	71.7	73.6	73.8	70.7	66.6	60.4	55.1	(24)	
10%		DB	51.0	52.4	56.4	62.8	71.5	79.5	83.3	84.2	77.6	69.5	61.9	55.3	(25)	
		MCWB	49.0	49.6	52.3	57.1	64.6	70.6	72.9	73.7	69.7	64.4	58.2	52.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.0	56.9	60.3	64.0	71.5	79.2	80.1	80.8	76.6	73.1	67.1	60.5	(27)
MCD B			60.0	62.5	65.3	70.3	75.3	82.7	85.7	87.1	80.7	74.9	67.9	64.6	(28)	
2%		WB	53.1	53.9	56.4	61.2	69.1	75.4	77.6	78.5	73.9	69.9	62.7	57.6	(29)	
		MCD B	55.8	57.9	61.7	66.3	73.3	80.9	84.2	84.8	78.7	72.1	65.6	61.2	(30)	
5%		WB	51.0	51.8	54.4	59.4	67.1	73.2	75.9	77.0	72.2	67.4	60.7	55.5	(31)	
		MCD B	53.0	54.7	58.9	64.2	71.9	79.6	82.8	83.4	77.4	70.6	63.9	58.0	(32)	
10%		WB	49.1	49.8	52.6	57.8	65.4	71.6	74.2	75.5	70.8	65.2	58.6	53.1	(33)	
		MCD B	50.8	52.2	56.2	62.2	70.5	78.3	81.4	82.2	76.2	68.9	61.4	55.1	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.6	10.1	11.3	11.8	12.8	13.8	14.3	12.9	11.6	10.9	9.8	(35)	
MCDBR			12.3	14.3	16.0	15.9	15.5	16.3	15.9	15.2	14.7	13.7	12.8	12.5	(36)	
MCWBR			9.4	9.9	10.4	10.2	9.9	10.1	9.8	9.5	9.5	9.4	9.4	9.7	(37)	
5% WB		MCD BR	11.8	13.1	14.6	14.6	14.2	15.1	14.6	14.1	13.6	12.8	11.8	11.5	(38)	
		MCWBR	9.5	9.4	10.2	10.4	10.5	10.9	10.8	10.3	9.9	10.1	9.7	9.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.372	0.403	0.444	0.487	0.452	0.444	0.445	0.452	0.440	0.421	0.391	0.378	(40)	
taud		2.294	2.183	2.082	1.985	2.164	2.230	2.236	2.216	2.227	2.247	2.276	2.271	(41)		
Ebn at Noon		241	250	253	251	263	265	264	258	252	241	231	226	(42)		
Edh at Noon		29	38	47	55	47	44	43	43	40	35	30	28	(43)		
(44)	All-Sky Solar Radiation	RadAvg	497	728	1126	1582	2001	2213	2305	2017	1486	960	610	447	(44)	
(45)		RadStd	67	87	104	172	141	158	104	94	109	94	73	64	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		+0.97	N/A	N/A	N/A	N/A	N/A	-117	-234	+212	+113

Nomenclature: See separate page