

CORUM, Turkey

WMO: 170840

Lat: 40.5459N

Lon: 34.9364E

Elev: 776

StdP: 92.34

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.4	-8.5	-14.5	1.2	-10.2	-11.8	1.5	-6.9	6.8	7.6	5.7	5.2	0.8	180	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.3	34.3	18.3	32.3	18.3	30.5	17.9	20.1	29.7	19.4	28.9	18.7	27.9	2.5	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.2	13.5	23.5	16.3	12.7	22.9	15.5	12.1	22.4	61.3	29.9	58.8	28.5	56.4	28.0	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.5	5.6	4.9	-14.8	37.6	4.4	2.0	-17.9	39.0	-20.5	40.2	-23.0	41.3	-26.1	42.8		
(5)			-15.0	21.3	4.3	1.2	-18.1	22.2	-20.6	22.9	-23.0	23.5	-26.1	24.4	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	0.4	2.3	6.0	10.8	15.0	18.5	21.4	21.9	18.0	12.9	6.4	2.0		
	DBStd	8.30	4.63	4.51	3.97	3.85	3.36	2.66	2.69	2.70	3.32	3.78	3.81	3.98		
	HDD10.0	1066	297	216	133	35	3	0	0	0	0	16	118	248		
	HDD18.3	2839	554	449	382	227	110	30	4	4	44	172	358	505		
	CDD10.0	1562	0	1	9	59	159	254	353	370	242	104	9	1		
	CDD18.3	296	0	0	0	1	8	34	99	116	36	3	0	0		
	CDH23.3	4331	0	0	2	41	223	582	1370	1460	564	88	0	0		
	CDH26.7	1693	0	0	0	4	50	183	593	641	207	16	0	0		
(14) Wind	WSAvg	1.6	1.2	1.4	1.8	1.8	1.6	1.9	2.3	2.2	1.7	1.3	1.0	1.1		
(15) Precipitation	PrecAvg	441	40	30	41	50	63	54	19	15	24	29	35	47		
	PrecMax	635	95	73	91	110	220	205	70	94	88	105	102	128		
	PrecMin	244	2	3	1	2	4	6	0	0	1	0	2	2		
	PrecStd	85	24	17	19	26	36	35	20	20	22	24	24	28		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	17.0	22.2	27.0	30.7	33.9	37.1	37.1	34.3	28.6	20.3	14.2		
		MCWB	7.5	8.5	11.0	14.0	17.3	18.0	18.6	17.9	16.7	15.2	11.4	9.0		
	2%	DB	10.2	13.9	18.8	24.2	27.9	30.7	34.3	34.2	31.5	25.9	18.0	11.5		
		MCWB	6.2	7.8	9.8	13.0	16.1	17.6	18.5	18.7	16.7	14.5	10.5	7.5		
	5%	DB	8.4	11.7	16.4	21.8	25.8	28.7	32.2	32.2	29.0	23.3	15.5	9.5		
		MCWB	5.4	6.9	8.9	12.1	15.3	17.3	18.5	18.6	16.1	13.8	9.4	6.7		
	10%	DB	6.5	9.5	14.0	19.3	23.7	26.8	30.1	30.3	26.6	20.7	13.3	7.8		
		MCWB	4.5	5.8	7.9	11.2	14.8	16.5	18.0	18.3	15.8	13.1	8.6	5.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	9.7	12.0	15.3	18.3	19.8	21.3	21.2	18.8	16.7	12.5	9.7		
		MCDB	11.2	14.8	20.0	24.6	27.8	28.7	31.2	30.6	28.9	25.3	18.4	13.1		
	2%	WB	6.7	8.3	10.4	13.8	17.0	18.7	20.1	20.3	17.8	15.3	11.2	8.2		
		MCDB	9.4	12.4	16.8	22.2	25.4	27.8	30.0	29.7	27.2	22.9	15.8	10.6		
	5%	WB	5.7	7.3	9.4	12.8	16.1	17.9	19.3	19.6	17.1	14.5	10.1	7.1		
		MCDB	8.0	11.2	15.1	19.9	24.2	26.6	29.0	28.9	26.2	21.4	14.5	9.1		
	10%	WB	4.6	6.1	8.3	11.7	15.2	17.1	18.6	18.9	16.3	13.6	9.0	6.0		
		MCDB	6.5	9.3	13.5	18.2	22.5	25.4	27.9	27.9	24.7	19.7	12.8	7.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	10.0	11.6	13.4	14.5	15.3	16.6	16.3	15.7	13.5	12.1	8.1		
		MCDBR	10.8	13.8	16.6	18.2	18.8	19.1	20.1	19.4	20.1	18.2	16.2	11.1		
		MCWBR	7.3	8.3	8.8	8.6	8.4	7.7	7.4	7.1	8.0	8.6	9.3	7.5		
		MCDBR	9.7	12.6	14.6	16.1	16.6	16.8	17.4	16.6	16.7	15.6	13.8	9.7		
	5% WB	MCWBR	6.7	7.7	8.1	8.0	7.7	7.1	6.7	6.4	7.0	7.6	8.1	6.7		
(40) Clear-Sky Solar Irradiance	taub		0.308	0.337	0.377	0.416	0.393	0.370	0.372	0.375	0.352	0.353	0.319	0.307		
	taud		2.373	2.315	2.233	2.150	2.292	2.382	2.381	2.356	2.420	2.398	2.452	2.429		
	Ebn at Noon		847	870	869	856	885	904	897	887	888	843	831	820		
	Edh at Noon		84	104	126	147	130	119	118	118	103	95	78	74		
(44) All-Sky Solar Radiation	RadAvg		1.83	2.83	3.88	5.05	6.06	6.92	7.22	6.48	5.06	3.39	2.31	1.56		
	RadStd		0.21	0.47	0.41	0.52	0.52	0.53	0.31	0.32	0.34	0.28	0.24	0.20		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (12 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	N/A	-137	+101	+62	(47)

Nomenclature: See separate page