

SIVAS, Turkey

WMO: 170900

Lat: 39.7438N

Lon: 37.0020E

Elev: 4216

StdP: 12.59

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.8	7.8	-1.6	5.9	3.1	3.3	7.6	9.5	28.3	31.8	24.8	31.5	2.4	130	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	29.4	91.8	63.2	88.3	62.5	85.0	61.8	67.3	85.4	65.2	82.3	63.5	80.0	4.5	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.8	93.3	76.6	58.8	86.7	74.1	57.1	81.3	71.0	34.3	85.6	32.6	82.5	31.1	80.2	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 19.0	14.9	11.7		-2.6	97.2	7.6	3.3	-8.0	99.5	-12.5	101.4	-16.7	103.3	-22.2	105.6	(4)
(5)				-3.1	68.9	7.4	3.0	-8.5	71.1	-12.8	72.9	-17.0	74.6	-22.4	76.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.6	27.5	30.0	39.3	49.0	56.9	63.3	68.8	70.2	62.6	53.1	41.8	31.2	(6)
(7)		DBStd	16.43	9.69	9.76	8.18	7.36	6.15	5.15	5.38	5.00	6.43	7.00	7.33	9.03	(7)
(8)		HDD50	2600	699	560	340	103	11	0	0	0	3	49	253	582	(8)
(9)		HDD65	6033	1164	980	796	481	258	92	19	12	117	371	696	1047	(9)
(10)		CDD50	2445	0	0	8	73	227	398	582	625	381	144	7	0	(10)
(11)		CDD65	402	0	0	0	1	8	39	135	172	45	2	0	0	(11)
(12)		CDH74	5748	0	0	0	20	186	657	1884	2174	759	68	0	0	(12)
(13)		CDH80	2106	0	0	0	1	25	160	768	912	234	6	0	0	(13)
(14)	Wind	WSAvg	3.9	4.1	4.1	4.4	4.2	3.9	4.1	4.4	4.4	3.6	3.1	3.3	3.9	(14)
(15)	Precipitation	PrecAvg	17.4	1.7	1.5	1.9	2.3	2.5	1.4	0.4	0.3	0.7	1.4	1.6	1.9	(15)
(16)		PrecMax	23.0	4.1	3.7	4.5	4.8	6.5	3.8	3.2	3.2	3.0	4.1	5.0	4.6	(16)
(17)		PrecMin	11.2	0.2	0.2	0.1	0.1	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.1	(17)
(18)		PrecStd	3.1	0.9	0.7	0.9	1.1	1.3	0.9	0.6	0.6	0.7	0.9	1.1	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.6	54.7	67.1	76.7	83.2	88.2	96.3	96.1	90.9	80.0	65.0	53.0	(19)
MCWB			39.8	42.6	47.8	53.9	58.9	61.7	63.2	62.7	58.7	56.3	48.0	43.3	(20)	
2%		DB	44.0	49.8	61.5	72.5	79.0	84.7	92.2	92.3	86.3	75.3	60.5	49.4	(21)	
		MCWB	38.0	40.9	46.2	51.8	57.2	60.8	64.1	63.5	59.0	54.9	47.1	41.8	(22)	
5%		DB	41.6	45.9	57.4	68.1	75.3	81.0	88.2	88.7	82.0	71.0	56.9	46.0	(23)	
		MCWB	36.7	38.8	44.7	50.6	55.7	60.0	63.1	63.1	57.8	53.7	45.4	40.2	(24)	
10%		DB	39.3	42.5	53.0	63.7	71.4	77.8	84.3	85.3	78.2	66.9	53.3	43.2	(25)	
		MCWB	35.1	37.2	43.1	48.7	54.7	58.9	62.0	62.9	57.4	52.4	44.4	38.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.8	44.3	50.4	56.5	62.1	65.7	69.9	69.5	63.9	59.3	51.0	44.7	(27)
MDCB			46.1	52.1	62.2	71.9	77.7	81.4	88.8	87.8	81.0	75.3	60.4	51.3	(28)	
2%		WB	38.6	41.1	47.5	54.0	59.3	63.1	67.4	67.5	61.7	56.7	48.8	42.7	(29)	
		MDCB	43.2	48.8	58.3	67.6	74.6	79.4	85.9	85.8	78.7	71.1	57.1	48.0	(30)	
5%		WB	37.0	39.2	45.5	52.0	57.3	61.4	65.3	65.7	60.2	54.9	47.0	40.8	(31)	
		MDCB	41.1	45.2	55.4	64.3	71.1	77.1	82.8	82.8	76.5	67.8	54.4	45.1	(32)	
10%		WB	35.3	37.3	43.4	50.0	55.5	59.9	63.4	63.9	58.6	53.1	45.2	38.8	(33)	
		MDCB	39.0	42.1	52.2	61.4	68.9	74.8	79.9	80.4	74.0	64.9	52.1	42.9	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.5	16.7	18.9	21.7	23.6	26.0	28.6	29.4	27.9	23.9	20.0	14.6	(35)
MCDBR			15.9	20.7	26.5	29.2	29.7	31.3	34.0	34.2	33.9	30.1	26.8	18.2	(36)	
MCWBR			10.6	13.0	14.3	13.6	12.6	12.3	12.4	11.9	12.9	13.5	15.0	11.5	(37)	
5% WB		MCDBR	14.5	18.0	22.4	24.9	25.6	28.1	29.3	29.1	28.4	25.9	21.5	15.7	(38)	
		MCWBR	9.8	11.4	12.7	12.4	11.9	12.2	12.3	11.7	12.1	12.3	12.6	10.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.287	0.317	0.359	0.393	0.371	0.343	0.335	0.343	0.321	0.337	0.302	0.285	(40)	
taud		2.348	2.282	2.246	2.195	2.327	2.429	2.451	2.405	2.463	2.403	2.459	2.424	(41)		
Ebn at Noon		279	285	283	279	287	295	296	292	293	274	273	272	(42)		
Edh at Noon		28	34	40	45	40	36	35	36	31	30	25	24	(43)		
(44)	All-Sky Solar Radiation	RadAvg	715	1050	1266	1561	1890	2248	2349	2120	1678	1119	762	569	(44)	
(45)		RadStd	91	136	154	174	142	161	115	100	109	88	100	82	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+2.11	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.63	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page