

SIVAS, Turkey

WMO: 170900

Lat: 39.7438N

Lon: 37.0020E

Elev: 1285

StdP: 86.81

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.8	-13.5	-18.6	0.8	-16.0	-15.9	1.1	-12.5	12.7	-0.1	11.1	-0.3	1.1	130	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.3	33.2	17.3	31.3	16.9	29.5	16.5	19.6	29.7	18.5	28.0	17.5	26.7	2.0	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	13.3	24.8	14.9	12.4	23.4	13.9	11.6	21.7	61.9	29.8	57.9	28.0	54.4	26.8	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	6.7	5.2	DB	-19.2	36.2	4.2	1.8	-22.2	37.5	-24.7	38.6	-27.1	39.6	-30.1	40.9	(4)
(5)			WB	-19.5	20.5	4.1	1.7	-22.5	21.7	-24.9	22.7	-27.2	23.7	-30.2	24.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.8	-2.5	-1.1	4.1	9.4	13.9	17.4	20.4	21.2	17.0	11.7	5.4	-0.4	(6)
(7)		DBStd	9.13	5.39	5.42	4.55	4.09	3.41	2.86	2.99	2.78	3.57	3.89	4.07	5.02	(7)
(8)		HDD10.0	1444	388	311	189	57	6	0	0	0	2	27	141	323	(8)
(9)		HDD18.3	3352	647	544	442	267	143	51	11	7	65	206	387	582	(9)
(10)		CDD10.0	1358	0	0	4	41	126	221	323	347	212	80	4	0	(10)
(11)		CDD18.3	223	0	0	0	1	4	22	75	96	25	1	0	0	(11)
(12)		CDH23.3	3193	0	0	0	11	103	365	1047	1208	422	38	0	0	(12)
(13)		CDH26.7	1170	0	0	0	1	14	89	427	507	130	3	0	0	(13)
(14)	Wind	WSAvg	1.8	1.8	1.8	2.0	1.9	1.7	1.8	2.0	2.0	1.6	1.4	1.5	1.7	(14)
(15)	Precipitation	PrecAvg	442	43	39	48	59	63	35	10	8	19	35	41	47	(15)
(16)		PrecMax	584	105	93	115	122	164	96	81	81	75	104	128	117	(16)
(17)		PrecMin	285	6	4	3	2	23	0	0	0	0	0	0	3	(17)
(18)		PrecStd	78	24	18	23	29	32	23	14	15	18	24	28	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.7	12.6	19.5	24.8	28.5	31.2	35.7	35.6	32.7	26.6	18.3	11.7	(19)
(20)			MCWB	4.3	5.9	8.8	12.2	15.0	16.5	17.3	17.1	14.8	13.5	8.9	6.3	(20)
(21)		2%	DB	6.7	9.9	16.4	22.5	26.1	29.3	33.4	33.5	30.2	24.1	15.9	9.7	(21)
(22)			MCWB	3.3	4.9	7.9	11.0	14.0	16.0	17.8	17.5	15.0	12.7	8.4	5.5	(22)
(23)		5%	DB	5.4	7.7	14.1	20.0	24.0	27.2	31.2	31.5	27.8	21.7	13.8	7.8	(23)
(24)			MCWB	2.6	3.8	7.0	10.4	13.2	15.6	17.3	17.3	14.3	12.0	7.5	4.5	(24)
(25)		10%	DB	4.1	5.8	11.7	17.6	21.9	25.4	29.0	29.6	25.7	19.4	11.8	6.2	(25)
(26)			MCWB	1.7	2.9	6.2	9.3	12.6	15.0	16.7	17.1	14.1	11.3	6.9	3.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.9	6.8	10.2	13.6	16.7	18.7	21.1	20.8	17.7	15.2	10.6	7.1	(27)
(28)			MCDWB	7.9	11.2	16.8	22.2	25.4	27.5	31.5	31.0	27.2	24.1	15.8	10.7	(28)
(29)		2%	WB	3.7	5.0	8.6	12.2	15.2	17.3	19.7	19.7	16.5	13.7	9.3	5.9	(29)
(30)			MCDWB	6.2	9.3	14.6	19.8	23.6	26.3	29.9	29.9	26.0	21.7	13.9	8.9	(30)
(31)		5%	WB	2.8	4.0	7.5	11.1	14.0	16.3	18.5	18.7	15.7	12.7	8.3	4.9	(31)
(32)			MCDWB	5.1	7.3	13.0	18.0	21.7	25.1	28.2	28.2	24.7	19.9	12.4	7.3	(32)
(33)		10%	WB	1.9	2.9	6.4	10.0	13.1	15.5	17.4	17.7	14.8	11.7	7.3	3.8	(33)
(34)			MCDWB	3.9	5.6	11.2	16.3	20.5	23.8	26.6	26.9	23.3	18.3	11.1	6.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.1	9.3	10.5	12.1	13.1	14.4	15.9	16.3	15.5	13.3	11.1	8.1	(35)
(36)			MCDBR	8.9	11.5	14.7	16.2	16.5	17.4	18.9	19.0	18.8	16.7	14.9	10.1	(36)
(37)			MCWBR	5.9	7.2	7.9	7.6	7.0	6.9	6.9	6.6	7.1	7.5	8.3	6.4	(37)
(38)		5% WB	MCDWB	8.0	10.0	12.5	13.8	14.2	15.6	16.3	16.1	15.8	14.4	11.9	8.7	(38)
(39)			MCWBR	5.4	6.3	7.1	6.9	6.6	6.8	6.8	6.5	6.7	6.8	7.0	5.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.287	0.317	0.359	0.393	0.371	0.343	0.335	0.343	0.321	0.337	0.302	0.285	(40)	
(41)		taud	2.348	2.282	2.246	2.195	2.327	2.429	2.451	2.405	2.463	2.403	2.459	2.424	(41)	
(42)		Ebn at Noon	880	897	891	880	906	930	934	920	924	865	860	858	(42)	
(43)		Edh at Noon	87	108	125	141	126	114	111	113	99	95	78	75	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.25	3.31	3.99	4.92	5.96	7.09	7.40	6.68	5.29	3.53	2.40	1.79	(44)	
(45)		RadStd	0.29	0.43	0.49	0.55	0.45	0.51	0.36	0.32	0.34	0.28	0.31	0.26	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+1.17	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.35	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page