

GOKCEADA, Turkey

WMO: 171100

Lat: 40.203N

Lon: 25.884E

Elev: 62

StdP: 14.66

Time Zone: 3.00 (E03)

Period: 86-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.1	30.5	19.4	14.6	31.4	22.0	16.6	33.2	29.9	35.5	28.2	35.2	18.7	20	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	89.3	70.5	86.8	69.8	84.7	69.3	72.9	84.9	71.7	83.2	70.7	81.6	7.9	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.0	106.8	78.6	67.8	102.4	77.6	66.6	98.3	77.2	36.6	85.2	35.4	83.2	34.5	81.5	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.7	22.9	20.4	DB	24.7	95.0	4.1	3.2	21.8	97.3	19.4	99.2	17.2	101.0	14.2	103.3	(4)
(5)			WB	23.4	76.1	3.5	3.0	20.9	78.3	18.8	80.0	16.9	81.7	14.3	83.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.5	43.8	44.8	47.5	55.9	63.8	73.2	77.1	76.9	70.4	61.5	52.0	46.1
	DBStd	13.63	7.01	7.08	7.35	6.21	5.46	4.41	3.90	3.25	4.50	6.35	6.79	7.73
	HDD50	778	220	173	135	19	0	0	0	0	0	4	58	169
	HDD65	3264	659	565	543	278	87	2	0	0	9	143	392	586
	CDD50	4241	26	28	57	195	429	696	839	833	611	362	117	48
	CDD65	1250	0	0	0	5	50	248	374	368	170	35	0	0
	CDH74	8125	0	0	0	13	175	1627	2916	2574	720	99	1	0
	CDH80	2162	0	0	0	0	13	404	924	698	108	15	0	0
Wind	WSAvg	9.0	10.3	10.6	10.1	8.1	7.7	6.6	8.6	9.1	7.6	9.7	9.0	10.6
Precipitation	PrecAvg	28.9	4.6	3.9	3.0	1.9	1.2	0.8	0.6	0.4	1.3	2.0	3.9	5.2
	PrecMax	38.0	10.7	11.1	8.4	7.5	3.1	2.4	2.2	3.0	5.8	7.3	11.3	13.7
	PrecMin	19.0	0.0	0.2	0.8	0.1	0.0	0.0	0.0	0.0	0.0	0.4	0.3	0.0
	PrecStd	6.2	3.0	2.6	1.8	1.7	0.9	0.7	0.7	0.7	1.6	1.6	2.7	3.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.6	61.0	66.5	76.1	82.1	90.8	95.7	90.8	86.3	80.6	68.2	62.1
		MCWB	56.2	54.7	55.6	61.3	66.0	70.3	71.9	71.2	68.2	66.6	60.7	57.9
	2%	DB	59.1	59.3	62.9	70.8	78.2	86.8	90.9	87.9	83.3	76.6	65.4	60.8
		MCWB	55.4	53.9	54.6	59.0	64.0	69.0	71.3	70.8	68.6	66.3	59.9	57.4
	5%	DB	57.3	57.6	59.9	67.5	75.9	84.3	87.4	86.0	80.8	73.2	63.4	59.4
		MCWB	53.6	53.4	53.4	57.4	63.3	68.6	70.1	70.1	67.4	64.5	58.9	56.4
	10%	DB	55.2	55.8	57.7	65.1	73.4	81.9	84.8	84.1	78.4	70.2	61.7	57.8
		MCWB	51.7	52.0	52.4	56.7	62.5	67.6	69.3	69.7	66.2	63.6	57.8	54.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.7	56.3	57.0	62.5	68.2	72.9	75.6	74.4	71.8	69.7	63.0	59.1
		MCDB	59.5	59.2	62.8	74.1	78.3	85.6	89.0	84.9	81.1	77.1	66.2	61.0
	2%	WB	55.7	55.2	55.6	60.1	65.9	71.1	73.2	72.7	70.4	67.3	60.7	58.0
		MCDB	58.5	58.2	60.7	68.4	75.8	83.0	86.7	83.8	79.4	73.8	63.9	60.3
	5%	WB	53.8	53.9	54.4	58.5	64.4	69.8	71.7	71.6	69.2	65.6	59.4	56.6
		MCDB	56.9	57.2	59.2	66.0	73.5	81.3	84.2	82.6	77.8	71.2	63.0	59.3
	10%	WB	51.8	52.1	52.9	57.1	63.0	68.5	70.5	70.7	67.8	64.0	58.0	54.8
		MCDB	55.0	55.6	57.8	63.9	71.5	79.8	82.2	81.2	75.9	69.9	61.4	57.6
Mean Daily Temperature Range	5% DB	MDBR	7.6	8.7	9.3	11.2	12.9	14.5	14.4	13.7	12.4	9.4	8.0	7.2
		MCDBR	9.2	10.1	11.4	14.5	15.5	17.2	17.1	15.7	15.2	13.1	10.4	7.4
		MCWBR	7.4	7.9	7.4	8.0	7.6	7.7	7.0	5.7	7.3	7.2	7.5	6.2
	5% WB	MCDBR	8.6	9.4	10.6	13.2	14.1	15.9	15.3	14.2	13.7	11.8	10.0	7.2
MCWBR		7.4	8.2	7.6	8.1	8.0	7.6	7.4	6.4	7.8	7.7	8.1	6.4	
Clear-Sky Solar Irradiance	taub	0.364	0.393	0.431	0.472	0.444	0.430	0.431	0.437	0.429	0.412	0.387	0.373	
	taud	2.366	2.266	2.166	2.075	2.236	2.318	2.319	2.294	2.300	2.312	2.322	2.329	
	Ebn at Noon	248	256	259	256	266	270	268	263	257	247	236	233	
	Edh at Noon	28	35	43	50	44	41	40	40	37	33	29	27	
All-Sky Solar Radiation	RadAvg	548	817	1245	1685	2136	2367	2444	2153	1622	1066	687	488	
	RadStd	69	76	109	168	116	142	77	62	95	90	62	70	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (14 neighbors)	+0.90	N/A	N/A	N/A	N/A	N/A	-99	-250	+207	+104

Nomenclature: See separate page