

GOKCEADA, Turkey

WMO: 171100

Lat: 40.203N

Lon: 25.884E

Elev: 19

StdP: 101.10

Time Zone: 3.00 (E03)

Period: 86-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.2	(c) -0.8	(d) -7.0	(e) 2.1	(f) -0.3	(g) -5.5	(h) 2.4	(i) 0.7	(j) 13.4	(k) 1.9	(l) 12.6	(m) 1.8	(n) 8.4	(o) 20	(p) 0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.0	(c) 31.9	(d) 21.4	(e) 30.4	(f) 21.0	(g) 29.3	(h) 20.7	(i) 22.7	(j) 29.4	(k) 22.0	(l) 28.4	(m) 21.5	(n) 27.6	(o) 3.5	(p) 20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.6	15.3	25.9	19.9	14.6	25.4	19.2	14.0	25.1	67.1	29.5	64.5	28.5	62.5	27.5	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.5	(b) 10.2	(c) 9.1	(e) -4.0	(f) 35.0	(g) 2.3	(h) 1.8	(i) -5.7	(j) 36.3	(k) -7.0	(l) 37.3	(m) -8.2	(n) 38.3	(o) -9.9	(p) 39.6		
(a) 11.5	(b) 10.2	(c) 9.1	(e) -4.8	(f) 24.5	(g) 2.0	(h) 1.7	(i) -6.2	(j) 25.7	(k) -7.3	(l) 26.7	(m) -8.4	(n) 27.6	(o) -9.8	(p) 28.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.3	6.5	7.1	8.6	13.3	17.7	22.9	25.0	24.9	21.3	16.4	11.1	7.8
	DBStd	7.57	3.90	3.94	4.09	3.45	3.03	2.45	2.17	1.80	2.50	3.53	3.77	4.30
	HDD10.0	432	122	96	75	11	0	0	0	0	0	2	32	94
	HDD18.3	1813	366	314	302	154	48	1	0	0	5	79	218	326
	CDD10.0	2356	14	16	32	108	238	387	466	463	339	201	65	27
	CDD18.3	694	0	0	0	3	28	138	208	204	94	19	0	0
	CDH23.3	4514	0	0	0	7	97	904	1620	1430	400	55	1	0
	CDH26.7	1201	0	0	0	0	7	224	513	388	60	8	0	0
Wind	WSAvg	4.0	4.6	4.7	4.5	3.6	3.4	3.0	3.9	4.1	3.4	4.3	4.0	4.7
Precipitation	PrecAvg	733	116	99	76	48	31	20	16	11	32	51	99	133
	PrecMax	964	271	281	213	191	80	60	57	76	147	185	288	347
	PrecMin	483	0	4	20	3	0	0	0	0	0	9	7	0
	PrecStd	157	75	65	45	43	23	19	17	17	41	41	68	85
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.9	16.1	19.2	24.5	27.8	32.7	35.4	32.6	30.2	27.0	20.1	16.7
		MCWB	13.4	12.6	13.1	16.3	18.9	21.3	22.2	21.8	20.1	19.2	15.9	14.4
	2%	DB	15.0	15.2	17.2	21.5	25.7	30.5	32.7	31.1	28.5	24.8	18.5	16.0
		MCWB	13.0	12.2	12.6	15.0	17.8	20.6	21.8	21.5	20.3	19.0	15.5	14.1
	5%	DB	14.1	14.2	15.5	19.7	24.4	29.1	30.8	30.0	27.1	22.9	17.5	15.2
		MCWB	12.0	11.9	11.9	14.1	17.4	20.3	21.2	21.2	19.7	18.1	15.0	13.6
	10%	DB	12.9	13.2	14.3	18.4	23.0	27.7	29.3	28.9	25.8	21.2	16.5	14.3
		MCWB	11.0	11.1	11.3	13.7	16.9	19.8	20.7	20.9	19.0	17.5	14.3	12.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.3	13.5	13.9	17.0	20.1	22.7	24.2	23.5	22.1	20.9	17.2	15.0
		MCDB	15.3	15.1	17.1	23.4	25.7	29.8	31.6	29.4	27.3	25.1	19.0	16.1
	2%	WB	13.2	12.9	13.1	15.6	18.8	21.7	22.9	22.6	21.4	19.6	16.0	14.4
		MCDB	14.7	14.6	15.9	20.2	24.3	28.3	30.4	28.8	26.3	23.2	17.7	15.7
	5%	WB	12.1	12.2	12.4	14.7	18.0	21.0	22.1	22.0	20.7	18.7	15.2	13.7
		MCDB	13.9	14.0	15.1	18.9	23.0	27.4	29.0	28.1	25.4	21.8	17.2	15.2
	10%	WB	11.0	11.2	11.6	13.9	17.2	20.3	21.4	21.5	19.9	17.8	14.4	12.7
		MCDB	12.8	13.1	14.3	17.7	22.0	26.6	27.9	27.3	24.4	21.0	16.3	14.2
Mean Daily Temperature Range	5% DB	MDBR	4.2	4.8	5.2	6.2	7.2	8.1	8.0	7.6	6.9	5.2	4.4	4.0
		MCDBR	5.1	5.6	6.3	8.0	8.6	9.6	9.5	8.7	8.4	7.3	5.8	4.1
		MCWBR	4.1	4.4	4.1	4.5	4.2	4.3	3.9	3.2	4.1	4.0	4.2	3.5
	5% WB	MCDBR	4.8	5.2	5.9	7.3	7.8	8.8	8.5	7.9	7.6	6.6	5.6	4.0
MCWBR		4.1	4.5	4.2	4.5	4.4	4.2	4.1	3.6	4.3	4.3	4.5	3.5	
Clear-Sky Solar Irradiance	taub	0.364	0.393	0.431	0.472	0.444	0.430	0.431	0.437	0.429	0.412	0.387	0.373	
	taud	2.366	2.266	2.166	2.075	2.236	2.318	2.319	2.294	2.300	2.312	2.322	2.329	
	Ebn at Noon	781	808	815	806	839	850	845	829	810	778	744	733	
	Edh at Noon	88	111	136	159	138	128	126	126	118	105	91	85	
All-Sky Solar Radiation	RadAvg	1.73	2.58	3.92	5.31	6.73	7.46	7.70	6.79	5.11	3.36	2.17	1.54	
	RadStd	0.22	0.24	0.34	0.53	0.37	0.45	0.24	0.20	0.30	0.28	0.20	0.22	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	+0.50	N/A	N/A	N/A	N/A	N/A	N/A	-55	-139	+115

Nomenclature: See separate page