

CANAKKALE, Turkey

WMO: 171120

Lat: 40.1414N

Lon: 26.3995E

Elev: 20

StdP: 14.69

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.6	29.9	19.4	14.6	30.8	22.9	17.3	32.6	32.9	57.1	28.4	57.7	9.4	40	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.7	92.4	71.6	90.2	71.2	88.0	70.7	76.7	84.4	75.3	83.6	74.0	82.8	10.1	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.5	128.9	81.1	72.7	121.4	80.2	71.2	115.2	79.3	40.1	84.4	38.8	83.6	37.6	82.8	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.0	21.0	18.2	DB	23.0	96.5	3.8	2.9	20.3	98.6	18.0	100.3	15.9	101.9	13.1	104.0
			WB	21.4	78.9	4.5	2.3	18.2	80.5	15.6	81.9	13.0	83.2	9.8	84.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.4	43.9	45.0	48.6	55.5	64.8	73.3	78.7	79.1	71.1	61.9	54.2	47.0
	DBStd	13.77	7.48	7.17	5.92	5.22	4.47	4.70	3.27	3.58	4.60	5.72	6.93	7.81
	HDD50	685	217	167	97	13	0	0	0	0	0	2	36	153
	HDD65	3090	653	561	508	286	59	2	0	0	8	126	328	559
	CDD50	4465	29	27	55	179	458	700	889	901	633	372	162	60
	CDD65	1393	0	0	0	2	52	252	424	436	192	30	4	1
	CDH74	11882	0	0	0	12	244	1972	4161	4219	1189	83	2	0
	CDH80	4289	0	0	0	1	25	630	1680	1697	249	7	0	0
Wind	WSAvg	8.1	8.7	9.2	8.6	7.5	7.2	7.0	8.0	8.9	7.7	7.7	8.1	8.6
Precipitation	PrecAvg	24.5	3.5	2.8	2.5	1.9	1.2	0.9	0.5	0.2	1.0	2.2	3.4	4.4
	PrecMax	38.5	10.2	7.8	7.0	4.8	3.7	3.0	3.4	1.3	7.7	11.8	8.7	11.3
	PrecMin	13.5	0.0	0.0	0.3	0.2	0.0	0.0	0.0	0.0	0.0	0.3	0.1	
	PrecStd	5.9	2.3	1.8	1.6	1.2	1.0	0.8	0.7	0.3	1.4	1.9	2.3	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.9	63.9	67.2	74.9	82.9	92.5	95.9	95.9	88.9	80.2	73.0	67.3
		MCWB	56.7	56.1	56.0	59.6	66.2	71.1	72.2	71.8	69.0	68.0	63.3	59.3
	2%	DB	60.0	60.0	62.9	69.8	79.4	89.3	92.2	92.8	85.3	76.0	69.5	63.6
		MCWB	54.7	54.1	54.7	59.0	64.7	70.5	71.6	72.0	68.6	66.1	62.4	58.1
	5%	DB	57.5	57.5	60.3	66.8	76.6	86.3	90.0	90.4	82.8	73.7	67.1	61.2
		MCWB	53.2	52.7	54.0	57.5	64.2	69.3	71.4	71.4	68.1	65.1	61.4	56.7
	10%	DB	55.2	55.5	58.1	64.2	74.0	83.6	88.0	88.1	80.4	71.5	64.8	58.9
		MCWB	51.8	51.7	53.0	56.5	63.2	68.9	70.8	71.1	68.1	63.8	59.6	55.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.6	56.8	59.2	62.8	70.1	76.1	78.7	79.2	75.3	71.4	65.5	60.9
		MCDB	61.7	61.8	64.1	69.4	76.6	83.4	86.2	87.3	81.5	76.2	69.0	64.8
	2%	WB	55.3	54.9	56.3	60.8	67.7	74.0	76.8	76.9	73.0	68.6	63.4	58.6
		MCDB	58.7	58.7	60.6	67.3	74.7	83.0	84.6	84.7	79.2	73.6	68.1	62.9
	5%	WB	53.7	53.4	54.8	59.2	66.2	72.5	75.3	75.4	71.6	66.4	61.9	56.9
		MCDB	57.2	56.9	59.3	64.9	73.1	81.7	83.8	83.9	78.5	72.1	66.4	61.0
	10%	WB	51.9	51.8	53.4	57.7	64.8	71.0	74.0	74.1	70.0	64.8	60.2	55.1
		MCDB	54.9	55.2	57.6	63.0	71.7	80.0	83.0	83.1	77.5	70.3	64.5	58.7
Mean Daily Temperature Range	5% DB	MDBR	10.6	11.0	12.6	14.0	15.9	17.9	18.3	17.7	16.2	13.6	12.6	10.9
		MCDBR	11.3	12.3	15.6	19.0	20.4	21.6	21.5	20.9	20.4	17.1	13.3	10.9
		MCWBR	8.4	8.7	9.7	10.4	9.4	8.5	8.4	7.8	9.7	9.9	9.0	8.0
	5% WB	MCDBR	10.3	10.7	13.3	15.9	16.9	18.9	18.0	17.7	16.9	14.6	12.0	10.1
		MCWBR	8.3	8.2	9.3	9.8	9.6	9.3	8.7	8.7	10.6	9.8	9.0	7.7
Clear-Sky Solar Irradiance	taub	0.368	0.398	0.438	0.481	0.449	0.432	0.433	0.439	0.431	0.416	0.389	0.375	
	taud	2.333	2.228	2.125	2.030	2.200	2.291	2.292	2.269	2.273	2.282	2.299	2.307	
	Ebn at Noon	246	254	256	253	265	269	267	262	256	245	235	231	
	Edh at Noon	29	36	45	53	45	42	41	41	38	34	30	28	
All-Sky Solar Radiation	RadAvg	559	811	1231	1654	2090	2329	2420	2130	1610	1066	697	501	
	RadStd	71	77	108	176	125	154	83	70	97	92	63	67	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (15 neighbors)	+0.94	N/A	N/A	N/A	N/A	N/A	-99	-250	+207	+104

Nomenclature: See separate page