

CANAKKALE, Turkey

WMO: 171120

Lat: 40.1414N

Lon: 26.3995E

Elev: 6

StdP: 101.25

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.0	-1.2	-7.0	2.1	-0.7	-5.0	2.5	0.4	14.7	14.0	12.7	14.3	4.2	40	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.8	33.6	22.0	32.3	21.8	31.1	21.5	24.8	29.1	24.0	28.7	23.3	28.2	4.5	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.6	18.4	27.3	22.6	17.3	26.8	21.8	16.5	26.3	75.5	29.1	72.3	28.6	69.5	28.2	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.2	9.4	8.2	-5.0	35.8	2.1	1.6	-6.5	37.0	-7.8	37.9	-9.0	38.8	-10.5	40.0		
			-5.9	26.0	2.5	1.3	-7.7	27.0	-9.1	27.7	-10.5	28.4	-12.3	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.8	6.6	7.2	9.2	13.1	18.2	23.0	25.9	26.1	21.7	16.6	12.3	8.3
	DBStd	7.65	4.16	3.98	3.29	2.90	2.49	2.61	1.82	1.99	2.56	3.18	3.85	4.34
	HDD10.0	381	121	93	54	7	0	0	0	0	0	1	20	85
	HDD18.3	1717	363	312	282	159	33	1	0	0	4	70	182	311
	CDD10.0	2481	16	15	31	99	254	389	494	501	352	207	90	33
	CDD18.3	774	0	0	0	1	29	140	236	242	107	17	2	1
	CDH23.3	6601	0	0	0	7	136	1096	2312	2344	661	46	1	0
	CDH26.7	2383	0	0	0	1	14	350	933	943	138	4	0	0
Wind	WSAvg	3.6	3.9	4.1	3.8	3.4	3.2	3.1	3.6	4.0	3.5	3.4	3.6	3.9
Precipitation	PrecAvg	623	89	72	64	48	31	24	13	4	25	56	87	113
	PrecMax	978	258	197	177	123	93	75	87	34	195	300	222	288
	PrecMin	342	0	1	8	4	0	0	0	0	0	0	8	2
	PrecStd	149	59	46	40	31	25	20	19	7	35	49	59	66
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.2	17.7	19.6	23.8	28.3	33.6	35.5	35.5	31.6	26.8	22.8	19.6
		MCWB	13.7	13.4	13.4	15.4	19.0	21.7	22.3	22.1	20.6	20.0	17.4	15.2
	2%	DB	15.6	15.5	17.1	21.0	26.3	31.8	33.4	33.8	29.6	24.4	20.8	17.5
		MCWB	12.6	12.3	12.6	15.0	18.2	21.4	22.0	22.2	20.3	18.9	16.9	14.5
	5%	DB	14.2	14.2	15.7	19.3	24.8	30.1	32.2	32.5	28.2	23.2	19.5	16.2
		MCWB	11.8	11.5	12.2	14.2	17.9	20.7	21.9	21.9	20.1	18.4	16.3	13.7
	10%	DB	12.9	13.1	14.5	17.9	23.3	28.7	31.1	31.2	26.9	21.9	18.2	14.9
		MCWB	11.0	10.9	11.7	13.6	17.3	20.5	21.6	21.7	20.0	17.7	15.4	12.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.2	13.8	15.1	17.1	21.1	24.5	26.0	26.2	24.0	21.9	18.6	16.0
		MCDB	16.5	16.5	17.8	20.8	24.8	28.6	30.1	30.7	27.5	24.6	20.6	18.2
	2%	WB	12.9	12.7	13.5	16.0	19.8	23.3	24.9	25.0	22.8	20.4	17.5	14.8
		MCDB	14.8	14.9	15.9	19.6	23.7	28.3	29.2	29.3	26.2	23.1	20.0	17.1
	5%	WB	12.1	11.9	12.7	15.1	19.0	22.5	24.1	24.1	22.0	19.1	16.6	13.9
		MCDB	14.0	13.8	15.2	18.3	22.8	27.6	28.8	28.8	25.9	22.3	19.1	16.1
	10%	WB	11.1	11.0	11.9	14.3	18.2	21.7	23.4	23.4	21.1	18.2	15.7	12.9
		MCDB	12.7	12.9	14.2	17.2	22.0	26.7	28.4	28.4	25.3	21.3	18.1	14.8
Mean Daily Temperature Range	5% DB	MDBR	5.9	6.1	7.0	7.8	8.8	9.9	10.2	9.8	9.0	7.6	7.0	6.0
		MCDBR	6.3	6.8	8.6	10.6	11.4	12.0	12.0	11.6	11.3	9.5	7.4	6.0
		MCWBR	4.6	4.8	5.4	5.8	5.2	4.7	4.7	4.4	5.4	5.5	5.0	4.4
	5% WB	MCDBR	5.7	6.0	7.4	8.9	9.4	10.5	10.0	9.9	9.4	8.1	6.7	5.6
		MCWBR	4.6	4.6	5.2	5.4	5.3	5.2	4.9	4.8	5.9	5.4	5.0	4.3
Clear-Sky Solar Irradiance	taub	0.368	0.398	0.438	0.481	0.449	0.432	0.433	0.439	0.431	0.416	0.389	0.375	
	taud	2.333	2.228	2.125	2.030	2.200	2.291	2.292	2.269	2.273	2.282	2.299	2.307	
	Ebn at Noon	774	801	808	798	835	848	843	827	807	772	740	729	
	Edh at Noon	91	115	142	166	143	131	130	129	121	108	93	87	
All-Sky Solar Radiation	RadAvg	1.76	2.56	3.88	5.21	6.59	7.34	7.63	6.72	5.07	3.36	2.20	1.58	
	RadStd	0.22	0.24	0.34	0.56	0.40	0.48	0.26	0.22	0.31	0.29	0.20	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	+0.90	-0.71	-1.15	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.52	N/A	N/A	N/A	N/A	N/A	-55	-139	+115	+58

Nomenclature: See separate page