

YENISEHIR, Turkey

WMO: 171180

Lat: 40.255N

Lon: 29.563E

Elev: 764

StdP: 14.29

Time Zone: 3.00 (E03)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.3	23.1	16.1	12.8	20.7	19.8	15.3	27.4	24.5	51.3	21.7	49.3	2.2	20	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	27.9	93.6	69.1	91.3	68.9	88.5	68.4	73.3	87.2	71.9	85.0	70.6	83.5	10.8	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.8	108.7	79.9	67.6	104.4	78.9	66.1	99.0	77.4	37.4	86.8	36.0	85.0	34.9	84.1	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.8	17.4	15.3	11.5	100.2	7.3	3.2	6.2	102.5	1.9	104.3	-2.2	106.1	-7.6	108.4		
(5)			10.9	75.4	7.3	1.9	5.7	76.8	1.4	77.9	-2.7	78.9	-8.0	80.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.6	38.4	42.5	47.3	53.7	62.3	69.4	73.4	74.3	67.4	58.7	49.5	41.4		
	DBStd	13.81	8.09	7.89	6.65	6.65	5.68	4.57	3.69	3.84	4.94	5.86	7.34	7.61		
	HDD50	1154	367	228	132	37	1	0	0	0	0	7	96	286		
	HDD65	3913	824	630	550	342	120	11	0	0	31	207	467	731		
	CDD50	3565	8	19	48	147	382	582	725	754	523	276	81	20		
	CDD65	847	0	0	0	2	36	144	260	289	104	10	2	0		
	CDH74	11106	0	1	8	144	665	1942	3335	3448	1340	201	20	2		
	CDH80	4531	0	0	1	21	178	761	1481	1569	482	38	0	0		
	WSAvg	5.3	5.6	5.8	5.7	5.0	4.8	5.4	6.3	6.0	5.1	4.1	4.2	5.1		
	PrecAvg	23.2	2.3	2.1	2.2	2.4	1.9	1.7	0.9	0.9	1.3	2.3	2.3	2.9		
(15) Precipitation	PrecMax	30.8	4.3	4.3	4.1	6.8	5.6	4.7	2.7	3.7	3.3	5.7	4.8	8.0		
	PrecMin	17.3	0.4	0.4	0.7	0.4	0.4	0.0	0.0	0.1	0.0	0.2	0.5	0.7		
	PrecStd	3.9	1.1	1.0	0.8	1.4	1.2	1.1	0.7	0.9	1.0	1.3	1.1	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.3	69.8	73.8	82.6	89.4	96.5	98.2	97.1	95.0	84.6	77.0	68.8		
		MCWB	51.1	54.5	55.6	62.3	66.0	69.8	70.4	68.7	68.1	62.3	58.5	54.9		
	2%	DB	59.2	64.3	69.6	78.5	84.5	91.1	93.2	93.4	89.4	79.0	71.6	62.3		
		MCWB	48.5	51.9	53.6	60.6	65.5	68.7	70.0	69.1	66.6	61.3	56.7	52.3		
	5%	DB	55.6	60.4	66.1	73.7	80.9	87.7	90.0	91.1	85.6	75.2	67.1	57.4		
		MCWB	47.1	50.2	52.6	58.5	63.8	67.3	69.0	69.6	65.8	60.6	55.4	50.2		
	10%	DB	51.7	55.7	62.2	69.5	77.2	84.4	87.8	88.1	82.1	71.3	62.7	53.5		
		MCWB	45.7	47.7	51.1	56.3	62.3	66.6	68.6	69.3	64.6	59.9	53.8	47.9		
	0.4%	WB	52.0	56.7	58.3	65.1	69.6	73.2	75.3	75.4	71.4	66.1	61.1	56.2		
		MCDB	62.5	66.3	71.3	78.6	84.9	88.6	90.7	88.8	84.7	76.3	70.8	65.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	49.6	53.0	55.1	62.0	67.0	71.0	73.0	73.7	69.7	64.1	58.1	53.2		
		MCDB	57.9	61.8	65.6	76.1	80.3	84.6	87.5	86.9	82.5	74.4	69.0	60.3		
	5%	WB	47.9	50.6	53.3	59.4	65.2	69.4	71.3	72.4	67.8	62.5	56.1	50.7		
		MCDB	54.7	58.0	63.6	71.9	77.6	82.3	84.9	85.1	80.2	71.0	65.6	56.3		
	10%	WB	45.8	48.7	51.4	57.0	63.6	67.8	70.1	71.0	66.3	60.9	54.2	48.7		
		MCDB	51.0	55.1	60.1	67.8	75.0	81.1	83.7	83.4	77.7	68.6	62.2	53.3		
	5% DB	MDBR	16.3	18.6	22.4	26.4	26.1	27.1	28.3	27.9	27.1	23.2	22.0	17.0		
		MCDBR	22.4	26.7	31.5	35.2	33.3	33.3	32.8	31.9	35.2	31.6	28.0	21.1		
		MCWBR	13.8	15.8	17.6	19.0	15.8	13.5	12.8	12.0	14.7	15.5	16.0	12.9		
		MCWBR	20.7	24.6	28.0	32.5	29.1	28.7	28.0	26.4	27.8	24.2	25.5	18.8		
(40) Clear-Sky Solar Irradiance	taub		0.341	0.369	0.411	0.452	0.427	0.411	0.411	0.417	0.403	0.386	0.353	0.342		
		taud	2.380	2.293	2.187	2.093	2.237	2.322	2.332	2.314	2.341	2.370	2.414	2.406		
	Ebn at Noon		257	265	265	261	271	275	273	269	265	256	250	246		
		Edn at Noon	27	34	42	49	44	40	40	39	36	31	26	25		
(44) All-Sky Solar Radiation	RadAvg		532	770	1144	1544	1920	2193	2300	2020	1524	1022	700	494		
	RadStd		75	115	110	175	169	203	92	126	125	88	87	75		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		+0.85	N/A	N/A	N/A	N/A	N/A	-175	N/A	+83

Nomenclature: See separate page