

ANKARA GÜVERCİNLİK, Turkey

WMO: 171310

Lat: 39.935N

Lon: 32.741E

Elev: 821

StdP: 91.84

Time Zone: 3.00 (E03)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.2	-8.0	-13.5	1.3	-7.0	-11.4	1.6	-4.7	8.9	7.7	7.8	6.6	1.1	220	0.478

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	35.0	17.4	33.2	17.1	31.9	16.8	19.2	29.8	18.5	29.2	17.9	28.4	3.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	12.5	22.7	15.0	11.8	21.7	14.1	11.1	21.5	57.9	29.7	55.6	29.1	53.6	28.5	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.1	6.9	6.0	-13.2	37.0	2.8	1.2	-15.2	37.9	-16.8	38.6	-18.4	39.3	-20.5	40.2		
			-14.7	20.3	3.7	1.3	-17.4	21.3	-19.6	22.0	-21.7	22.7	-24.4	23.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.5	0.8	2.8	6.9	11.2	16.2	20.4	23.9	24.1	19.2	13.5	7.2	2.7	(6)
(7)		DBStd	8.82	4.74	4.49	3.96	3.64	3.11	2.87	2.43	2.61	3.25	3.71	3.75	4.17	(7)
(8)		HDD10.0	968	286	203	110	28	1	0	0	0	13	99	228		(8)
(9)		HDD18.3	2641	543	434	355	215	81	12	0	1	28	152	334	486	(9)
(10)		CDD10.0	1867	1	2	13	64	193	313	432	436	274	123	15	1	(10)
(11)		CDD18.3	499	0	0	0	1	15	75	174	178	53	3	0	0	(11)
(12)		CDH23.3	6307	0	0	2	32	258	913	2138	2125	751	88	0	0	(12)
(13)		CDH26.7	2636	0	0	0	3	59	319	991	992	262	11	0	0	(13)
(14)	Wind	WSAvg	2.3	2.0	2.2	2.6	2.5	2.4	2.6	2.8	2.6	2.2	1.8	1.6	1.9	(14)
(15)	Precipitation	PrecAvg	392	37	31	43	49	48	36	14	17	18	28	30	42	(15)
(16)		PrecMax	522	95	78	118	92	172	109	66	67	68	70	63	136	(16)
(17)		PrecMin	268	4	9	13	14	7	0	1	0	0	2	4	2	(17)
(18)		PrecStd	73	21	19	29	27	35	28	16	17	20	16	19	31	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	17.5	22.1	27.0	30.8	34.0	37.5	37.0	34.1	28.0	21.1	15.0	(19)
(20)			MCWB	7.5	8.8	10.1	13.2	15.1	17.0	17.5	17.5	16.1	14.3	11.7	9.6	(20)
(21)		2%	DB	10.9	14.2	19.0	23.6	28.1	31.9	35.1	35.0	31.7	25.8	19.0	12.2	(21)
(22)			MCWB	6.6	8.0	9.4	12.2	14.8	16.7	17.5	17.4	15.6	13.7	11.1	8.0	(22)
(23)		5%	DB	9.0	12.1	16.9	21.2	26.2	30.0	33.2	33.2	29.9	23.9	16.8	10.5	(23)
(24)			MCWB	5.9	6.8	8.6	11.3	14.5	16.4	17.2	17.2	15.1	13.3	10.1	7.3	(24)
(25)		10%	DB	7.2	10.1	14.8	19.1	24.1	28.2	31.8	31.9	27.8	21.7	14.2	8.9	(25)
(26)			MCWB	5.0	6.1	7.9	10.5	13.7	15.8	17.0	17.1	14.7	12.6	9.0	6.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	10.3	11.2	14.3	16.9	18.9	20.2	20.5	18.0	15.6	13.5	9.9	(27)
(28)			MCDWB	12.0	15.9	19.2	22.9	26.0	29.2	31.1	30.7	28.5	22.8	18.8	13.9	(28)
(29)		2%	WB	7.1	8.4	10.0	13.1	16.0	18.0	19.2	19.3	17.0	14.8	12.0	8.6	(29)
(30)			MCDWB	10.3	13.2	16.6	21.3	24.7	27.9	30.1	29.7	26.9	21.9	17.1	11.5	(30)
(31)		5%	WB	6.0	7.2	9.1	12.2	15.2	17.3	18.5	18.6	16.2	14.2	10.8	7.7	(31)
(32)			MCDWB	8.1	11.4	15.2	19.5	23.8	26.9	29.4	29.3	25.9	21.4	15.4	10.1	(32)
(33)		10%	WB	5.0	6.2	8.3	11.3	14.5	16.7	17.8	18.1	15.6	13.4	9.5	6.6	(33)
(34)			MCDWB	7.0	9.5	13.8	17.9	22.5	25.9	28.6	28.6	25.0	20.1	13.7	8.7	(34)
(35)	Mean Daily Temperature Range	MDBR	7.6	9.9	11.4	12.3	13.0	13.7	14.4	14.3	14.8	13.3	12.1	8.2	(35)	
(36)		5% DB	MCDBR	10.6	13.7	15.8	16.0	16.3	16.7	16.3	18.0	17.0	15.7	10.6	(36)	
(37)			MCWBR	6.9	8.0	7.8	7.0	6.0	5.2	5.1	5.0	6.5	7.5	8.5	6.8	(37)
(38)			MCDBR	8.8	11.8	13.1	13.9	14.0	14.4	14.9	14.2	14.7	13.8	13.1	9.4	(38)
(39)		5% WB	MCWBR	6.0	7.1	6.9	6.5	5.6	5.0	5.0	4.8	5.7	6.4	7.3	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.307	0.333	0.376	0.412	0.392	0.372	0.369	0.367	0.348	0.348	0.317	0.307	(40)	
(41)		taud	2.381	2.327	2.225	2.150	2.275	2.351	2.355	2.338	2.392	2.389	2.447	2.438	(41)	
(42)		Ebn at Noon	855	879	873	861	887	902	901	895	893	851	838	827	(42)	
(43)		Edh at Noon	85	103	128	147	133	123	122	120	107	96	79	75	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.88	2.88	4.03	5.17	6.15	7.00	7.41	6.60	5.20	3.55	2.46	1.67	(44)	
(45)		RadStd	0.23	0.42	0.36	0.46	0.44	0.58	0.31	0.27	0.35	0.25	0.24	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page