

KIRSEHIR, Turkey

WMO: 171600

Lat: 39.1644N

Lon: 34.1558E

Elev: 3304

StdP: 13.02

Time Zone: 3.00 (E03)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.1	15.4	4.4	7.8	12.8	9.3	10.0	17.2	22.7	31.8	19.3	30.6	4.6	350	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 23.2	(c) 94.5	(d) 63.0	(e) 91.5	(f) 62.7	(g) 88.4	(h) 62.1	(i) 66.2	(j) 85.2	(k) 64.8	(l) 84.2	(m) 63.7	(n) 83.0	(o) 6.7	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.8	86.6	73.6	58.1	81.4	72.7	56.5	76.9	71.6	32.7	85.0	31.7	84.0	30.7	83.3	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 19.9	(b) 16.9	(c) 14.5	(e) 5.0	(f) 99.0	(g) 10.0	(h) 2.7	(i) -2.2	(j) 100.9	(k) -8.1	(l) 102.5	(m) -13.7	(n) 104.1	(o) -21.0	(p) 106.0		
			DB			5.0	99.0	10.0	2.7	-2.2	100.9	-8.1	102.5	-13.7	104.1	-21.0
			WB			4.2	68.8	9.7	3.3	-2.8	71.2	-8.4	73.1	-13.9	74.9	-20.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.4	32.6	36.8	43.5	52.8	60.7	68.3	75.4	75.7	67.2	57.0	45.3	35.9
	DBStd	16.40	9.23	8.90	7.63	6.67	5.78	5.37	5.14	4.95	5.76	7.10	7.22	8.52
	HDD50	1817	541	372	224	45	2	0	0	0	0	22	170	441
	HDD65	4809	1005	789	667	367	156	27	1	2	42	259	590	904
	CDD50	3413	0	3	22	129	335	548	789	798	516	240	30	3
	CDD65	929	0	0	0	2	23	125	325	334	108	12	0	0
	CDH74	9969	0	0	0	52	349	1319	3461	3496	1160	132	0	0
	CDH80	3981	0	0	0	1	67	429	1543	1567	358	16	0	0
Wind	WSAvg	5.7	4.4	5.3	5.6	5.7	5.3	6.4	8.2	7.8	5.9	5.1	4.1	4.3
Precipitation	PrecAvg	15.6	1.8	1.5	1.5	1.8	1.7	1.4	0.3	0.2	0.6	1.1	1.6	2.0
	PrecMax	19.9	5.7	3.7	3.1	3.7	3.8	3.7	1.6	1.5	1.9	4.5	4.5	3.5
	PrecMin	11.9	0.2	0.3	0.2	0.3	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.2
	PrecStd	2.4	1.2	0.9	0.7	0.9	0.8	1.1	0.4	0.3	0.5	1.1	1.3	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	63.4	70.9	78.9	86.3	92.5	98.1	98.4	91.9	82.4	69.6	60.3
		MCWB	44.2	47.2	50.6	54.5	59.2	61.9	63.1	63.3	61.5	57.1	51.9	47.7
	2%	DB	51.1	58.1	65.3	75.0	81.1	88.2	94.9	95.0	87.6	77.4	65.1	54.4
		MCWB	42.5	45.3	48.4	53.6	58.2	61.5	63.3	63.0	59.8	56.2	50.7	46.0
	5%	DB	47.7	53.9	61.2	70.4	77.9	85.0	91.9	91.7	84.1	74.1	61.6	50.8
		MCWB	41.1	43.8	46.7	52.0	57.3	60.9	63.0	62.8	59.0	55.5	48.8	43.9
	10%	DB	44.8	49.9	57.3	66.3	74.2	81.5	88.3	88.4	80.8	70.1	57.6	47.5
		MCWB	39.5	41.9	45.3	50.6	56.2	59.7	62.4	62.5	58.4	54.2	47.2	42.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.6	49.2	52.1	56.4	61.9	65.3	68.4	67.8	64.3	59.2	54.4	49.9
		MCDB	52.3	59.0	65.1	73.1	79.3	84.6	88.5	87.2	83.3	75.5	65.2	55.7
	2%	WB	43.3	45.9	49.8	54.4	59.9	63.6	66.6	66.1	62.0	57.6	51.8	46.9
		MCDB	49.2	55.1	61.4	70.5	76.3	82.0	85.7	85.3	80.9	73.2	62.3	52.8
	5%	WB	41.6	44.2	47.8	53.0	58.5	62.1	65.2	64.9	60.7	56.4	49.8	44.7
		MCDB	47.2	52.7	59.0	67.6	74.3	79.1	84.3	84.4	79.5	71.0	59.2	49.6
	10%	WB	39.7	42.2	46.0	51.6	57.2	61.0	63.8	63.8	59.5	55.1	48.0	42.7
		MCDB	44.4	49.4	55.6	64.5	71.7	78.0	83.2	83.4	77.2	68.0	56.0	47.1
Mean Daily Temperature Range	5% DB	MDBR	14.4	16.9	19.3	21.4	22.1	22.7	23.3	23.2	24.1	21.3	19.9	14.8
		MCDBR	18.7	23.8	26.6	28.3	28.1	27.3	27.7	27.4	28.7	26.7	26.1	19.3
		MCWBR	11.7	13.1	13.6	12.6	11.0	9.2	8.6	8.9	10.8	11.6	14.1	11.8
	5% WB	MCDBR	17.3	21.9	23.6	24.6	25.3	24.1	23.7	23.4	24.8	23.4	23.0	16.4
		MCWBR	11.0	12.3	12.7	11.6	10.4	8.7	8.1	7.9	9.8	10.4	12.8	10.3
Clear-Sky Solar Irradiance	taub		0.305	0.335	0.375	0.417	0.393	0.365	0.364	0.364	0.341	0.349	0.316	0.303
	taud		2.375	2.303	2.204	2.111	2.251	2.348	2.345	2.318	2.386	2.354	2.418	2.427
	Ebn at Noon		274	279	278	272	281	289	288	285	287	271	268	266
	Edh at Noon		27	34	42	49	43	39	39	39	34	32	26	24
All-Sky Solar Radiation	RadAvg		631	957	1316	1683	2007	2305	2409	2167	1719	1183	812	572
	RadStd		75	129	104	144	124	154	93	63	101	74	75	69

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	+0.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page