

DIKILI, Turkey

WMO: 171800

Lat: 39.0739N

Lon: 26.8881E

Elev: 3

StdP: 101.29

Time Zone: 3.00 (E03)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.6	0.7	-5.5	2.4	1.1	-4.2	2.7	2.1	7.7	10.8	6.5	9.5	1.8	160	0.359

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	33.3	22.1	31.6	22.5	30.2	22.8	24.9	30.0	24.2	29.4	23.7	28.9	3.2	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	18.0	29.0	22.5	17.2	28.5	21.8	16.4	27.9	75.9	30.1	73.3	29.5	70.9	29.1	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.4	6.3	5.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB												
			WB	-4.7	25.9	1.8	0.3	-6.0	26.2	-7.0	26.4	-8.1	26.6	-9.4	26.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	7.7	8.7	11.0	14.7	18.7	23.5	26.1	25.9	22.2	18.4	13.0	9.8
	DBStd	7.13	3.38	3.45	3.25	3.18	2.96	2.29	1.89	2.06	2.30	3.15	3.58	4.00
	HDD10.0	250	89	59	29	3	0	0	0	0	0	16	53	
	HDD18.3	1438	331	269	228	114	31	1	0	1	37	162	264	
	CDD10.0	2693	17	23	59	146	270	406	499	493	367	261	105	47
	CDD18.3	840	0	0	0	7	43	157	241	234	118	39	1	1
	CDH23.3	6449	0	0	0	15	153	1099	2242	2141	653	144	1	0
	CDH26.7	1886	0	0	0	1	24	242	748	731	124	16	0	0
Wind	WSAvg	2.3	1.9	2.2	2.3	2.3	2.5	2.7	2.5	2.4	2.4	1.9	2.0	2.2
Precipitation	PrecAvg	622	88	92	62	51	26	14	4	4	21	56	91	112
	PrecMax	904	213	226	157	118	91	39	13	33	77	182	239	293
	PrecMin	377	1	11	6	8	0	1	0	0	0	6	0	0
	PrecStd	144	58	57	36	23	23	13	3	6	22	49	62	72
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.7	18.1	21.2	25.5	29.4	33.4	35.2	35.8	32.3	28.6	22.2	19.6
		MCWB	14.5	13.3	14.2	17.0	20.6	20.9	22.5	23.1	22.5	21.6	17.4	14.9
	2%	DB	15.9	16.4	19.0	22.9	26.4	30.8	33.5	33.0	29.5	26.6	20.9	18.0
		MCWB	12.8	12.6	14.2	16.7	20.0	21.6	22.0	22.6	22.6	21.0	16.6	14.4
	5%	DB	14.5	15.4	17.7	21.4	24.9	29.2	31.9	31.4	28.1	24.9	19.4	17.0
		MCWB	11.6	12.1	13.5	16.1	19.4	22.1	22.0	23.3	22.1	20.3	15.5	13.8
	10%	DB	12.9	14.2	16.4	19.9	23.6	27.9	30.2	30.1	26.7	23.4	18.1	15.8
		MCWB	10.4	11.3	12.4	15.6	18.7	21.6	22.4	23.7	21.3	19.3	14.8	13.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.6	14.1	15.5	18.7	21.8	24.6	25.2	26.0	24.7	22.9	18.1	15.5
		MCDB	17.3	17.1	19.1	22.7	26.5	29.6	30.8	30.4	29.3	27.2	21.3	18.5
	2%	WB	13.0	13.1	14.7	17.7	20.7	23.6	24.5	25.2	23.6	21.6	17.0	14.6
		MCDB	15.5	15.9	18.2	21.8	25.7	28.5	30.1	30.0	28.3	25.6	20.4	17.5
	5%	WB	11.9	12.3	13.8	16.7	20.0	22.9	23.9	24.6	22.6	20.6	15.9	13.9
		MCDB	14.3	15.0	17.3	20.6	24.3	27.8	29.6	29.6	27.3	24.5	18.9	16.7
	10%	WB	10.7	11.4	12.9	15.7	19.1	22.1	23.3	24.0	21.7	19.6	15.0	13.2
		MCDB	12.7	14.0	15.9	19.5	23.2	27.1	28.9	29.1	26.1	23.2	17.7	15.7
Mean Daily Temperature Range	5% DB	MDBR	6.7	7.4	8.1	7.8	7.7	8.2	8.5	8.6	8.4	7.6	7.0	6.0
		MCDBR	7.6	8.3	9.2	9.3	8.8	10.1	11.2	10.8	9.9	9.2	7.8	6.4
		MCWBR	5.8	6.0	6.2	5.8	5.4	5.9	5.3	5.5	6.2	6.3	5.4	4.5
	5% WB	MCDBR	7.2	7.7	8.7	8.4	7.8	7.9	8.6	8.5	8.3	8.5	7.2	5.4
		MCWBR	5.5	5.8	6.2	6.0	5.5	5.8	5.6	5.6	6.1	6.4	5.3	3.9
Clear-Sky Solar Irradiance	taub	0.360	0.393	0.429	0.469	0.441	0.411	0.409	0.413	0.408	0.402	0.378	0.365	
	taud	2.379	2.262	2.160	2.077	2.226	2.352	2.358	2.337	2.345	2.338	2.357	2.371	
	Ebn at Noon	797	815	822	812	844	868	866	854	835	796	768	759	
	Edh at Noon	88	113	138	159	140	124	122	121	114	104	90	84	
All-Sky Solar Radiation	RadAvg	1.92	2.66	4.06	5.33	6.63	7.49	7.78	6.88	5.34	3.68	2.44	1.75	
	RadStd	0.23	0.27	0.32	0.53	0.36	0.46	0.20	0.21	0.30	0.26	0.22	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	-114	+105	+52

Nomenclature: See separate page