

KAYSERI ERKILET, Turkey

WMO: 171950

Lat: 38.773N

Lon: 35.491E

Elev: 3458

StdP: 12.95

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.3	12.0	1.3	6.7	9.6	6.6	8.7	14.9	26.8	44.2	22.6	45.4	3.3	30	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.6	94.7	62.7	91.4	62.1	88.2	61.2	66.1	85.0	64.4	84.2	63.1	82.6	6.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.6	86.6	72.1	57.6	80.6	70.7	55.8	75.5	69.5	32.8	85.2	31.4	83.5	30.4	82.6	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.2	16.5	13.4	-0.4	99.3	7.7	2.5	-5.9	101.1	-10.4	102.6	-14.8	104.0	-20.4	105.8		
(5)			-0.9	69.0	7.5	2.5	-6.3	70.7	-10.7	72.2	-14.9	73.6	-20.4	75.4	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	31.1	34.3	42.6	51.2	59.2	66.3	71.9	72.1	64.1	54.5	43.0	34.4	(6)	(7)
	DBStd	15.87	9.13	9.74	7.46	6.91	5.81	4.98	4.65	4.58	5.87	6.72	7.17	8.51	(7)	(8)
	HDD50	2089	586	441	248	66	3	0	0	0	1	34	224	486	(8)	(9)
	HDD65	5287	1051	860	694	415	196	44	2	4	82	328	661	950	(9)	(10)
	CDD50	2874	0	1	19	102	288	489	678	684	425	174	13	1	(10)	(11)
	CDD65	596	0	0	0	2	15	82	215	223	56	3	0	0	(11)	(12)
	CDH74	9583	0	0	4	72	401	1372	3171	3178	1223	162	0	0	(12)	(13)
	CDH80	3999	0	0	0	10	83	470	1494	1500	420	22	0	0	(13)	(14)
(14) Wind	WSAvg	4.9	4.7	5.2	5.9	5.7	5.3	5.4	5.4	5.0	4.3	3.8	3.5	4.2	(14)	(15)
(15) Precipitation	PrecAvg	14.5	1.2	1.3	1.5	2.1	2.0	1.5	0.4	0.2	0.6	1.1	1.3	1.7	(15)	(16)
	PrecMax	21.1	2.9	3.0	3.4	5.2	4.5	6.5	2.4	0.9	1.9	3.7	3.1	3.5	(16)	(17)
	PrecMin	10.2	0.0	0.1	0.4	0.3	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.2	(17)	(18)
	PrecStd	2.6	0.7	0.7	0.7	1.0	1.0	1.2	0.6	0.3	0.6	0.9	0.9	0.7	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.1	62.9	71.4	80.9	86.4	91.8	98.6	97.5	92.9	82.7	69.1	59.2	(19)	(20)
		MCWB	44.0	45.4	49.7	55.6	59.6	61.5	64.2	63.4	59.6	57.1	50.9	46.1	(20)	(21)
	2%	DB	50.3	56.9	66.1	75.3	82.2	88.2	95.1	94.6	88.1	78.7	64.7	54.0	(21)	(22)
		MCWB	41.6	44.2	48.2	52.9	57.7	60.7	63.1	62.7	59.0	55.2	49.5	44.5	(22)	(23)
	5%	DB	47.3	53.3	62.0	71.4	78.7	85.7	91.6	91.5	84.8	74.9	61.2	50.3	(23)	(24)
		MCWB	40.2	42.6	46.8	51.8	56.9	60.2	62.6	62.2	58.6	54.7	47.7	42.7	(24)	(25)
	10%	DB	44.2	49.2	57.7	66.8	75.0	82.3	88.1	88.2	81.1	70.3	57.2	47.2	(25)	(26)
		MCWB	38.4	41.1	44.9	50.1	56.0	59.2	61.6	61.8	57.6	53.5	46.5	41.0	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.3	48.0	52.3	57.5	62.3	65.8	69.0	68.4	63.9	59.6	53.1	48.0	(27)	(28)
		MCDB	52.3	58.5	65.5	72.5	76.8	82.8	89.5	87.6	81.1	75.5	63.5	55.4	(28)	(29)
	2%	WB	42.8	45.3	49.5	54.9	59.8	63.5	66.4	66.1	61.8	57.4	51.0	45.6	(29)	(30)
		MCDB	48.9	54.6	62.4	70.8	76.7	80.9	86.3	84.7	80.7	72.2	61.5	52.4	(30)	(31)
	5%	WB	40.7	43.1	47.5	53.0	58.3	62.1	64.6	64.5	60.3	55.8	49.1	43.4	(31)	(32)
		MCDB	46.0	51.8	59.7	67.7	74.6	79.3	84.8	84.7	79.2	70.4	58.8	49.5	(32)	(33)
	10%	WB	38.5	41.1	45.7	51.2	56.8	60.7	63.2	63.1	58.9	54.4	47.3	41.4	(33)	(34)
		MCDB	43.4	48.7	56.6	64.4	72.0	77.2	83.0	83.4	78.0	68.2	55.9	46.4	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	17.8	19.9	22.5	25.1	26.3	28.7	31.6	31.8	31.9	27.9	25.2	18.3	(35)	(36)
		MCDBR	22.1	26.4	30.9	32.7	32.9	33.7	35.7	35.1	36.7	34.9	32.1	23.5	(36)	(37)
	5% WB	MCWBR	14.9	15.5	16.4	15.5	14.0	12.5	12.4	11.8	14.7	16.6	18.7	15.4	(37)	(38)
		MCWBR	20.4	24.0	26.7	28.6	29.7	29.3	32.3	31.3	32.2	29.6	27.6	21.2	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.303	0.334	0.377	0.417	0.395	0.360	0.354	0.359	0.335	0.352	0.317	0.299	(39)	(40)
		taud	2.360	2.279	2.192	2.112	2.245	2.367	2.383	2.338	2.405	2.343	2.409	2.418	(40)	(41)
	Ebn at Noon		275	280	278	273	281	290	291	287	289	270	268	269	(41)	(42)
		Edh at Noon	28	35	42	49	43	39	38	38	34	32	27	25	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		712	1041	1314	1663	1987	2328	2463	2245	1781	1215	833	607	(43)	(44)
	RadStd		86	140	121	151	121	151	111	71	108	75	83	69	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+0.65	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+88
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page