

MALATYA ERHAC, Turkey

WMO: 172000

Lat: 38.434N

Lon: 38.093E

Elev: 849

StdP: 91.53

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.6	-8.1	-14.2	1.2	-6.9	-12.2	1.5	-5.3	11.1	-1.3	10.0	0.3	2.1	210	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	38.1	19.0	36.9	18.4	35.5	18.0	22.1	34.1	20.5	32.5	19.2	31.9	3.5	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	14.1	31.8	15.9	12.5	28.8	14.2	11.2	25.5	69.4	34.3	63.3	32.4	58.4	31.8	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.5	7.3	DB	-14.5	40.2	3.4	1.4	-16.9	41.2	-18.9	42.0	-20.8	42.8	-23.3	43.8	(4)
(5)			WB	-14.9	21.6	3.3	2.7	-17.2	23.6	-19.1	25.2	-21.0	26.7	-23.4	28.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	0.9	2.5	7.3	12.6	17.5	23.2	27.4	27.3	21.8	14.8	7.3	2.3	(6)
(7)		DBStd	9.89	3.68	3.86	3.51	3.38	3.02	2.76	2.07	2.18	3.00	3.35	3.62	3.91	(7)
(8)		HDD10.0	941	282	211	97	13	0	0	0	0	0	4	93	240	(8)
(9)		HDD18.3	2507	540	444	342	175	52	1	0	0	7	116	332	498	(9)
(10)		CDD10.0	2326	0	0	13	90	233	397	539	536	354	153	11	0	(10)
(11)		CDD18.3	851	0	0	0	2	27	148	281	277	111	7	0	0	(11)
(12)		CDH23.3	12322	0	0	1	57	512	2053	4039	3982	1517	161	0	0	(12)
(13)		CDH26.7	6518	0	0	0	8	149	982	2362	2322	671	26	0	0	(13)
(14)	Wind	WSAvg	2.7	2.1	2.4	3.0	2.9	2.9	3.5	3.5	3.1	2.9	2.3	2.2	1.9	(14)
(15)	Precipitation	PrecAvg	407	42	37	55	60	52	23	2	6	37	49	43		(15)
(16)		PrecMax	597	139	71	131	141	158	67	12	24	27	130	146	93	(16)
(17)		PrecMin	247	4	9	9	3	5	0	0	0	0	0	0	4	(17)
(18)		PrecStd	102	29	16	31	36	36	19	3	4	8	32	29	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	16.0	21.2	27.6	32.8	36.9	40.0	39.8	36.1	29.1	19.9	12.8	(19)
(20)			MCWB	5.8	8.5	11.4	14.5	16.6	18.0	20.8	18.6	16.9	15.2	12.0	8.3	(20)
(21)		2%	DB	9.0	12.9	19.0	24.9	30.0	35.1	38.2	38.1	34.1	27.0	17.7	10.2	(21)
(22)			MCWB	5.6	7.0	10.5	13.2	15.9	17.7	19.2	18.9	16.4	15.0	10.7	7.1	(22)
(23)		5%	DB	7.8	11.0	17.0	22.8	28.1	33.2	37.1	37.0	32.2	25.1	15.9	9.0	(23)
(24)			MCWB	4.8	6.3	9.4	12.9	15.5	17.2	18.5	18.4	16.4	14.3	9.9	6.5	(24)
(25)		10%	DB	6.2	9.0	14.9	20.8	26.2	31.9	35.8	35.8	30.8	23.0	14.1	7.8	(25)
(26)			MCWB	4.0	5.3	8.5	11.9	15.0	16.9	18.2	18.1	16.0	13.5	9.1	5.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	9.1	12.7	16.0	18.7	22.0	24.5	24.3	20.7	17.4	13.1	9.2	(27)
(28)			MCD B	9.2	14.1	18.9	23.7	27.8	32.9	37.4	35.7	30.4	25.8	17.8	11.5	(28)
(29)		2%	WB	6.1	7.8	11.1	14.7	17.4	20.2	22.5	21.9	18.9	15.7	11.8	8.0	(29)
(30)			MCD B	8.0	11.9	17.1	22.2	27.1	30.9	35.0	34.1	29.2	23.9	15.5	9.6	(30)
(31)		5%	WB	5.2	6.7	9.9	13.6	16.4	18.7	20.7	20.2	17.6	14.9	10.7	6.9	(31)
(32)			MCD B	6.9	9.9	15.8	20.9	25.8	30.1	33.2	33.1	29.1	22.6	14.4	8.4	(32)
(33)		10%	WB	4.4	5.7	8.9	12.6	15.5	17.6	19.2	19.0	16.6	14.1	9.7	6.0	(33)
(34)			MCD B	5.9	8.3	14.2	19.4	24.4	29.5	32.8	32.7	28.6	21.6	13.2	7.3	(34)
(35)	Mean Daily Temperature Range			MDBR	8.2	10.5	11.9	13.4	15.1	16.1	16.4	16.5	14.2	11.8	8.0	(35)
(36)		5% DB	MCD BR	10.1	14.1	16.0	17.6	18.6	18.0	18.5	18.5	18.6	17.6	14.7	9.3	(36)
(37)			MCWBR	7.0	9.0	9.0	8.7	7.9	6.7	6.9	6.9	7.5	8.4	8.6	6.4	(37)
(38)		5% WB	MCD BR	7.7	11.7	13.9	15.1	16.7	16.2	16.3	16.3	16.7	14.6	11.3	7.1	(38)
(39)			MCWBR	5.7	7.8	8.3	8.2	8.0	7.5	8.5	7.9	8.0	7.4	7.0	5.2	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.335	0.371	0.415	0.466	0.436	0.379	0.368	0.385	0.354	0.396	0.350	0.330	(40)
(41)		taud		2.229	2.133	2.051	1.954	2.102	2.300	2.337	2.269	2.343	2.172	2.271	2.286	(41)
(42)		Ebn at Noon		821	836	835	815	849	898	904	880	891	799	799	800	(42)
(43)		Edh at Noon		102	128	154	180	159	130	124	130	113	122	97	90	(43)
(44)	All-Sky Solar Radiation	RadAvg		2.18	3.18	4.25	5.30	6.48	7.85	8.04	7.12	5.82	3.90	2.65	1.87	(44)
(45)		RadStd		0.29	0.51	0.41	0.51	0.39	0.36	0.23	0.24	0.25	0.30	0.31	0.38	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		N/A	N/A	N/A	N/A	-0.88	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page