

ESKISEHIR ANADOLU, Turkey

WMO: 172006

Lat: 39.810N

Lon: 30.519E

Elev: 789

StdP: 92.20

Time Zone: 3.00 (E03)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.8	-7.9	-12.0	1.5	-6.8	-10.2	1.7	-5.9	9.9	-2.5	8.7	0.7	2.3	270	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.1	33.1	17.9	31.9	17.8	30.1	17.4	20.2	28.2	19.5	27.6	18.9	26.8	3.7	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.9	14.2	22.7	17.0	13.3	22.3	16.1	12.6	21.9	61.4	28.4	59.0	27.7	56.8	26.6	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	8.4	7.4	6.7	DB	-13.3	36.6	3.5	1.3	-15.9	37.5	-17.9	38.3	-19.9	39.0	-22.4	40.0
(5)				WB	-13.7	21.9	3.4	0.8	-16.1	22.4	-18.1	22.9	-20.0	23.3	-22.4	23.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.6	0.0	3.0	6.6	11.0	15.0	19.2	22.0	22.3	18.3	12.3	7.0	2.1	(6)
(7)		DBStd	8.33	4.29	4.71	3.90	3.78	3.03	2.71	2.22	2.08	3.24	3.52	3.85	4.05	(7)
(8)		HDD10.0	1027	308	199	115	32	2	0	0	0	19	104	247		(8)
(9)		HDD18.3	2782	567	430	363	221	108	21	2	1	40	187	341	503	(9)
(10)		CDD10.0	1617	0	2	11	62	158	277	371	380	249	91	13	2	(10)
(11)		CDD18.3	331	0	0	0	1	6	48	114	123	39	1	0	0	(11)
(12)		CDH23.3	4293	0	0	1	55	177	657	1382	1336	643	42	0	0	(12)
(13)		CDH26.7	1577	0	0	0	5	31	219	556	524	235	6	0	0	(13)
(14)	Wind	WSAvg	3.1	3.4	3.2	3.4	3.2	3.0	3.1	3.5	3.5	3.0	2.6	2.6	3.1	(14)
(15)	Precipitation	PrecAvg	390	43	31	40	41	46	35	12	11	15	31	30	47	(15)
(16)		PrecMax	507	104	78	79	117	127	128	64	40	83	98	73	128	(16)
(17)		PrecMin	296	3	2	7	9	8	2	0	0	0	1	1	1	(17)
(18)		PrecStd	57	27	20	19	22	28	28	14	11	17	20	17	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.0	18.1	21.2	27.2	29.2	33.2	36.1	34.2	33.9	27.5	21.1	15.8	(19)
(20)		MCWB	8.1	10.4	10.5	14.1	16.2	18.3	18.2	18.0	17.3	14.8	12.1	10.3		(20)
(21)		2%	DB	10.1	15.1	18.8	25.0	27.2	31.2	33.2	32.9	31.8	24.1	18.9	12.0	(21)
(22)		MCWB	6.5	8.4	9.6	13.3	15.3	18.0	18.0	18.0	16.8	14.0	11.0	8.7		(22)
(23)		5%	DB	7.9	12.9	16.8	22.8	25.2	29.1	31.2	31.1	29.8	22.1	16.2	10.0	(23)
(24)		MCWB	5.6	7.7	8.9	12.5	14.7	17.2	17.9	18.0	16.3	13.5	10.2	7.3		(24)
(25)		10%	DB	6.0	10.8	14.8	20.0	23.2	27.1	29.9	29.9	27.1	19.9	14.0	8.1	(25)
(26)		MCWB	4.6	6.7	8.2	11.5	14.1	16.6	17.7	17.8	15.8	12.9	9.2	6.3		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	11.4	11.6	15.1	17.8	20.6	20.8	21.3	19.4	16.2	13.5	10.9	(27)
(28)		MCDWB	12.3	16.9	18.1	25.1	26.4	28.1	29.2	29.4	28.7	22.7	19.0	13.8		(28)
(29)		2%	WB	6.7	9.1	10.2	13.7	16.6	19.5	19.9	20.4	18.5	15.3	11.6	8.9	(29)
(30)		MCDWB	9.3	13.7	16.8	22.7	24.2	27.6	28.3	28.1	27.2	21.4	17.4	11.4		(30)
(31)		5%	WB	5.5	8.2	9.2	12.9	15.7	18.6	19.2	19.8	17.5	14.5	10.5	7.7	(31)
(32)		MCDWB	7.4	12.2	15.4	21.4	22.7	26.5	27.7	27.4	25.9	20.1	15.4	9.6		(32)
(33)		10%	WB	4.3	6.8	8.5	11.8	14.7	17.6	18.6	19.0	16.7	13.6	9.5	6.4	(33)
(34)		MCDWB	5.6	10.1	13.8	19.0	21.3	25.0	27.1	26.4	24.5	18.4	13.4	8.1		(34)
(35)	Mean Daily Temperature Range	MDBR	6.7	10.4	12.0	13.9	13.4	14.1	15.1	14.9	15.7	13.4	12.2	7.5	(35)	
(36)		5% DB	MCDBR	9.7	14.9	17.1	18.7	17.6	17.6	18.2	17.5	20.4	17.6	16.0	10.4	(36)
(37)		MCWBR	6.8	9.0	9.2	8.6	7.3	6.6	6.0	5.7	7.3	8.7	9.3	7.0	(37)	
(38)		5% WB	MCDBR	9.1	13.5	14.6	16.7	15.2	15.2	15.6	14.4	16.7	13.8	14.1	8.2	(38)
(39)		MCWBR	6.5	8.4	8.1	8.1	7.1	6.4	5.7	4.9	6.4	7.3	8.5	5.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.314	0.341	0.387	0.424	0.404	0.383	0.380	0.382	0.367	0.357	0.326	0.314	(40)	
(41)		taud	2.385	2.321	2.202	2.124	2.254	2.343	2.356	2.340	2.376	2.389	2.439	2.430	(41)	
(42)		Ebn at Noon	847	870	861	850	876	892	891	881	874	841	828	819	(42)	
(43)		Edh at Noon	85	104	131	151	136	124	122	120	109	97	80	76	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.82	2.69	3.84	4.98	6.00	6.93	7.35	6.46	5.01	3.42	2.36	1.63	(44)	
(45)		RadStd	0.20	0.35	0.33	0.49	0.49	0.61	0.29	0.31	0.37	0.26	0.28	0.22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (14 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page