

ELAZIG, Turkey

WMO: 172020

Lat: 38.606N

Lon: 39.297E

Elev: 2890

StdP: 13.22

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.1	18.0	2.7	7.0	21.4	6.6	8.6	24.5	20.2	40.7	17.9	38.8	4.3	250	0.482

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.1	100.8	65.3	98.7	64.6	96.4	64.0	67.8	96.0	66.5	94.2	65.3	92.5	7.4	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.5	78.6	73.0	55.7	73.5	73.9	54.0	69.0	73.9	33.8	95.8	32.7	94.0	31.7	92.5	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	15.1	12.8	8.6	104.7	6.3	2.3	4.1	106.4	0.4	107.7	-3.1	109.0	-7.7	110.7
			7.4	70.1	6.1	2.7	3.0	72.0	-0.6	73.6	-4.0	75.1	-8.4	77.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.6	33.3	35.9	44.7	54.0	63.0	72.8	80.7	80.7	71.1	59.6	45.9	36.5		
	DBStd	17.65	6.70	7.17	6.46	6.28	5.31	4.91	3.77	3.62	5.22	5.93	6.16	7.25		
	HDD50	1699	519	395	187	29	0	0	0	0	0	5	145	419		
	HDD65	4521	984	815	630	334	101	4	0	0	12	183	574	884		
	CDD50	4118	0	0	22	148	403	685	951	952	632	303	22	0		
	CDD65	1464	0	0	0	3	39	239	486	487	194	16	0	0		
	CDH74	21275	0	0	1	87	773	3516	7027	6856	2698	317	0	0		
	CDH80	11571	0	0	0	13	197	1715	4212	4126	1254	54	0	0		
(14) Wind	WSAvg	5.4	4.8	5.0	5.9	5.6	5.6	6.1	6.3	5.7	5.5	5.0	4.8	4.8		
(15) Precipitation	PrecAvg	18.0	1.9	2.2	2.1	2.7	2.0	0.4	0.2	0.0	0.4	2.0	2.1	2.0		
	PrecMax	24.6	4.3	4.3	5.0	4.5	5.5	1.1	0.6	0.2	1.3	5.4	3.8	4.6		
	PrecMin	10.8	0.2	0.9	0.1	0.9	0.4	0.0	0.0	0.0	0.0	0.2	0.1	0.0		
	PrecStd	3.3	0.9	0.9	1.4	1.0	1.3	0.4	0.2	0.0	0.4	1.3	1.1	1.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.5	59.2	69.4	81.4	89.6	98.5	104.3	104.1	97.0	84.9	67.2	55.0		
		MCWB	42.3	46.0	50.4	56.6	62.5	63.6	66.8	65.6	62.5	59.0	50.9	46.0		
	2%	DB	47.7	54.1	65.3	76.1	84.9	95.0	101.8	101.0	93.6	80.9	64.0	51.4		
		MCWB	40.6	43.5	48.7	54.8	59.4	63.6	65.4	65.4	62.3	57.5	49.3	44.4		
	5%	DB	45.4	50.3	62.0	72.1	82.0	91.8	99.0	98.9	90.8	77.4	60.7	49.0		
		MCWB	39.8	41.4	47.1	53.0	58.5	62.2	64.6	64.9	61.5	56.2	48.1	43.0		
	10%	DB	43.2	47.3	57.7	68.2	78.6	89.5	96.6	96.7	87.7	73.8	57.4	46.7		
		MCWB	38.3	40.1	45.2	51.7	57.6	61.2	64.2	64.3	60.2	55.0	46.9	41.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.6	48.3	52.7	59.2	65.1	67.8	70.1	69.8	65.9	61.2	53.7	48.5		
		MCDB	48.0	55.0	64.6	74.0	84.2	91.0	100.2	98.1	92.4	77.0	62.1	52.8		
	2%	WB	42.1	44.9	50.1	56.4	62.1	65.6	68.0	67.8	64.1	59.3	51.7	45.9		
		MCDB	45.9	51.7	61.6	71.3	77.9	90.0	96.7	96.9	89.8	74.8	59.4	49.9		
	5%	WB	40.5	42.7	48.2	54.8	60.4	63.9	66.5	66.5	62.5	57.9	49.9	44.1		
		MCDB	44.2	48.5	58.9	68.7	76.5	87.8	94.6	95.1	87.0	72.9	57.3	47.9		
	10%	WB	39.0	40.8	46.5	53.1	58.7	62.4	65.3	65.3	61.0	56.3	48.2	42.3		
		MCDB	42.6	46.1	55.7	65.9	74.5	85.4	92.9	93.6	85.0	70.6	55.9	45.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.2	17.5	21.1	23.6	26.9	30.7	31.1	31.6	31.1	25.4	20.7	13.7		
		MCDBR	16.2	23.6	28.0	30.6	32.9	33.8	34.7	34.7	35.1	31.2	26.2	16.5		
		MCWBR	10.6	14.7	14.7	14.5	13.5	12.9	13.8	14.3	15.6	14.4	14.5	10.5		
	5% WB	MCDBR	12.7	19.7	23.4	26.2	29.0	32.3	31.6	32.6	32.8	26.8	21.0	12.7		
		MCWBR	8.9	12.8	13.0	13.3	13.2	13.1	13.3	14.6	15.2	13.0	12.3	8.5		
(40) Clear-Sky Solar Irradiance	taub		0.331	0.365	0.403	0.452	0.419	0.366	0.362	0.372	0.341	0.386	0.343	0.329		
	taud		2.245	2.175	2.129	2.029	2.193	2.378	2.398	2.350	2.422	2.246	2.336	2.309		
	Ebn at Noon		262	268	269	262	274	288	289	283	287	257	257	254		
	Edh at Noon		32	39	45	53	46	38	37	38	33	36	29	28		
(44) All-Sky Solar Radiation	RadAvg		636	940	1313	1647	2063	2521	2554	2264	1849	1224	831	578		
	RadStd		100	147	121	175	135	114	68	69	74	93	97	122		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	+2.41	N/A	-1.31	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	-1.57	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page