

IZMIR CIGLI, Turkey

WMO: 172180

Lat: 38.513N

Lon: 27.014E

Elev: 5

StdP: 101.26

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.2	-0.1	-8.1	1.9	1.8	-6.8	2.1	3.1	11.3	12.2	10.3	11.9	2.1	0	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	36.9	21.4	35.2	21.3	34.1	21.0	23.7	32.8	22.9	32.0	22.2	31.3	6.0	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.9	15.6	28.3	19.9	14.6	27.7	19.0	13.8	27.0	70.8	33.0	67.6	31.9	64.9	31.5	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.9	8.9	8.0	-4.0	39.9	1.6	2.0	-5.2	41.3	-6.2	42.5	-7.1	43.7	-8.3	45.1
			-5.2	25.4	1.8	1.9	-6.5	26.8	-7.5	27.9	-8.5	29.0	-9.9	30.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	8.3	9.3	12.2	15.7	20.7	25.2	27.7	27.6	23.1	18.6	13.8	9.8
	DBStd	7.55	4.07	3.96	3.52	3.04	2.63	2.76	1.84	2.02	2.42	3.13	3.65	4.11
	HDD10.0	219	82	55	18	1	0	0	0	0	0	8	56	
	HDD18.3	1291	311	252	190	89	9	0	0	1	34	141	264	
	CDD10.0	3043	29	37	87	173	332	454	549	545	394	268	123	50
	CDD18.3	1073	0	1	1	11	83	205	291	287	144	44	6	1
	CDH23.3	12179	0	1	7	102	766	2403	3711	3507	1362	304	17	0
	CDH26.7	5798	0	0	1	16	211	1162	2014	1851	497	47	1	0
Wind	WSAvg	3.5	3.4	3.7	3.7	3.3	3.3	3.7	4.2	4.0	3.3	3.0	3.0	3.4
Precipitation	PrecAvg	644	103	95	70	54	35	14	5	5	19	47	83	112
	PrecMax	972	222	241	162	120	131	49	21	37	79	174	249	232
	PrecMin	395	6	10	17	10	3	1	1	0	0	2	0	2
	PrecStd	139	61	64	39	27	28	13	4	7	23	38	52	64
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.9	20.8	24.0	28.6	32.4	38.1	39.0	38.3	34.8	29.9	25.2	21.2
		MCWB	12.5	13.3	15.0	17.0	18.6	21.1	22.0	21.9	20.3	18.9	17.6	14.4
	2%	DB	17.1	18.2	21.2	26.1	30.8	35.9	36.9	36.2	32.2	28.0	23.0	19.0
		MCWB	12.3	12.4	13.5	16.0	18.4	20.8	21.6	21.8	19.8	18.4	16.4	13.9
	5%	DB	15.9	17.0	19.9	24.0	29.0	34.1	35.2	35.1	31.0	26.2	21.2	17.8
		MCWB	11.6	12.1	13.0	15.3	18.0	20.3	21.3	21.7	19.5	17.5	15.4	13.5
	10%	DB	14.2	15.4	18.2	22.1	27.3	32.4	34.1	33.9	29.8	25.0	19.9	16.0
		MCWB	10.7	11.2	12.3	14.3	17.5	19.8	21.0	21.4	19.3	17.0	14.8	12.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.1	14.1	15.6	18.6	20.9	23.2	24.9	24.9	22.7	20.8	18.7	15.5
		MCDB	17.5	18.5	21.7	25.9	29.2	32.8	34.2	33.7	30.1	26.8	23.3	19.1
	2%	WB	12.8	13.1	14.5	17.2	19.8	22.1	23.6	23.9	21.6	19.6	17.4	14.6
		MCDB	16.2	17.4	19.5	23.7	27.9	31.7	33.0	32.8	28.8	25.4	21.5	18.1
	5%	WB	11.8	12.3	13.6	16.1	19.0	21.3	22.8	23.1	20.8	18.7	16.2	13.7
		MCDB	15.1	16.4	18.4	22.4	26.9	30.9	32.3	32.1	28.1	24.4	20.3	17.1
	10%	WB	10.9	11.4	12.8	15.1	18.2	20.6	22.1	22.4	20.1	17.9	15.2	12.7
		MCDB	14.2	15.1	17.5	21.0	25.8	30.2	31.6	31.4	27.5	23.6	19.3	15.8
Mean Daily Temperature Range	5% DB	MDBR	7.9	8.5	9.5	11.2	12.2	12.9	13.1	12.8	12.5	11.3	9.7	7.8
		MCDBR	7.8	9.7	11.0	14.2	14.6	15.2	14.7	14.0	14.3	12.7	10.4	7.1
		MCWBR	5.1	5.9	6.2	7.1	6.2	5.3	5.4	5.1	5.8	6.0	6.0	4.7
	5% WB	MCDBR	7.1	8.7	9.7	12.5	13.0	13.4	13.2	12.7	12.7	11.3	9.2	6.7
		MCWBR	5.0	5.6	5.9	6.9	6.0	5.3	5.5	5.2	5.8	5.9	5.7	4.8
Clear-Sky Solar Irradiance	taub	0.361	0.394	0.431	0.470	0.445	0.410	0.407	0.413	0.405	0.401	0.378	0.366	
	taud	2.375	2.252	2.142	2.064	2.200	2.338	2.346	2.320	2.338	2.328	2.353	2.372	
	Ebn at Noon	801	817	822	812	841	869	868	856	840	800	772	764	
	Edh at Noon	90	115	141	162	144	125	123	124	115	105	91	85	
All-Sky Solar Radiation	RadAvg	2.05	2.80	4.23	5.55	6.81	7.70	7.96	7.05	5.56	3.89	2.59	1.89	
	RadStd	0.24	0.28	0.30	0.51	0.33	0.40	0.15	0.15	0.29	0.22	0.22	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	-93	N/A	N/A

Nomenclature: See separate page