

IZMIR ADNAN MENDERES, Turkey

WMO: 172190

Lat: 38.295N

Lon: 27.148E

Elev: 394

StdP: 14.49

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.8	30.3	17.4	13.5	35.2	20.2	15.4	36.5	29.9	43.7	27.3	43.7	5.1	0	0.565

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.5	99.0	69.5	96.7	69.2	94.6	68.8	73.3	91.4	72.0	90.0	70.7	88.5	16.2	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.9	104.1	80.3	66.1	97.6	79.9	64.5	92.1	79.2	37.1	91.2	35.9	90.1	34.8	88.6	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	25.7	23.4	21.8	DB	22.5	103.8	3.2	2.9	20.2	105.9	18.3	107.6	16.5	109.3	14.1	111.4
(5)				WB	21.2	74.9	3.1	2.0	19.0	76.4	17.2	77.5	15.4	78.6	13.2	80.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.0	45.3	47.3	51.5	58.3	67.6	76.9	82.8	82.7	74.2	64.9	55.1	47.8	(6)
(7)		DBStd	14.43	6.42	6.32	5.62	5.41	5.06	5.45	3.81	3.94	4.66	5.56	6.45	6.47	(7)
(8)		HDD50	485	171	112	50	7	0	0	0	0	0	25	120	(8)	
(9)		HDD65	2665	610	494	419	208	31	1	0	1	70	299	532	(9)	
(10)		CDD50	5222	26	38	96	256	546	808	1018	1015	725	462	179	53	(10)
(11)		CDD65	1927	0	0	0	7	112	359	553	550	276	67	3	0	(11)
(12)		CDH74	22914	0	1	8	156	1273	4270	7138	6908	2640	498	22	0	(12)
(13)		CDH80	11228	0	0	1	25	386	2074	3891	3694	1058	98	1	0	(13)
(14)	Wind	WSAvg	10.3	9.2	9.8	9.9	8.9	9.0	11.6	14.3	13.9	10.8	9.6	8.0	9.0	(14)
(15)	Precipitation	PrecAvg	25.6	4.3	3.7	2.8	2.0	1.2	0.5	0.1	0.1	0.8	1.9	3.6	4.6	(15)
(16)		PrecMax	40.2	9.2	10.3	7.2	4.2	4.7	2.0	0.6	1.1	4.3	8.2	11.4	10.1	(16)
(17)		PrecMin	14.0	0.0	0.0	0.4	0.6	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	6.3	2.6	3.0	1.8	1.1	1.1	0.6	0.1	0.2	1.1	1.8	2.4	2.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.0	68.0	73.9	83.4	91.3	101.1	104.1	102.1	96.4	87.1	77.0	66.8	(19)
(20)		0.4%	MCWB	55.3	55.0	58.2	62.1	64.8	69.7	70.1	69.3	67.5	64.4	61.9	57.8	(20)
(21)		2%	DB	61.1	64.3	69.0	78.7	87.4	96.7	99.1	98.7	92.1	82.6	72.1	63.0	(21)
(22)		2%	MCWB	54.1	54.3	55.6	60.5	64.6	68.6	69.6	69.7	66.8	63.9	60.2	56.0	(22)
(23)		5%	DB	58.8	61.1	66.0	74.5	84.4	93.4	96.7	96.5	89.3	79.1	69.3	60.8	(23)
(24)		5%	MCWB	52.2	53.1	54.4	59.2	63.9	67.6	69.1	69.6	66.3	62.6	59.0	54.8	(24)
(25)		10%	DB	55.7	58.2	62.9	70.8	81.0	90.7	94.6	94.0	86.1	76.5	66.1	58.1	(25)
(26)		10%	MCWB	50.2	51.4	53.0	57.5	62.7	66.9	68.8	69.3	65.4	61.7	57.6	53.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.3	57.6	59.4	64.6	68.3	72.6	74.5	75.5	71.7	68.1	63.9	59.1	(27)
(28)		0.4%	MCDWB	61.7	65.2	70.5	79.3	85.5	94.2	93.4	93.1	85.2	78.3	71.9	65.0	(28)
(29)		2%	WB	54.7	55.4	57.2	62.1	66.5	70.5	72.9	73.8	69.9	66.5	61.9	57.1	(29)
(30)		2%	MCDWB	60.1	62.0	66.2	75.0	82.7	90.4	92.3	91.1	83.7	76.6	69.6	62.0	(30)
(31)		5%	WB	52.8	53.7	55.6	60.2	65.2	69.3	71.5	72.6	68.5	65.0	60.3	55.4	(31)
(32)		5%	MCDWB	57.7	60.0	63.6	71.7	80.6	88.4	90.8	89.7	83.0	74.9	67.4	59.9	(32)
(33)		10%	WB	51.1	52.1	54.1	58.4	63.8	68.1	70.3	71.2	67.3	63.6	58.6	53.7	(33)
(34)		10%	MCDWB	55.1	57.6	61.6	68.9	78.2	86.6	89.2	88.3	81.8	73.2	65.1	57.8	(34)
(35)	Mean Daily Temperature Range		MDBR	15.6	16.7	19.1	21.3	23.5	23.5	22.5	22.0	22.6	20.4	18.8	15.4	(35)
(36)		5% DB	MCDBR	18.5	21.6	24.6	28.1	28.3	26.8	25.7	24.7	27.0	24.8	22.3	17.2	(36)
(37)			MCWBR	12.1	13.2	13.8	13.9	11.3	9.0	8.5	8.1	9.7	10.5	12.2	11.2	(37)
(38)			MCDBR	15.9	18.5	21.1	25.1	25.5	24.4	23.4	22.5	22.9	20.4	18.9	14.4	(38)
(39)		5% WB	MCWBR	10.9	11.8	12.5	13.4	11.0	8.8	8.5	7.8	9.3	9.8	10.9	9.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.352	0.384	0.420	0.456	0.434	0.400	0.396	0.402	0.394	0.391	0.368	0.357	(40)	
(41)		taud	2.399	2.282	2.175	2.102	2.229	2.361	2.370	2.342	2.365	2.356	2.382	2.400	(41)	
(42)		Ebn at Noon	259	263	265	262	270	279	279	275	271	258	250	247	(42)	
(43)		Edh at Noon	28	36	43	49	44	39	38	38	36	32	28	26	(43)	
(44)	All-Sky Solar Radiation	RadAvg	665	905	1357	1775	2168	2454	2529	2244	1775	1250	836	609	(44)	
(45)		RadStd	78	89	95	160	108	124	47	47	91	67	71	86	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-167	N/A	N/A

Nomenclature: See separate page