

IZMIR ADNAN MENDERES, Turkey

WMO: 172190

Lat: 38.295N

Lon: 27.148E

Elev: 120

StdP: 99.89

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.4	-0.9	-8.1	1.9	1.8	-6.6	2.2	2.5	13.3	6.5	12.2	6.5	2.3	0	0.565

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	37.2	20.8	35.9	20.6	34.8	20.5	22.9	33.0	22.2	32.2	21.5	31.4	7.2	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	14.9	26.8	18.9	13.9	26.6	18.0	13.2	26.2	68.4	32.9	65.6	32.3	63.2	31.5	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.5	10.5	9.7	-5.3	39.9	1.8	1.6	-6.6	41.1	-7.6	42.0	-8.6	42.9	-9.9	44.1
			-6.0	23.8	1.7	1.1	-7.2	24.6	-8.2	25.3	-9.2	25.9	-10.4	26.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	7.4	8.5	10.8	14.6	19.8	25.0	28.2	28.2	23.4	18.3	12.8	8.8
	DBStd	8.01	3.56	3.51	3.12	3.01	2.81	3.03	2.12	2.19	2.59	3.09	3.58	3.60
	HDD10.0	269	95	62	28	4	0	0	0	0	0	0	14	67
	HDD18.3	1481	339	274	233	116	17	1	0	0	1	39	166	296
	CDD10.0	2901	14	21	53	142	303	449	566	564	403	257	99	29
	CDD18.3	1071	0	0	0	4	62	199	307	306	153	37	2	0
	CDH23.3	12730	0	1	4	87	707	2372	3966	3838	1467	277	12	0
	CDH26.7	6238	0	0	1	14	214	1152	2162	2052	588	54	1	0
Wind	WSAvg	4.6	4.1	4.4	4.4	4.0	4.0	5.2	6.4	6.2	4.8	4.3	3.6	4.0
Precipitation	PrecAvg	650	109	95	70	51	30	13	3	3	20	49	92	116
	PrecMax	1021	233	262	183	106	120	52	14	29	108	208	290	256
	PrecMin	355	1	0	10	14	0	2	0	0	0	0	0	0
	PrecStd	161	66	75	46	28	28	14	3	6	29	46	61	70
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.8	20.0	23.3	28.6	32.9	38.4	40.0	38.9	35.8	30.6	25.0	19.3
		MCWB	12.9	12.8	14.6	16.7	18.2	21.0	21.2	20.7	19.7	18.0	16.6	14.3
	2%	DB	16.2	17.9	20.6	25.9	30.8	36.0	37.3	37.1	33.4	28.1	22.3	17.2
		MCWB	12.3	12.4	13.1	15.8	18.1	20.3	20.9	20.9	19.3	17.7	15.6	13.3
	5%	DB	14.9	16.2	18.9	23.6	29.1	34.1	35.9	35.8	31.8	26.2	20.7	16.0
		MCWB	11.2	11.7	12.4	15.1	17.7	19.8	20.6	20.9	19.0	17.0	15.0	12.7
	10%	DB	13.2	14.6	17.2	21.6	27.2	32.6	34.8	34.4	30.1	24.7	19.0	14.5
		MCWB	10.1	10.8	11.7	14.2	17.1	19.4	20.5	20.7	18.5	16.5	14.2	11.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.1	14.2	15.2	18.1	20.2	22.6	23.6	24.2	22.0	20.1	17.7	15.1
		MCDB	16.5	18.4	21.4	26.3	29.7	34.6	34.1	34.0	29.6	25.7	22.2	18.3
	2%	WB	12.6	13.0	14.0	16.7	19.2	21.4	22.7	23.2	21.1	19.2	16.6	14.0
		MCDB	15.6	16.7	19.0	23.9	28.2	32.5	33.5	32.8	28.7	24.8	20.9	16.7
	5%	WB	11.6	12.1	13.1	15.7	18.5	20.7	22.0	22.5	20.3	18.3	15.7	13.0
		MCDB	14.3	15.6	17.5	22.1	27.0	31.4	32.7	32.1	28.4	23.8	19.7	15.5
	10%	WB	10.6	11.2	12.3	14.7	17.7	20.1	21.3	21.8	19.6	17.5	14.8	12.0
		MCDB	12.8	14.2	16.4	20.5	25.7	30.3	31.8	31.3	27.7	22.9	18.4	14.3
Mean Daily Temperature Range	5% DB	MDBR	8.7	9.3	10.6	11.8	13.0	13.0	12.5	12.2	12.6	11.3	10.5	8.6
		MCDBR	10.3	12.0	13.7	15.6	15.7	14.9	14.3	13.7	15.0	13.8	12.4	9.6
		MCWBR	6.7	7.4	7.7	7.7	6.3	5.0	4.7	4.5	5.4	5.8	6.8	6.2
	5% WB	MCDBR	8.8	10.3	11.7	13.9	14.2	13.6	13.0	12.5	12.7	11.3	10.5	8.0
		MCWBR	6.1	6.5	6.9	7.4	6.1	4.9	4.7	4.3	5.2	5.5	6.1	5.5
Clear-Sky Solar Irradiance	taub	0.352	0.384	0.420	0.456	0.434	0.400	0.396	0.402	0.394	0.391	0.368	0.357	
	taud	2.399	2.282	2.175	2.102	2.229	2.361	2.370	2.342	2.365	2.356	2.382	2.400	
	Ebn at Noon	815	830	835	826	851	879	879	866	853	813	787	779	
	Edh at Noon	88	112	137	156	140	123	121	121	112	102	89	83	
All-Sky Solar Radiation	RadAvg	2.10	2.85	4.28	5.60	6.84	7.74	7.97	7.08	5.60	3.94	2.64	1.92	
	RadStd	0.25	0.28	0.30	0.50	0.34	0.39	0.15	0.15	0.29	0.21	0.22	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	-93	N/A	N/A

Nomenclature: See separate page