

IZMIR GUZELYALI, Turkey

WMO: 172200

Lat: 38.3945N

Lon: 27.0821E

Elev: 29

StdP: 100.98

Time Zone: 3.00 (E03)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.8	2.5	-7.7	2.0	2.3	-5.8	2.3	4.2	8.4	11.2	7.5	10.6	2.7	160	0.382

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.8	35.8	21.5	34.5	21.3	33.4	21.1	23.6	32.1	23.0	31.5	22.4	30.9	3.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.8	15.5	28.6	20.0	14.7	28.1	19.2	14.0	28.1	70.6	32.2	68.1	31.4	65.9	30.8	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.8	6.1	5.4	-0.9	38.5	2.4	1.1	-2.6	39.3	-4.0	40.0	-5.3	40.6	-7.0	41.4		
			-2.9	24.7	2.2	1.0	-4.5	25.4	-5.8	26.0	-7.0	26.6	-8.6	27.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.9	9.3	11.0	13.5	17.2	21.5	26.0	28.7	28.7	24.6	19.5	15.5	11.0
	DBStd	7.36	3.79	3.75	3.08	2.92	2.83	2.83	1.69	1.72	2.53	2.77	3.26	3.81
	HDD10.0	128	58	31	6	0	0	0	0	0	0	0	1	33
	HDD18.3	1040	278	207	151	55	6	0	0	0	0	20	95	229
	CDD10.0	3388	37	58	115	217	357	478	581	581	437	296	167	64
	CDD18.3	1258	0	1	1	22	104	228	322	323	187	58	10	2
	CDH23.3	13222	0	2	4	138	718	2371	4096	4096	1576	207	14	0
CDH26.7	5696	0	0	0	24	179	998	1998	1964	512	21	1	0	
Wind	WSAvg	2.6	2.7	2.7	2.7	2.5	2.5	2.6	2.9	2.9	2.5	2.3	2.3	2.5
Precipitation	PrecAvg	650	109	95	70	51	30	13	3	3	20	49	92	116
	PrecMax	1021	233	262	183	106	120	52	14	29	108	208	290	256
	PrecMin	355	1	0	10	14	0	2	0	0	0	0	0	0
	PrecStd	161	66	75	46	28	28	14	3	6	29	46	61	70
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.0	22.5	23.4	29.2	32.4	37.2	37.6	37.0	34.3	28.8	25.1	21.8
		MCWB	13.5	14.0	13.9	16.7	18.1	21.9	21.6	21.5	20.0	19.0	17.4	14.3
	2%	DB	17.4	19.1	21.2	27.0	30.2	35.0	35.7	35.5	32.4	26.9	23.1	19.7
		MCWB	12.4	13.1	13.1	16.0	18.2	21.3	21.2	21.8	20.2	18.2	16.3	14.2
	5%	DB	15.9	17.6	20.0	24.8	28.7	33.3	34.5	34.2	30.9	25.5	21.7	18.2
		MCWB	11.6	12.5	12.8	15.4	17.8	20.5	21.2	21.7	19.6	17.6	15.7	13.7
	10%	DB	14.5	16.4	18.7	22.9	27.1	31.7	33.4	33.1	29.6	24.3	20.5	16.5
		MCWB	11.0	11.9	12.5	14.9	17.4	20.0	21.0	21.6	19.4	17.2	15.2	12.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.8	14.9	15.1	18.2	20.4	23.7	24.5	24.6	22.7	20.5	18.5	15.6
		MCDB	18.4	20.1	20.8	26.1	28.3	33.8	32.0	33.6	29.6	25.4	23.1	19.6
	2%	WB	12.7	13.7	14.3	17.1	19.4	22.6	23.4	23.7	21.8	19.6	17.2	14.8
		MCDB	16.2	18.1	19.6	24.6	27.3	32.0	31.7	32.2	28.4	24.8	21.8	18.3
	5%	WB	11.9	12.9	13.6	16.1	18.7	21.7	22.7	23.1	21.1	18.9	16.4	14.0
		MCDB	15.0	17.0	18.6	23.3	26.5	30.4	31.4	31.6	27.8	23.9	20.7	17.6
	10%	WB	11.2	12.1	13.0	15.3	18.0	21.0	22.2	22.6	20.5	18.1	15.5	13.1
		MCDB	14.2	15.9	17.6	21.9	25.6	29.6	31.0	31.0	27.4	22.9	19.6	16.2
Mean Daily Temperature Range	5% DB	MDBR	5.8	6.6	7.8	9.0	9.4	9.1	9.2	8.8	8.8	8.2	7.2	5.9
		MCDBR	6.1	7.6	9.1	11.5	11.1	10.8	10.8	9.9	10.5	9.2	7.5	5.5
		MCWBR	3.5	4.1	4.5	5.1	4.5	4.3	4.7	4.1	4.6	4.3	3.9	3.5
	5% WB	MCDBR	5.6	7.1	8.2	10.6	10.0	9.4	9.2	8.5	8.8	8.4	6.7	5.3
		MCWBR	3.7	3.9	4.3	5.1	4.5	4.2	4.2	3.8	4.1	4.1	3.8	3.7
Clear-Sky Solar Irradiance	taub	0.359	0.392	0.429	0.467	0.443	0.408	0.405	0.410	0.402	0.399	0.376	0.364	
	taud	2.381	2.260	2.150	2.074	2.207	2.344	2.353	2.326	2.347	2.336	2.361	2.380	
	Ebn at Noon	805	820	825	816	843	872	871	858	844	804	776	768	
	Edh at Noon	89	114	140	160	143	125	123	123	114	104	90	84	
All-Sky Solar Radiation	RadAvg	2.08	2.83	4.25	5.58	6.82	7.72	7.97	7.06	5.58	3.92	2.62	1.91	
	RadStd	0.24	0.28	0.30	0.51	0.34	0.39	0.15	0.15	0.29	0.21	0.22	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	-93	N/A	N/A

Nomenclature: See separate page