

AYDIN, Turkey

WMO: 172340

Lat: 37.850N

Lon: 27.850E

Elev: 184

StdP: 14.60

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.4	33.7	17.2	13.2	40.6	20.8	15.7	41.4	12.2	51.3	10.4	48.8	2.8	90	0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.5	101.0	71.2	98.5	71.3	96.2	71.0	76.4	94.7	74.8	92.6	73.3	90.7	4.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.9	114.5	86.2	69.0	107.2	84.2	67.4	101.5	82.4	40.0	95.3	38.4	92.8	37.0	90.6	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.2	8.7	7.5	DB	27.9	105.6	2.1	2.8	26.4	107.7	25.1	109.3	23.9	110.9	22.4	112.9
			WB	26.0	78.8	2.3	2.4	24.3	80.5	23.0	81.9	21.7	83.2	20.0	84.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.6	48.0	49.8	54.7	61.7	71.4	79.7	84.3	83.8	76.6	68.3	58.1	50.2	(6)
	DBStd	14.10	6.03	6.02	5.95	5.97	5.59	5.01	3.46	3.52	4.49	5.83	6.38	6.01	(7)
	HDD50	292	109	71	24	3	0	0	0	0	0	0	14	71	(8)
	HDD65	2129	527	424	322	130	12	0	0	0	0	36	218	460	(9)
	CDD50	5999	46	66	170	354	664	892	1063	1048	797	566	256	77	(10)
	CDD65	2363	0	0	3	31	211	442	598	583	347	137	11	0	(11)
	CDH74	25606	0	0	22	267	1926	4986	7536	6848	3103	876	41	1	(12)
	CDH80	13307	0	0	3	53	764	2629	4353	3837	1421	244	3	0	(13)
(14) Wind	WSAvg	3.0	3.1	3.1	3.1	2.9	3.0	3.3	3.5	3.3	3.2	2.4	2.6	2.9	(14)
(15) Precipitation	PrecAvg	26.1	4.3	3.8	2.8	2.3	1.6	0.4	0.2	0.1	0.6	1.8	3.5	4.7	(15)
	PrecMax	39.1	10.6	7.8	5.3	4.7	5.0	1.9	1.2	0.5	3.0	4.7	12.3	9.9	(16)
	PrecMin	15.9	0.5	0.7	0.4	0.3	0.2	0.0	0.0	0.0	0.0	0.1	0.1	0.2	(17)
	PrecStd	5.6	2.6	2.2	1.4	1.1	1.2	0.5	0.2	0.2	0.8	1.3	2.4	2.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.8	68.2	76.5	85.7	95.4	103.3	105.1	103.5	98.1	90.1	78.7	68.8	(19)
		MCWB	54.7	54.7	58.0	63.1	66.2	69.9	72.8	71.3	69.1	65.4	61.6	56.7	(20)
	2%	DB	62.6	65.0	71.4	80.5	91.2	98.9	101.3	100.4	94.4	85.9	74.1	64.3	(21)
		MCWB	53.7	53.0	56.2	60.7	65.9	69.5	71.5	71.8	68.8	64.8	59.6	54.8	(22)
	5%	DB	59.6	62.3	68.5	76.7	87.8	95.8	98.7	97.6	91.3	82.5	71.0	61.7	(23)
		MCWB	51.8	52.0	54.9	58.8	65.3	69.3	71.7	72.2	68.4	63.9	58.3	53.5	(24)
	10%	DB	57.1	59.6	65.6	73.1	84.3	92.7	96.3	95.2	88.2	79.0	67.8	59.1	(25)
		MCWB	50.5	50.9	53.5	57.8	64.0	68.5	71.5	71.8	67.2	62.6	57.5	52.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.3	57.2	60.7	65.5	70.1	75.3	78.8	79.0	73.8	69.3	64.5	58.5	(27)
		MCDB	62.1	63.9	72.2	81.5	89.5	94.7	97.6	96.9	91.5	80.5	73.2	66.3	(28)
	2%	WB	54.7	54.7	58.3	62.3	68.1	72.9	76.4	76.9	71.9	67.8	62.1	56.4	(29)
		MCDB	60.2	62.3	68.1	76.4	86.9	92.3	95.5	94.6	87.7	78.7	69.7	62.4	(30)
	5%	WB	53.0	53.0	56.5	60.5	66.6	71.3	74.7	75.2	70.4	66.2	60.3	54.7	(31)
		MCDB	58.0	60.2	65.5	72.9	83.6	90.2	93.5	92.1	85.5	77.0	67.8	59.7	(32)
	10%	WB	51.4	51.7	54.8	59.0	65.1	69.8	73.3	73.6	69.0	64.8	58.7	53.3	(33)
		MCDB	56.1	57.9	63.3	70.4	80.4	87.9	91.6	89.8	83.0	74.6	65.4	57.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.1	15.5	18.4	19.9	23.2	24.8	25.5	24.3	24.2	21.1	17.7	13.9	(35)
		MCDBR	15.8	18.6	22.3	25.0	27.5	28.0	27.9	26.5	27.3	24.8	21.0	15.6	(36)
	5% WB	MCWBR	9.0	9.7	10.8	10.4	9.7	9.3	9.8	9.6	9.6	9.0	9.7	8.6	(37)
		MCWBR	13.5	15.9	19.6	22.3	24.8	25.3	25.0	23.6	24.1	20.6	17.0	12.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.350	0.384	0.424	0.462	0.443	0.405	0.400	0.409	0.394	0.392	0.367	0.354	(40)
		taud	2.390	2.268	2.144	2.076	2.190	2.335	2.347	2.311	2.352	2.341	2.379	2.404	(41)
	Ebn at Noon		260	264	264	261	268	278	278	273	271	259	252	250	(42)
		Edh at Noon	28	36	45	51	46	40	39	40	36	33	28	26	(43)
(44) All-Sky Solar Radiation	RadAvg		695	941	1382	1790	2166	2465	2540	2254	1807	1285	872	639	(44)
	RadStd		83	100	96	158	115	125	49	52	93	66	75	88	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (17 neighbors)		+0.58	N/A	N/A	N/A	N/A	N/A	N/A	-131	+153	N/A	

Nomenclature: See separate page