

ISPARTA, Turkey

WMO: 172400

Lat: 37.7852N

Lon: 30.5668E

Elev: 3271

StdP: 13.04

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 18.1	(c) 21.6	(d) 7.9	(e) 9.3	(f) 21.9	(g) 11.6	(h) 11.2	(i) 25.3	(j) 18.5	(k) 43.6	(l) 16.2	(m) 44.5	(n) 3.1	(o) 270	(p) 0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.3	92.7	65.2	90.2	64.7	87.8	64.1	70.0	87.1	68.0	84.6	66.2	82.8	5.5	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.7	99.9	80.6	61.8	93.1	78.5	59.8	86.6	76.2	36.1	87.2	34.3	84.5	32.7	82.8	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.1	(b) 12.0	(c) 10.4	(e) 12.3	(f) 96.6	(g) 4.5	(h) 2.7	(i) 9.0	(j) 98.6	(k) 6.4	(l) 100.1	(m) 3.8	(n) 101.6	(o) 0.5	(p) 103.6		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			10.9	71.8	4.4	2.3	7.7	73.5	5.1	74.9	2.6	76.2	-0.6	77.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.9	36.1	38.9	44.2	51.6	60.1	68.1	74.6	74.5	66.5	56.9	46.6	39.1
	DBStd	14.60	6.66	6.67	6.22	6.16	5.42	5.03	3.85	3.94	5.03	5.63	6.28	6.53
	HDD50	1475	431	313	194	50	2	0	0	0	0	13	132	340
	HDD65	4516	896	731	644	401	166	25	0	1	42	255	552	803
	CDD50	3252	0	2	15	99	316	544	763	760	494	227	30	2
	CDD65	818	0	0	0	1	16	119	298	295	86	3	0	0
	CDH74	9633	0	0	0	28	308	1380	3400	3285	1137	94	1	0
	CDH80	3755	0	0	0	1	48	434	1482	1415	368	7	0	0
(14) Wind	WSAvg	3.7	3.7	4.3	4.8	4.4	3.7	3.7	3.7	3.4	3.2	3.0	3.0	3.4
(15) Precipitation	PrecAvg	21.3	2.9	2.6	2.2	2.1	2.1	1.2	0.6	0.5	0.7	1.5	1.9	3.3
	PrecMax	38.1	10.2	7.1	6.7	6.1	5.9	4.4	3.4	2.7	3.9	5.6	8.0	14.2
	PrecMin	11.1	0.1	0.2	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	6.0	2.1	1.7	1.3	1.2	1.3	0.9	0.8	0.6	0.7	1.3	1.4	2.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	60.1	67.5	77.6	84.6	91.4	96.4	95.9	91.8	80.9	69.2	58.4
		MCWB	44.6	47.2	51.1	56.0	61.2	64.9	66.9	65.6	61.1	58.9	52.4	45.5
	2%	DB	50.7	55.8	63.0	72.8	80.8	88.1	93.1	92.8	87.4	76.5	64.8	54.2
		MCWB	43.6	44.8	48.1	54.0	59.4	63.4	65.9	65.5	61.8	57.5	51.3	45.6
	5%	DB	48.3	52.1	59.8	68.4	77.4	85.0	90.5	90.1	84.3	73.2	61.5	51.4
		MCWB	42.2	43.2	46.8	52.4	58.5	62.8	65.3	65.1	60.7	56.3	49.4	44.9
	10%	DB	45.9	49.2	56.2	64.6	73.9	81.8	87.9	87.6	80.8	69.7	58.2	49.2
		MCWB	40.9	42.2	45.5	50.6	57.1	61.8	64.3	64.7	60.1	54.8	48.3	43.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	48.6	53.1	57.5	63.7	68.2	73.2	72.2	67.4	61.9	54.8	49.2
		MCDB	51.1	57.6	64.8	73.2	81.2	86.2	91.6	89.0	82.2	76.0	64.7	54.4
	2%	WB	44.5	46.0	49.7	55.1	61.1	66.0	70.2	70.2	64.7	59.3	52.7	47.4
		MCDB	48.9	53.2	59.8	69.7	77.0	83.5	88.0	86.7	80.3	71.6	61.3	52.1
	5%	WB	42.9	44.4	47.8	53.3	59.6	64.3	68.2	68.2	62.8	57.6	51.0	45.8
		MCDB	47.5	50.2	57.2	66.4	74.5	81.1	85.3	84.3	78.8	69.3	58.9	50.4
	10%	WB	41.4	43.0	46.2	51.5	58.0	62.9	66.2	66.4	61.3	56.1	49.5	44.3
		MCDB	45.5	48.6	55.0	62.7	71.7	78.7	83.0	82.8	77.3	67.2	56.6	48.7
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	15.8	17.9	19.6	22.4	24.1	25.3	25.6	26.0	22.7	20.2	14.8
		MCDBR	17.2	22.0	25.7	27.9	29.0	28.4	29.5	29.3	32.0	29.1	27.1	19.0
		MCWBR	11.4	13.0	14.1	13.2	12.5	11.6	11.4	11.1	12.8	13.5	15.0	12.0
	5% WB	MCDBR	14.1	17.7	21.9	24.5	26.4	25.9	27.1	26.3	27.6	24.7	21.6	14.6
		MCWBR	9.9	11.0	12.7	12.2	12.5	12.1	13.1	12.2	12.8	12.3	12.3	9.7
(40) Clear-Sky Solar Irradiance	taub		0.313	0.345	0.396	0.432	0.415	0.381	0.378	0.386	0.361	0.358	0.327	0.313
	taud		2.399	2.303	2.154	2.085	2.197	2.333	2.340	2.296	2.373	2.356	2.413	2.441
	Ebn at Noon		275	278	273	269	275	284	284	279	281	270	267	267
	Edh at Noon		28	35	44	50	46	40	39	40	35	32	27	25
(44) All-Sky Solar Radiation	RadAvg		685	953	1362	1721	2022	2344	2426	2154	1760	1254	882	635
	RadStd		91	116	101	141	146	149	75	61	104	77	78	93

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.65	N/A	N/A	+1.35	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page