

KONYA, Turkey

WMO: 172440

Lat: 37.984N

Lon: 32.574E

Elev: 1031

StdP: 89.54

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.1	-8.5	-13.4	1.3	-9.0	-11.6	1.6	-6.5	13.0	0.4	11.6	-0.3	1.7	340	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	34.2	16.5	32.9	16.4	31.2	16.1	18.5	29.6	17.5	28.9	16.9	28.3	4.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.7	11.8	22.3	13.3	10.8	21.3	12.6	10.3	20.9	56.5	29.3	53.4	29.0	51.2	28.4	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.7	9.3	8.3	-15.0	36.6	3.6	1.5	-17.6	37.7	-19.7	38.6	-21.7	39.4	-24.3	40.5		
			-15.4	19.6	3.4	1.2	-17.8	20.5	-19.9	21.2	-21.8	21.9	-24.3	22.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.4	0.5	2.3	6.5	11.1	16.2	20.7	24.3	24.2	19.6	13.5	7.0	2.1	(6)
(7)		DBStd	9.15	4.71	4.74	4.15	3.91	3.31	3.02	2.55	2.69	3.26	3.72	4.15	4.35	(7)
(8)		HDD10.0	1027	295	215	122	31	1	0	0	0	13	103	247		(8)
(9)		HDD18.3	2701	553	448	367	217	83	12	0	1	24	152	341	504	(9)
(10)		CDD10.0	1898	0	1	13	65	192	321	443	441	287	123	13	1	(10)
(11)		CDD18.3	531	0	0	0	1	16	82	185	183	61	3	0	0	(11)
(12)		CDH23.3	5878	0	0	4	37	242	873	2037	1928	687	70	0	0	(12)
(13)		CDH26.7	2318	0	0	0	5	47	292	912	836	218	9	0	0	(13)
(14)	Wind	WSAvg	3.6	3.0	3.4	3.8	3.6	3.5	4.2	4.7	4.5	3.6	3.2	2.7	2.7	(14)
(15)	Precipitation	PrecAvg	328	36	27	27	36	39	24	7	5	16	31	33	47	(15)
(16)		PrecMax	501	96	61	92	84	78	79	29	19	88	83	109	119	(16)
(17)		PrecMin	192	0	5	6	8	13	1	0	0	0	1	0	0	(17)
(18)		PrecStd	70	21	13	18	20	19	21	8	6	20	23	26	34	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.7	17.2	22.5	27.0	30.1	33.2	36.4	36.0	33.0	27.9	20.5	15.0	(19)
(20)			MCWB	7.1	8.2	9.8	12.6	14.5	15.7	17.0	16.9	15.3	14.0	11.0	8.6	(20)
(21)		2%	DB	10.9	14.1	19.1	24.0	27.9	31.3	34.9	34.1	31.0	25.2	18.2	12.0	(21)
(22)			MCWB	6.1	7.2	8.7	11.4	14.0	15.7	16.7	16.6	15.1	12.7	10.2	7.5	(22)
(23)		5%	DB	8.8	11.9	16.8	21.8	26.1	29.9	33.1	32.9	29.2	23.2	16.1	10.0	(23)
(24)			MCWB	5.4	6.3	8.2	10.9	13.5	15.3	16.5	16.6	14.5	12.5	9.2	6.5	(24)
(25)		10%	DB	6.8	9.8	14.2	19.1	24.1	28.2	31.3	31.1	27.2	21.1	14.0	8.0	(25)
(26)			MCWB	4.5	5.4	7.3	10.0	13.0	14.8	16.3	16.4	14.1	11.8	8.5	5.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	9.1	10.8	13.6	15.8	17.9	20.8	20.2	17.5	15.2	12.4	9.3	(27)
(28)			MCDWB	11.8	15.2	20.1	22.7	25.9	28.4	31.5	30.2	26.4	23.0	18.1	13.0	(28)
(29)		2%	WB	6.6	7.8	9.5	12.3	14.9	16.8	18.6	18.6	16.2	14.0	11.0	8.0	(29)
(30)			MCDWB	9.9	13.3	17.2	21.4	25.2	27.2	29.9	29.8	26.7	21.8	16.5	11.2	(30)
(31)		5%	WB	5.5	6.6	8.6	11.4	14.2	16.2	17.5	17.7	15.5	13.2	9.9	6.8	(31)
(32)			MCDWB	8.2	11.0	15.5	19.8	23.7	26.5	29.4	29.1	26.1	20.7	14.9	9.5	(32)
(33)		10%	WB	4.4	5.5	7.6	10.5	13.6	15.6	16.8	17.0	14.8	12.5	8.8	5.8	(33)
(34)			MCDWB	6.4	9.2	13.8	18.2	22.5	25.7	28.8	28.5	25.2	19.6	13.1	7.7	(34)
(35)	Mean Daily Temperature Range	MDBR	7.9	9.6	11.4	12.2	12.7	12.8	13.0	12.7	13.2	11.9	11.1	7.9	(35)	
(36)		5% DB	MCDBR	11.2	13.5	16.1	16.2	15.9	14.8	15.2	14.4	15.8	15.6	14.7	11.0	(36)
(37)			MCWBR	7.2	7.7	8.0	7.2	6.3	5.3	5.6	5.4	6.4	7.0	8.0	7.2	(37)
(38)		5% WB	MCDBR	10.2	12.4	14.4	14.2	14.2	13.1	13.3	12.5	13.7	13.0	12.6	9.7	(38)
(39)		MCWBR	6.9	7.3	7.5	6.9	6.0	5.1	5.1	5.0	5.8	6.2	7.2	6.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.298	0.324	0.361	0.399	0.383	0.361	0.360	0.362	0.338	0.339	0.310	0.297	(40)	
(41)		taud	2.412	2.345	2.248	2.165	2.268	2.348	2.345	2.310	2.388	2.387	2.437	2.455	(41)	
(42)		Ebn at Noon	885	902	896	879	897	915	913	904	911	873	863	862	(42)	
(43)		Edh at Noon	85	104	127	146	135	124	124	125	109	98	83	77	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.16	3.17	4.35	5.48	6.44	7.39	7.67	6.87	5.54	3.90	2.71	1.93	(44)	
(45)		RadStd	0.27	0.36	0.25	0.45	0.41	0.44	0.24	0.16	0.31	0.24	0.28	0.24	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page