

NIGDE, Turkey

WMO: 172500

Lat: 37.9585N

Lon: 34.6796E

Elev: 3970

StdP: 12.71

Time Zone: 3.00 (E03)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.3	14.1	3.5	7.6	16.3	7.8	9.5	19.3	21.7	46.6	19.3	47.9	5.3	40	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.8	91.3	63.0	88.9	62.2	86.4	61.4	66.2	86.5	64.7	85.0	63.3	82.5	5.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.4	84.5	75.8	56.6	79.0	75.2	55.0	74.6	74.0	33.1	86.4	31.9	85.6	30.8	82.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	14.0	11.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.5	32.7	35.9	44.6	52.6	60.1	67.3	73.4	72.9	65.3	55.7	45.3	34.8
	DBStd	15.73	8.94	9.44	8.03	6.92	5.64	4.80	3.91	3.66	5.40	6.80	7.20	9.43
	HDD50	1857	537	396	201	50	3	0	0	0	0	27	169	474
	HDD65	4901	1001	814	634	374	169	30	0	1	62	290	591	935
	CDD50	3126	0	2	33	128	316	518	726	709	458	205	28	3
	CDD65	699	0	0	0	3	18	99	262	244	70	3	0	0
	CDH74	7877	0	0	2	57	282	1114	2925	2517	892	88	0	0
	CDH80	2670	0	0	0	5	37	293	1196	909	224	6	0	0
	WSAvg	5.5	5.3	5.7	6.6	6.4	5.4	5.5	6.0	5.8	4.8	4.8	4.7	5.1
	PrecAvg	13.2	1.2	1.2	1.3	1.7	2.0	0.9	0.2	0.1	0.3	0.9	1.2	1.6
(15) Precipitation	PrecMax	17.3	2.5	2.7	3.6	3.9	4.4	2.8	0.9	0.5	0.9	2.9	2.8	3.5
	PrecMin	8.0	0.2	0.3	0.3	0.3	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.1
	PrecStd	2.6	0.6	0.7	0.8	0.9	1.1	0.7	0.2	0.2	0.3	0.8	0.8	0.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.6	62.0	71.3	79.4	84.4	90.6	95.5	93.6	89.8	80.4	68.6	64.2
		MCWB	41.6	43.7	49.9	55.6	58.3	59.3	63.3	65.5	62.4	56.4	49.4	47.2
	2%	DB	51.7	57.6	66.4	74.8	80.7	87.2	92.4	90.3	85.6	76.5	64.6	56.7
		MCWB	41.4	43.4	46.6	51.8	57.2	59.4	63.1	64.1	62.6	55.7	49.3	44.6
	5%	DB	48.6	53.8	62.5	70.8	77.4	84.0	89.9	88.1	82.2	73.0	61.8	51.9
		MCWB	39.9	41.4	45.3	50.6	56.1	59.6	62.0	63.2	60.7	55.0	47.6	42.6
	10%	DB	45.5	50.1	59.1	66.9	74.1	80.8	87.2	85.4	79.3	69.6	58.5	48.0
		MCWB	38.2	40.2	44.3	49.0	54.7	58.6	61.4	62.0	59.0	53.6	46.2	40.6
	0.4%	WB	44.4	46.7	50.7	57.2	60.8	63.8	68.2	68.9	66.7	59.4	53.3	48.2
		MCDB	53.8	57.7	66.8	77.2	79.5	84.2	92.0	86.5	84.6	74.3	64.0	61.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	42.2	43.4	48.1	53.8	58.8	62.0	65.7	66.6	64.3	57.6	51.0	45.3
		MCDB	49.7	54.6	61.9	70.0	77.1	81.5	87.8	86.4	83.9	72.1	62.1	54.4
	5%	WB	40.4	42.0	46.5	52.0	57.2	60.6	64.3	65.1	61.8	56.1	48.9	43.3
		MCDB	47.6	52.5	60.3	67.8	73.7	79.4	85.7	84.8	78.9	70.3	58.4	50.9
	10%	WB	38.6	40.4	45.0	50.2	55.7	59.3	62.7	63.8	60.2	54.5	47.1	41.2
		MCDB	45.1	49.7	57.9	64.0	71.2	77.4	82.7	82.7	76.7	68.0	55.9	47.5
(35) Mean Daily Temperature Range	5% DB	MDBR	15.6	16.5	18.3	20.3	21.8	23.4	24.8	24.1	24.2	22.4	19.4	15.7
		MCDBR	19.4	22.7	25.0	27.3	27.0	27.1	28.6	26.9	28.6	27.5	25.2	21.7
		MCWBR	11.2	11.7	11.8	11.9	10.9	9.6	10.7	10.9	13.5	13.1	13.2	12.4
		MCDBR	18.0	20.8	21.8	24.2	24.2	24.3	26.1	24.5	25.6	24.4	21.4	19.7
	5% WB	MCWBR	11.2	11.3	10.8	11.4	10.6	9.8	11.6	10.8	12.4	12.4	11.8	11.7
(40) Clear-Sky Solar Irradiance	taub		0.293	0.321	0.362	0.404	0.387	0.356	0.351	0.354	0.331	0.342	0.309	0.291
	taud		2.387	2.312	2.230	2.143	2.257	2.369	2.379	2.341	2.414	2.373	2.431	2.443
	Ebn at Noon		282	287	284	277	284	292	292	289	291	276	274	276
	Edh at Noon		28	34	41	47	43	39	38	38	34	32	26	24
(44) All-Sky Solar Radiation	RadAvg		700	994	1341	1674	1986	2335	2451	2207	1779	1248	867	639
	RadStd		88	122	97	146	119	148	105	67	101	76	81	82

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page