

NIGDE, Turkey

WMO: 172500

Lat: 37.9585N

Lon: 34.6796E

Elev: 1210

StdP: 87.61

Time Zone: 3.00 (E03)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.6	-9.9	-15.9	1.1	-8.7	-13.4	1.4	-7.1	9.7	8.1	8.6	8.9	2.4	40	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	33.0	17.2	31.6	16.8	30.2	16.4	19.0	30.3	18.1	29.4	17.4	28.1	2.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.7	12.1	24.3	13.6	11.3	24.0	12.8	10.7	23.3	59.2	30.2	56.3	29.8	53.7	27.9	21.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.3	5.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.9	0.4	2.2	7.0	11.4	15.6	19.6	23.0	22.7	18.5	13.2	7.4	1.6		
	DBStd	8.74	4.97	5.24	4.46	3.84	3.13	2.67	2.17	2.03	3.00	3.78	4.00	5.24		
	HDD10.0	1032	298	220	112	28	2	0	0	0	15	94	263			
	HDD18.3	2723	556	452	352	208	94	17	0	1	34	161	328	519		
	CDD10.0	1737	0	1	18	71	176	288	403	394	254	114	16	2		
	CDD18.3	388	0	0	0	2	10	55	146	136	39	2	0	0		
	CDH23.3	4376	0	0	1	32	157	619	1625	1398	496	49	0	0		
	CDH26.7	1483	0	0	0	3	21	163	664	505	124	3	0	0		
(14) Wind	WSAvg	2.5	2.4	2.6	2.9	2.9	2.4	2.5	2.7	2.6	2.1	2.1	2.1	2.3		
(15) Precipitation	PrecAvg	336	31	31	33	43	52	24	5	3	8	24	30	40		
	PrecMax	440	64	69	91	99	112	71	22	12	22	73	71	89		
	PrecMin	203	4	7	7	7	10	1	0	0	0	1	2			
	PrecStd	67	16	18	21	23	29	17	6	4	7	20	20	19		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.6	16.7	21.8	26.4	29.1	32.5	35.3	34.2	32.1	26.9	20.3	17.9		
		MCWB	5.3	6.5	9.9	13.1	14.6	15.1	17.4	18.6	16.9	13.6	9.6	8.5		
	2%	DB	10.9	14.2	19.1	23.8	27.0	30.7	33.6	32.4	29.8	24.7	18.1	13.7		
		MCWB	5.2	6.3	8.1	11.0	14.0	15.2	17.3	17.8	17.0	13.2	9.6	7.0		
	5%	DB	9.2	12.1	17.0	21.5	25.2	28.9	32.1	31.2	27.9	22.8	16.6	11.0		
		MCWB	4.4	5.2	7.4	10.3	13.4	15.3	16.7	17.4	15.9	12.8	8.7	5.9		
	10%	DB	7.5	10.0	15.0	19.4	23.4	27.1	30.7	29.7	26.3	20.9	14.7	8.9		
		MCWB	3.4	4.5	6.9	9.4	12.6	14.8	16.3	16.7	15.0	12.0	7.9	4.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	8.1	10.4	14.0	16.0	17.6	20.1	20.5	19.3	15.2	11.8	9.0		
		MCDB	12.1	14.3	19.3	25.1	26.4	29.0	33.3	30.3	29.2	23.5	17.8	16.4		
	2%	WB	5.7	6.3	8.9	12.1	14.9	16.6	18.7	19.2	17.9	14.2	10.6	7.4		
		MCDB	9.8	12.5	16.6	21.1	25.1	27.5	31.0	30.2	28.8	22.3	16.7	12.4		
	5%	WB	4.6	5.6	8.1	11.1	14.0	15.9	17.9	18.4	16.6	13.4	9.4	6.3		
		MCDB	8.6	11.4	15.7	19.9	23.1	26.3	29.9	29.3	26.1	21.3	14.7	10.5		
	10%	WB	3.7	4.7	7.2	10.1	13.1	15.2	17.1	17.7	15.7	12.5	8.4	5.1		
		MCDB	7.3	9.8	14.4	17.8	21.8	25.2	28.2	28.2	24.8	20.0	13.3	8.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.7	9.2	10.2	11.3	12.1	13.0	13.8	13.4	13.4	12.5	10.8	8.7		
		MCDBR	10.8	12.6	13.9	15.2	15.0	15.1	15.9	15.0	15.9	15.3	14.0	12.1		
	5% WB	MCWBR	6.2	6.5	6.5	6.6	6.0	5.3	5.9	6.1	7.5	7.3	7.3	6.9		
		MCWBR	10.0	11.6	12.1	13.4	13.4	13.5	14.5	13.6	14.2	13.5	11.9	11.0		
(40) Clear-Sky Solar Irradiance	taub		0.293	0.321	0.362	0.404	0.387	0.356	0.351	0.354	0.331	0.342	0.309	0.291		
	taud		2.387	2.312	2.230	2.143	2.257	2.369	2.379	2.341	2.414	2.373	2.431	2.443		
	Ebn at Noon		890	904	894	874	894	920	921	912	918	869	865	869		
	Edh at Noon		87	107	129	149	136	122	119	121	106	100	83	77		
(44) All-Sky Solar Radiation	RadAvg		2.21	3.13	4.23	5.28	6.26	7.36	7.73	6.96	5.61	3.94	2.73	2.02		
	RadStd		0.28	0.39	0.30	0.46	0.38	0.47	0.33	0.21	0.32	0.24	0.26	0.26		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page