

DIYARBAKIR, Turkey

WMO: 172800

Lat: 37.8967N

Lon: 40.2023E

Elev: 2211

StdP: 13.56

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.2	22.6	6.6	8.4	30.6	10.8	10.3	30.8	23.3	42.1	20.6	41.5	3.9	290	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.6	105.2	66.0	102.6	65.8	100.7	65.5	73.0	96.4	70.4	94.1	68.2	92.9	9.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.4	98.4	89.6	61.4	88.3	85.0	59.1	81.0	79.8	38.2	96.8	35.8	94.0	33.8	92.5	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.0	17.3	15.0	12.1	108.5	8.8	2.4	5.8	110.2	0.7	111.6	-4.3	112.9	-10.6	114.7		
(5)			10.8	72.0	8.2	4.9	4.9	75.5	0.1	78.4	-4.5	81.1	-10.4	84.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.1	37.1	40.5	48.2	56.5	66.3	78.6	86.9	86.1	76.6	64.6	50.1	40.1	(6)
(7)		DBStd	18.30	6.47	6.47	5.71	5.93	5.73	5.13	3.68	3.44	5.09	6.05	6.15	7.32	(7)
(8)		HDD50	1164	400	269	101	11	0	0	0	0	0	1	72	310	(8)
(9)		HDD65	3695	865	686	521	261	56	0	0	2	83	448	773	(9)	
(10)		CDD50	5206	0	2	45	206	507	857	1144	1119	797	453	74	2	(10)
(11)		CDD65	2263	0	0	0	7	97	407	679	654	349	70	0	0	(11)
(12)		CDH74	33801	0	0	3	153	1424	5881	10754	10132	4571	882	1	0	(12)
(13)		CDH80	20200	0	0	0	33	490	3376	7042	6566	2442	251	0	0	(13)
(14)	Wind	WSAvg	6.1	5.0	5.5	6.3	5.9	6.1	8.1	8.1	7.0	6.4	5.3	4.4	4.6	(14)
(15)	Precipitation	PrecAvg	19.0	2.7	2.6	2.6	2.7	1.7	0.3	0.1	0.0	0.1	1.4	2.0	2.9	(15)
(16)		PrecMax	29.5	7.4	6.0	8.3	8.2	7.2	1.6	1.9	1.1	5.8	4.8	7.5	(16)	
(17)		PrecMin	9.3	0.0	0.2	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	4.8	1.5	1.3	1.6	1.8	1.7	0.4	0.3	0.3	0.2	1.4	1.1	1.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.4	63.0	71.9	83.9	92.1	102.5	108.7	107.5	100.9	89.5	72.3	60.8	(19)
(20)			MCWB	46.0	49.1	53.7	58.0	65.7	65.0	67.1	65.7	63.4	61.2	53.0	47.8	(20)
(21)		2%	DB	52.0	58.9	67.9	77.7	88.3	99.4	105.8	104.5	97.9	86.0	68.6	55.7	(21)
(22)			MCWB	44.1	47.4	52.4	58.4	63.3	64.3	66.3	65.9	63.6	60.2	52.6	46.7	(22)
(23)		5%	DB	49.6	55.3	64.3	74.4	85.6	97.0	103.8	102.6	95.0	82.6	66.0	52.8	(23)
(24)			MCWB	43.0	45.9	51.1	57.6	62.2	64.6	65.9	65.9	63.3	58.8	51.8	45.9	(24)
(25)		10%	DB	46.7	51.8	60.8	70.6	82.3	94.8	101.8	100.7	91.8	79.1	62.5	50.1	(25)
(26)			MCWB	41.6	44.1	49.5	55.8	61.6	63.5	65.8	65.6	62.0	57.9	50.6	44.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.6	51.8	57.3	64.6	72.0	74.6	77.0	75.2	73.2	66.4	58.1	51.7	(27)
(28)			MCDWB	52.5	59.9	66.0	75.8	86.9	95.6	98.8	98.7	94.8	82.9	66.1	56.8	(28)
(29)		2%	WB	46.2	49.1	54.3	61.2	67.9	70.6	73.0	71.9	68.7	63.1	55.6	49.4	(29)
(30)			MCDWB	49.4	56.0	63.5	72.9	82.3	91.3	98.0	97.3	89.4	78.7	63.7	53.4	(30)
(31)		5%	WB	44.2	47.3	52.4	59.0	64.9	67.7	70.1	69.2	65.5	60.9	53.7	47.7	(31)
(32)			MCDWB	47.6	53.3	61.8	70.5	79.9	89.7	96.2	96.3	87.6	76.3	61.0	51.3	(32)
(33)		10%	WB	42.7	45.2	50.6	57.1	62.7	65.2	67.7	67.3	63.4	59.3	51.9	45.9	(33)
(34)			MCDWB	45.6	50.3	59.2	68.0	77.6	88.7	95.3	95.9	87.6	73.9	60.2	48.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.7	18.3	20.9	23.3	27.0	29.5	28.6	29.5	29.0	25.0	21.8	16.2	(35)
(36)			MCDBR	20.1	24.5	27.3	29.3	31.8	31.4	31.2	31.6	32.2	30.1	26.8	21.0	(36)
(37)			MCWBR	13.6	15.1	15.1	15.0	13.5	11.7	12.0	12.1	14.0	14.3	15.1	13.7	(37)
(38)		5% WB	MCDBR	15.0	20.2	23.1	25.3	28.5	29.2	28.6	30.0	29.7	25.5	21.2	15.5	(38)
(39)			MCWBR	11.2	13.3	14.1	14.7	15.2	14.7	14.4	14.4	15.9	13.6	13.5	10.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.346	0.377	0.408	0.463	0.431	0.380	0.376	0.380	0.355	0.401	0.352	0.344	(40)	
(41)		taud	2.276	2.193	2.136	2.001	2.150	2.314	2.330	2.304	2.374	2.204	2.326	2.295	(41)	
(42)		Ebn at Noon	259	265	269	260	271	285	285	281	283	253	255	250	(42)	
(43)		Edh at Noon	31	39	45	55	48	41	40	40	35	38	30	29	(43)	
(44)	All-Sky Solar Radiation	RadAvg	677	952	1349	1699	2122	2541	2504	2229	1829	1243	872	625	(44)	
(45)		RadStd	102	143	102	171	144	111	66	67	69	85	90	110	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) -3.01	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) +92	(46)
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	-1.51	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page