

DIYARBAKIR, Turkey

WMO: 172800

Lat: 37.8967N

Lon: 40.2023E

Elev: 674

StdP: 93.49

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.2	-5.2	-14.1	1.2	-0.8	-11.8	1.5	-0.7	10.4	5.6	9.2	5.3	1.8	290	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.9	40.7	18.9	39.2	18.8	38.2	18.6	22.8	35.8	21.4	34.5	20.1	33.8	4.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	14.1	32.0	16.3	12.6	29.5	15.0	11.6	26.5	71.0	36.0	65.3	34.4	60.7	33.6	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
8.9	7.7	6.7	DB	-11.0	42.5	4.9	1.3	-14.6	43.4	-17.4	44.2	-20.1	45.0	-23.7	45.9	
			WB	-11.8	22.2	4.5	2.7	-15.0	24.2	-17.7	25.8	-20.3	27.3	-23.6	29.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	2.8	4.7	9.0	13.6	19.1	25.9	30.5	30.1	24.8	18.1	10.0	4.5	(6)
(7)		DBStd	10.17	3.59	3.59	3.17	3.29	3.18	2.85	2.05	1.91	2.83	3.36	3.41	4.07	(7)
(8)		HDD10.0	647	222	149	56	6	0	0	0	0	1	40	172	(8)	
(9)		HDD18.3	2053	481	381	289	145	31	0	0	1	46	249	429	(9)	
(10)		CDD10.0	2892	0	1	25	114	282	476	636	622	443	252	41	1	(10)
(11)		CDD18.3	1257	0	0	0	4	54	226	377	363	194	39	0	0	(11)
(12)		CDH23.3	18778	0	0	2	85	791	3267	5974	5629	2539	490	1	0	(12)
(13)		CDH26.7	11222	0	0	0	18	272	1876	3912	3648	1357	139	0	0	(13)
(14)	Wind	WSAvg	2.7	2.2	2.5	2.8	2.6	2.7	3.6	3.6	3.1	2.9	2.4	2.0	2.0	(14)
(15)	Precipitation	PrecAvg	482	68	67	65	68	43	8	2	1	3	35	52	73	(15)
(16)		PrecMax	749	189	152	210	209	182	40	48	48	27	148	123	191	(16)
(17)		PrecMin	236	1	4	1	2	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	121	39	33	40	45	42	10	7	7	5	35	28	47	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.0	17.2	22.2	28.8	33.4	39.1	42.6	42.0	38.3	31.9	22.4	16.0	(19)
(20)		MCWB	7.8	9.5	12.1	14.4	18.7	18.3	19.5	18.7	17.5	16.2	11.7	8.8	(20)	
(21)		2%	DB	11.1	14.9	20.0	25.4	31.3	37.4	41.0	40.3	36.6	30.0	20.3	13.2	(21)
(22)		MCWB	6.7	8.6	11.3	14.7	17.4	18.0	19.1	18.8	17.5	15.7	11.5	8.2	(22)	
(23)		5%	DB	9.8	12.9	18.0	23.6	29.8	36.1	39.9	39.2	35.0	28.1	18.9	11.6	(23)
(24)		MCWB	6.1	7.7	10.6	14.2	16.8	18.1	18.9	18.8	17.4	14.9	11.0	7.7	(24)	
(25)		10%	DB	8.2	11.0	16.0	21.4	27.9	34.9	38.8	38.2	33.2	26.1	16.9	10.0	(25)
(26)		MCWB	5.4	6.7	9.7	13.2	16.4	17.5	18.8	18.7	16.7	14.4	10.3	7.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	11.0	14.1	18.1	22.2	23.7	25.0	24.0	22.9	19.1	14.5	10.9	(27)
(28)		MADB	11.4	15.5	18.9	24.3	30.5	35.3	37.1	37.1	34.9	28.3	18.9	13.8	(28)	
(29)		2%	WB	7.9	9.5	12.4	16.2	19.9	21.4	22.8	22.2	20.4	17.3	13.1	9.6	(29)
(30)		MADB	9.7	13.3	17.5	22.7	27.9	32.9	36.7	36.3	31.9	25.9	17.6	11.9	(30)	
(31)		5%	WB	6.8	8.5	11.3	15.0	18.3	19.8	21.2	20.7	18.6	16.0	12.1	8.7	(31)
(32)		MADB	8.7	11.8	16.5	21.4	26.6	32.1	35.7	35.7	30.9	24.6	16.1	10.7	(32)	
(33)		10%	WB	5.9	7.3	10.3	14.0	17.1	18.5	19.8	19.6	17.4	15.2	11.0	7.7	(33)
(34)		MADB	7.6	10.2	15.1	20.0	25.3	31.5	35.1	35.5	30.9	23.3	15.7	9.4	(34)	
(35)	Mean Daily Temperature Range	MDBR	8.7	10.2	11.6	13.0	15.0	16.4	15.9	16.4	16.1	13.9	12.1	9.0	(35)	
(36)		5% DB	MADB	11.2	13.6	15.2	16.3	17.7	17.5	17.4	17.5	17.9	16.7	14.9	11.7	(36)
(37)		MCWBR	7.5	8.4	8.4	8.3	7.5	6.5	6.7	6.7	7.8	8.0	8.4	7.6	(37)	
(38)		5% WB	MADB	8.3	11.2	12.8	14.0	15.8	16.2	15.9	16.7	16.5	14.2	11.8	8.6	(38)
(39)		MCWBR	6.2	7.4	7.8	8.2	8.4	8.1	8.0	8.0	8.8	7.5	7.5	6.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.346	0.377	0.408	0.463	0.431	0.380	0.376	0.380	0.355	0.401	0.352	0.344	(40)	
(41)		taud	2.276	2.193	2.136	2.001	2.150	2.314	2.330	2.304	2.374	2.204	2.326	2.295	(41)	
(42)		Ebn at Noon	817	836	847	819	854	897	898	887	893	798	805	789	(42)	
(43)		Edh at Noon	99	122	142	173	151	129	126	126	111	119	93	91	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.13	3.00	4.25	5.36	6.69	8.01	7.89	7.03	5.77	3.92	2.75	1.97	(44)	
(45)		RadStd	0.32	0.45	0.32	0.54	0.45	0.35	0.21	0.21	0.22	0.27	0.28	0.35	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	-1.67	N/A	N/A	N/A	N/A	+51	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	-0.84	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page