

BODRUM, TurkeyWMO: **172900**Lat: **37.033N**Lon: **27.440E**Elev: **85**StdP: **14.65**Time Zone: **3.00 (E03)**Period: **94-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.8	40.4	20.0	15.1	44.4	22.9	17.3	45.0	22.6	57.9	19.9	57.5	8.6	340	0.348

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.9	99.2	71.6	96.5	71.6	94.0	71.4	77.3	87.4	76.1	86.8	74.9	86.1	8.4	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.9	131.1	81.7	73.1	123.3	81.3	71.5	116.8	81.1	40.9	87.4	39.6	86.8	38.5	85.9	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.4	16.0	13.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.2	53.9	54.5	57.7	62.8	71.3	80.1	84.9	85.3	78.4	70.7	62.2	55.5
	DBStd	12.46	5.61	5.70	5.06	5.20	4.55	4.99	3.56	3.75	4.12	4.86	5.34	6.29
	HDD50	91	30	25	6	1	0	0	0	0	0	0	3	26
	HDD65	1390	345	295	231	98	4	0	0	0	0	13	108	296
	CDD50	6732	151	149	245	385	661	904	1082	1095	853	640	369	198
	CDD65	2557	0	0	5	32	200	454	617	630	403	188	25	3
	CDH74	24769	0	0	10	107	1028	4473	7494	7587	3265	780	25	0
	CDH80	11059	0	0	1	12	246	1949	3777	3796	1146	132	0	0
Wind	WSAvg	5.5	6.0	6.3	6.1	5.3	4.8	5.7	5.8	5.3	5.1	4.7	5.0	5.9
Precipitation	PrecAvg	26.1	4.7	4.1	2.7	1.7	0.9	0.1	0.0	0.0	0.4	1.7	3.8	5.9
	PrecMax	41.0	12.2	9.0	6.2	4.2	2.4	0.6	0.2	0.6	2.1	5.9	9.9	12.3
	PrecMin	14.0	0.2	1.0	0.1	0.2	0.0	0.0	0.0	0.0	0.1	0.7	0.1	0.1
	PrecStd	6.9	2.6	2.5	1.7	1.0	0.7	0.1	0.0	0.1	0.6	1.5	2.2	3.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.0	69.3	74.5	81.8	90.6	101.8	102.8	103.3	95.6	87.2	76.9	70.4
		MCWB	57.9	58.3	59.2	62.2	67.5	70.7	72.7	70.7	69.7	67.8	64.7	60.8
	2%	DB	64.9	66.1	70.4	77.1	85.6	96.2	99.0	99.2	91.4	83.4	74.1	67.4
		MCWB	56.8	56.9	57.2	60.0	66.3	69.9	71.6	72.1	69.5	66.2	62.6	59.2
	5%	DB	63.3	64.2	67.6	74.0	82.6	92.9	96.3	96.4	89.0	80.8	71.9	65.8
		MCWB	56.3	56.2	56.1	59.5	65.8	69.6	71.8	72.3	69.2	66.1	62.0	58.3
	10%	DB	61.9	62.3	65.3	71.2	79.7	89.5	93.6	93.8	86.4	78.5	70.0	64.1
		MCWB	55.6	55.4	55.6	58.6	64.8	68.9	71.4	72.3	69.5	65.7	61.1	57.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.2	59.7	62.1	66.4	71.3	76.2	79.5	78.9	76.8	73.2	67.2	62.7
		MCDB	64.9	66.2	69.6	74.9	82.3	88.0	89.1	87.4	84.3	80.4	72.9	67.9
	2%	WB	58.6	58.3	60.0	63.7	69.7	74.2	77.4	77.4	74.9	70.6	65.0	61.3
		MCDB	63.0	64.1	66.8	71.9	80.0	85.9	87.6	87.5	83.3	77.3	71.3	66.2
	5%	WB	57.5	57.4	58.6	62.0	68.2	72.7	76.0	76.3	73.4	69.0	63.6	59.7
		MCDB	62.2	62.6	65.2	69.9	77.9	84.5	87.0	87.2	82.6	76.6	70.0	64.5
	10%	WB	56.3	56.3	57.2	60.5	66.9	71.4	74.6	75.1	72.2	67.7	62.2	58.0
		MCDB	61.1	61.5	63.7	68.3	76.3	83.4	86.4	86.5	81.4	75.6	68.5	62.9
Mean Daily Temperature Range	5% DB	MDBR	11.0	11.1	12.4	13.4	14.6	16.3	17.3	16.9	15.2	13.8	12.2	10.8
		MCDBR	11.6	11.8	14.9	17.2	18.5	20.6	20.7	20.1	18.2	16.2	13.6	10.7
		MCWBR	7.5	6.5	7.7	8.3	7.3	6.8	6.7	6.6	7.1	7.0	7.2	6.3
	5% WB	MCDBR	9.6	10.0	12.6	14.3	15.8	17.5	16.7	17.1	15.3	12.9	11.7	8.5
		MCWBR	7.2	6.3	7.6	8.3	8.0	7.5	7.4	7.1	8.0	7.3	7.2	6.1
Clear-Sky Solar Irradiance	taub		0.354	0.384	0.419	0.451	0.436	0.400	0.397	0.408	0.393	0.393	0.372	0.358
	taud		2.427	2.325	2.215	2.158	2.258	2.400	2.406	2.370	2.415	2.391	2.414	2.438
	Ebn at Noon		262	266	267	265	270	279	279	274	272	260	252	252
	Edh at Noon		28	35	42	47	43	37	37	38	34	32	28	26
All-Sky Solar Radiation	RadAvg		726	991	1458	1888	2259	2544	2558	2284	1854	1328	902	665
	RadStd		77	83	85	141	101	84	35	33	70	63	65	80