

MILAS BODRUM, Turkey

WMO: 172910

Lat: 37.251N

Lon: 27.664E

Elev: 21

StdP: 14.68

Time Zone: 3.00 (E03)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 31.8	(c) 34.1	(d) 15.8	(e) 12.3	(f) 40.9	(g) 19.6	(h) 14.8	(i) 42.3	(j) 26.4	(k) 60.1	(l) 22.9	(m) 59.0	(n) 5.1	(o) 120	(p) 0.446

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.1	100.4	69.6	98.2	69.5	95.1	69.6	75.4	89.0	74.2	88.1	73.1	87.3	12.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.5	116.4	82.1	69.9	110.1	81.4	68.3	104.0	80.2	38.8	90.1	37.7	87.9	36.8	87.3	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 21.5	(b) 19.0	(c) 17.2	(e) 27.1	(f) 105.7	(g) 2.5	(h) 2.7	(i) 25.3	(j) 107.7	(k) 23.9	(l) 109.3	(m) 22.5	(n) 110.8	(o) 20.7	(p) 112.7		
(a) 21.5	(b) 19.0	(c) 17.2	(e) 25.4	(f) 76.9	(g) 2.8	(h) 1.4	(i) 23.4	(j) 78.0	(k) 21.8	(l) 78.8	(m) 20.3	(n) 79.6	(o) 18.2	(p) 80.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.6	49.3	50.9	54.7	60.4	68.4	76.8	81.7	81.4	74.3	66.6	58.4	51.8
	DBStd	12.43	5.77	5.63	5.05	4.32	4.26	4.89	3.51	3.31	3.75	4.56	5.53	5.90
	HDD50	206	83	52	15	0	0	0	0	0	0	0	6	50
	HDD65	2022	486	395	322	150	15	0	0	0	0	37	207	410
	CDD50	5545	62	77	160	311	569	805	981	974	730	513	258	105
	CDD65	1889	0	0	2	11	120	355	516	509	280	86	9	1
	CDH74	23564	0	1	21	193	1364	4414	6993	6618	3093	813	54	0
	CDH80	11954	0	0	3	29	404	2197	4060	3789	1312	157	3	0
Wind	WSAvg	6.8	6.5	7.0	7.0	7.0	7.0	8.0	7.6	7.2	7.0	6.0	5.3	5.8
Precipitation	PrecAvg	27.2	4.8	4.1	2.9	2.0	1.3	0.3	0.2	0.1	0.6	1.8	3.8	5.4
	PrecMax	40.6	11.7	7.9	5.8	4.6	3.8	1.0	1.1	0.4	3.4	4.1	11.9	12.3
	PrecMin	16.1	0.3	1.0	0.4	0.3	0.2	0.0	0.0	0.0	0.0	0.0	0.3	0.3
	PrecStd	5.9	2.7	2.4	1.6	1.0	0.9	0.3	0.2	0.1	0.8	1.2	2.3	3.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.4	69.8	76.8	83.9	91.6	101.9	104.2	102.6	96.8	87.5	78.9	70.1
		MCWB	56.6	56.3	56.6	62.3	64.9	68.9	69.2	69.5	67.6	64.5	62.7	60.0
	2%	DB	64.2	66.3	71.6	79.0	87.7	98.3	100.5	100.1	93.1	84.1	75.2	66.8
		MCWB	55.9	55.4	56.4	60.3	64.4	68.8	69.5	70.0	67.4	64.2	62.3	58.1
	5%	DB	62.2	64.2	68.3	75.4	84.3	94.7	98.3	97.0	89.8	81.0	72.0	64.7
		MCWB	54.8	54.9	56.0	58.9	63.9	68.0	69.3	70.2	67.4	64.4	60.7	56.9
	10%	DB	60.1	62.2	66.1	72.0	81.0	91.1	95.2	94.7	87.5	78.8	69.8	62.6
		MCWB	53.6	54.4	55.5	58.3	63.5	68.3	69.7	70.5	67.7	63.8	60.2	55.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.7	59.2	60.7	65.5	69.2	74.3	76.3	77.3	74.3	70.2	66.2	61.3
		MCDB	64.3	66.0	69.3	78.0	82.6	91.1	90.7	90.8	86.2	79.0	74.2	68.1
	2%	WB	56.7	57.2	59.0	62.9	67.4	72.6	74.9	75.8	72.4	68.6	64.0	59.6
		MCDB	62.3	63.9	67.1	73.5	80.4	89.0	89.1	89.3	84.6	77.8	71.8	65.5
	5%	WB	55.3	55.7	57.6	61.2	66.3	71.4	73.7	74.8	71.1	67.3	62.6	58.0
		MCDB	60.9	62.6	66.0	71.7	79.1	86.7	88.4	88.2	83.4	76.6	69.9	63.5
	10%	WB	53.9	54.3	56.3	59.8	65.0	69.9	72.7	73.7	69.8	65.8	61.0	56.5
		MCDB	59.1	60.9	64.3	69.7	77.6	84.6	87.6	87.1	82.0	75.2	68.0	61.6
Mean Daily Temperature Range	5% DB	MDBR	16.8	17.7	20.4	22.3	24.3	25.5	27.1	26.7	25.8	23.5	21.1	17.5
		MCDBR	18.1	20.8	24.1	27.9	29.1	30.4	31.2	29.8	29.6	26.8	23.5	19.1
		MCWBR	11.5	12.4	13.1	12.9	11.4	9.5	9.1	9.5	11.7	12.1	12.8	12.1
	5% WB	MCDBR	16.1	18.4	21.2	24.5	25.1	26.7	26.7	25.8	25.1	22.4	19.5	15.9
MCWBR		10.9	11.6	12.6	13.1	11.4	10.2	10.1	10.1	11.2	11.8	11.3	10.8	
Clear-Sky Solar Irradiance	taub	0.352	0.383	0.418	0.451	0.436	0.400	0.397	0.407	0.391	0.391	0.369	0.355	
	taud	2.419	2.314	2.200	2.141	2.243	2.382	2.388	2.350	2.399	2.381	2.411	2.434	
	Ebn at Noon	262	266	267	264	270	279	279	274	273	260	253	252	
	Edh at Noon	28	35	43	48	44	38	38	38	35	32	28	26	
All-Sky Solar Radiation	RadAvg	722	984	1442	1866	2240	2534	2565	2286	1852	1324	898	662	
	RadStd	81	90	89	148	106	97	39	37	77	64	69	84	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-112	N/A	N/A

Nomenclature: See separate page