

MILAS BODRUM, Turkey

WMO: 172910

Lat: 37.251N

Lon: 27.664E

Elev: 6

StdP: 101.25

Time Zone: 3.00 (E03)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.1	1.2	-9.0	1.8	5.0	-6.9	2.1	5.7	11.8	15.6	10.2	15.0	2.3	120	0.446

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.0	38.0	20.9	36.8	20.8	35.1	20.9	24.1	31.7	23.4	31.2	22.8	30.7	5.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	16.6	27.8	21.1	15.7	27.5	20.2	14.9	26.8	72.3	32.3	69.8	31.0	67.6	30.7	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.6	8.5	7.7	-2.7	41.0	1.4	1.5	-3.7	42.0	-4.5	42.9	-5.3	43.8	-6.3	44.9		
			-3.7	25.0	1.5	0.8	-4.8	25.5	-5.7	26.0	-6.5	26.5	-7.6	27.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.1	9.6	10.5	12.6	15.8	20.2	24.9	27.6	27.5	23.5	19.2	14.7	11.0
	DBStd	6.91	3.21	3.13	2.80	2.40	2.37	2.71	1.95	1.84	2.08	2.54	3.07	3.28
	HDD10.0	114	46	29	8	0	0	0	0	0	0	3	28	
	HDD18.3	1123	270	219	179	83	8	0	0	0	21	115	228	
	CDD10.0	3081	34	43	89	173	316	447	545	541	406	285	143	58
	CDD18.3	1049	0	0	1	6	67	197	287	283	156	48	5	1
	CDH23.3	13091	0	1	12	107	758	2452	3885	3677	1718	452	30	0
	CDH26.7	6641	0	0	2	16	224	1221	2256	2105	729	87	2	0
Wind	WSAvg	3.0	2.9	3.1	3.1	3.1	3.1	3.6	3.4	3.2	3.1	2.7	2.3	2.6
Precipitation	PrecAvg	692	121	103	73	52	34	8	4	2	16	46	96	138
	PrecMax	1031	297	200	148	116	97	25	27	10	87	105	301	312
	PrecMin	410	7	26	10	8	5	0	0	0	1	8	7	
	PrecStd	149	68	61	40	25	23	7	5	3	21	31	59	75
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.1	21.0	24.9	28.8	33.1	38.8	40.1	39.2	36.0	30.9	26.1	21.2
		MCWB	13.7	13.5	13.7	16.8	18.3	20.5	20.7	20.8	19.8	18.0	17.0	15.6
	2%	DB	17.9	19.0	22.0	26.1	31.0	36.8	38.1	37.8	33.9	28.9	24.0	19.3
		MCWB	13.3	13.0	13.5	15.7	18.0	20.5	20.9	21.1	19.7	17.9	16.8	14.5
	5%	DB	16.8	17.9	20.2	24.1	29.1	34.8	36.8	36.1	32.1	27.2	22.2	18.1
		MCWB	12.7	12.7	13.3	14.9	17.7	20.0	20.7	21.2	19.7	18.0	15.9	13.8
	10%	DB	15.6	16.8	19.0	22.2	27.2	32.9	35.1	34.8	30.8	26.0	21.0	17.0
		MCWB	12.0	12.5	13.1	14.6	17.5	20.1	21.0	21.4	19.8	17.7	15.7	13.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.8	15.1	15.9	18.6	20.7	23.5	24.6	25.1	23.5	21.2	19.0	16.3
		MCDB	18.0	18.9	20.7	25.6	28.1	32.8	32.6	32.6	30.1	26.1	23.4	20.0
	2%	WB	13.7	14.0	15.0	17.2	19.7	22.6	23.8	24.3	22.4	20.4	17.8	15.3
		MCDB	16.8	17.7	19.5	23.1	26.9	31.7	31.7	31.8	29.2	25.4	22.1	18.6
	5%	WB	13.0	13.2	14.2	16.2	19.0	21.9	23.2	23.8	21.7	19.6	17.0	14.4
		MCDB	16.1	17.0	18.9	22.0	26.2	30.4	31.3	31.2	28.5	24.8	21.1	17.5
	10%	WB	12.2	12.4	13.5	15.5	18.3	21.1	22.6	23.2	21.0	18.8	16.1	13.6
		MCDB	15.1	16.1	18.0	20.9	25.3	29.2	30.9	30.6	27.8	24.0	20.0	16.5
Mean Daily Temperature Range	5% DB	MDBR	9.3	9.9	11.4	12.4	13.5	14.2	15.0	14.8	14.4	13.1	11.7	9.7
		MCDBR	10.0	11.6	13.4	15.5	16.1	16.9	17.3	16.5	16.5	14.9	13.0	10.6
		MCWBR	6.4	6.9	7.3	7.2	6.4	5.3	5.1	5.3	6.5	6.7	7.1	6.7
	5% WB	MCDBR	8.9	10.2	11.8	13.6	14.0	14.9	14.8	14.4	13.9	12.4	10.8	8.9
		MCWBR	6.1	6.4	7.0	7.3	6.4	5.7	5.6	5.6	6.2	6.5	6.3	6.0
Clear-Sky Solar Irradiance	taub	0.352	0.383	0.418	0.451	0.436	0.400	0.397	0.407	0.391	0.391	0.369	0.355	
	taud	2.419	2.314	2.200	2.141	2.243	2.382	2.388	2.350	2.399	2.381	2.411	2.434	
	Ebn at Noon	825	840	841	833	851	880	880	863	860	821	798	794	
	Edh at Noon	88	110	134	151	138	120	119	121	109	101	88	82	
All-Sky Solar Radiation	RadAvg	2.28	3.10	4.55	5.88	7.06	7.99	8.09	7.21	5.84	4.17	2.83	2.09	
	RadStd	0.25	0.28	0.28	0.47	0.33	0.30	0.12	0.12	0.24	0.20	0.22	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page