

DALAMAN, Turkey

WMO: 172950

Lat: 36.723N

Lon: 28.790E

Elev: 16

StdP: 14.69

Time Zone: 3.00 (E03)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.0	38.9	14.0	11.2	43.9	18.5	14.0	45.5	31.1	50.4	28.2	51.6	10.0	40	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.8	95.4	69.3	91.8	70.7	89.7	72.0	77.8	87.2	76.7	86.5	75.6	85.6	12.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.9	131.0	85.4	73.4	124.5	84.5	71.9	118.0	83.5	41.3	87.3	40.3	86.2	39.2	85.8	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.6	20.4	17.8	31.7	105.2	2.8	3.5	29.7	107.7	28.0	109.7	26.4	111.6	24.4	114.1
			28.0	79.6	3.2	1.9	25.7	81.0	23.9	82.1	22.1	83.1	19.8	84.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.1	51.5	52.5	55.3	59.9	67.4	75.4	80.5	80.7	75.3	67.8	60.0	54.1
	DBStd	11.32	4.66	4.67	4.18	3.95	4.05	5.00	4.04	3.37	3.97	4.20	4.50	4.60
	HDD50	91	38	26	7	1	0	0	0	0	0	0	2	17
	HDD65	1764	418	351	302	160	19	0	0	0	0	20	157	337
	CDD50	5602	84	95	171	297	539	762	945	951	760	552	302	144
	CDD65	1803	0	0	1	6	93	312	480	486	311	107	7	0
	CDH74	19293	0	0	12	52	633	3104	5719	5860	3085	794	34	0
	CDH80	7653	0	0	1	5	99	1063	2600	2713	1071	100	1	0
Wind	WSAvg	8.1	8.9	8.9	8.4	7.9	7.7	8.3	8.3	7.7	7.8	7.3	7.4	8.3
Precipitation	PrecAvg	37.8	6.9	5.4	3.1	2.2	1.1	0.2	0.1	0.1	0.9	2.8	5.2	8.1
	PrecMax	52.8	17.6	12.4	7.7	5.9	3.5	1.2	0.4	0.9	4.4	8.2	13.2	14.6
	PrecMin	27.0	0.3	1.1	0.5	0.4	0.0	0.0	0.0	0.0	0.3	1.0	0.7	0.7
	PrecStd	7.1	4.0	3.1	1.7	1.2	0.9	0.2	0.1	0.2	1.2	2.0	3.2	4.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.6	69.6	74.8	79.0	87.6	98.8	101.9	100.1	94.6	86.1	77.3	69.7
		MCWB	56.0	55.7	56.9	61.5	63.8	67.8	69.1	70.3	67.8	64.8	63.3	59.2
	2%	DB	64.3	65.9	69.5	75.0	82.5	92.8	96.5	94.6	89.7	82.5	74.7	66.6
		MCWB	55.0	55.3	56.3	60.2	64.9	68.3	68.5	71.2	69.4	66.3	61.9	57.0
	5%	DB	62.5	63.9	66.5	71.9	79.2	88.2	91.9	91.3	87.5	80.5	72.7	65.0
		MCWB	54.5	54.7	56.3	59.8	65.4	68.8	70.5	72.9	70.0	66.4	61.2	56.4
	10%	DB	60.8	62.1	64.6	69.8	77.2	85.7	89.5	89.4	85.7	78.7	70.1	64.0
		MCWB	53.3	54.3	55.5	59.8	65.3	69.6	71.9	74.0	70.4	65.6	60.0	55.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.1	59.0	61.1	65.4	70.0	75.8	78.9	79.5	76.6	72.7	67.2	61.6
		MCDB	63.8	64.7	67.4	73.6	78.5	84.4	87.7	88.2	85.9	79.6	74.0	66.6
	2%	WB	56.7	57.2	59.7	63.4	68.6	74.1	77.2	78.4	75.0	70.3	64.8	59.5
		MCDB	62.1	63.1	66.0	71.0	77.5	83.7	86.6	87.6	85.1	78.3	71.9	65.0
	5%	WB	55.3	55.8	58.3	62.1	67.5	72.7	76.0	77.3	73.7	68.7	63.1	57.9
		MCDB	61.3	62.0	64.7	69.4	76.5	82.6	85.9	87.1	84.0	77.1	70.0	63.8
	10%	WB	53.9	54.5	56.8	60.6	66.4	71.5	75.0	76.4	72.3	67.1	61.1	56.4
		MCDB	59.8	60.9	63.3	67.8	75.4	81.5	85.2	86.4	82.8	76.0	68.3	62.2
Mean Daily Temperature Range	5% DB	MDBR	15.4	15.8	17.7	18.5	19.0	20.0	19.3	18.8	19.7	19.9	19.0	16.1
		MCDBR	17.3	17.7	20.3	21.8	22.0	24.1	24.0	21.8	21.3	21.7	21.9	18.0
		MCWBR	11.2	11.1	11.9	12.3	11.2	10.6	11.6	12.4	12.8	12.9	13.4	11.3
	5% WB	MCDBR	15.2	16.3	18.5	19.4	19.6	20.7	18.9	18.8	19.7	19.9	18.8	15.6
		MCWBR	10.6	11.2	12.2	12.4	11.3	10.6	11.1	11.4	12.5	13.0	12.1	10.7
Clear-Sky Solar Irradiance	taub	0.349	0.378	0.415	0.449	0.435	0.401	0.401	0.420	0.393	0.391	0.365	0.351	
	taud	2.444	2.342	2.223	2.161	2.262	2.396	2.392	2.334	2.412	2.400	2.440	2.466	
	Ebn at Noon	265	269	269	266	271	279	278	271	273	262	257	256	
	Edh at Noon	27	34	42	47	43	38	38	39	34	32	27	25	
All-Sky Solar Radiation	RadAvg	741	1006	1456	1865	2210	2513	2534	2255	1858	1332	923	684	
	RadStd	82	95	92	139	112	89	53	48	81	71	65	77	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-112	N/A	N/A
Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-119	N/A	N/A

Nomenclature: See separate page