

DALAMAN, Turkey

WMO: 172950

Lat: 36.723N

Lon: 28.790E

Elev: 5

StdP: 101.26

Time Zone: 3.00 (E03)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.2	3.9	-10.0	1.6	6.6	-7.5	2.0	7.5	13.9	10.2	12.6	10.9	4.5	40	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.5	35.2	20.7	33.2	21.5	32.0	22.2	25.5	30.7	24.8	30.3	24.2	29.8	5.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	18.7	29.7	23.0	17.8	29.2	22.2	16.9	28.6	78.3	30.7	75.8	30.1	73.2	29.9	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.6	9.1	7.9	-0.2	40.7	1.6	1.9	-1.3	42.0	-2.2	43.2	-3.1	44.2	-4.2	45.6
			-2.2	26.5	1.8	1.0	-3.5	27.2	-4.5	27.8	-5.5	28.4	-6.8	29.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	10.8	11.4	12.9	15.5	19.7	24.1	26.9	27.1	24.1	19.9	15.6	12.3
	DBStd	6.29	2.59	2.59	2.32	2.19	2.25	2.78	2.25	1.87	2.20	2.34	2.50	2.56
	HDD10.0	51	21	14	4	1	0	0	0	0	0	1	9	
	HDD18.3	980	232	195	168	89	11	0	0	0	11	87	187	
	CDD10.0	3112	47	53	95	165	299	423	525	528	422	307	168	80
	CDD18.3	1002	0	0	1	3	52	173	267	270	173	59	4	0
	CDH23.3	10718	0	0	7	29	352	1724	3177	3256	1714	441	19	0
CDH26.7	4252	0	0	1	3	55	591	1444	1507	595	56	1	0	
Wind	WSAvg	3.6	4.0	4.0	3.7	3.5	3.4	3.7	3.7	3.4	3.5	3.3	3.3	3.7
Precipitation	PrecAvg	959	175	136	79	55	28	5	2	3	23	72	131	206
	PrecMax	1342	448	314	196	150	90	30	11	23	112	208	336	371
	PrecMin	685	8	28	13	10	0	0	0	1	7	25	18	
	PrecStd	181	101	78	43	31	22	6	3	6	30	52	82	111
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.2	20.9	23.8	26.1	30.9	37.1	38.8	37.9	34.8	30.1	25.2	20.9
		MCWB	13.3	13.2	13.8	16.4	17.7	19.9	20.6	21.3	19.9	18.2	17.4	15.1
	2%	DB	17.9	18.9	20.8	23.9	28.1	33.8	35.9	34.8	32.1	28.1	23.7	19.2
		MCWB	12.8	12.9	13.5	15.7	18.3	20.2	20.3	21.8	20.8	19.1	16.6	13.9
	5%	DB	17.0	17.7	19.2	22.2	26.2	31.2	33.3	32.9	30.9	26.9	22.6	18.4
		MCWB	12.5	12.6	13.5	15.4	18.5	20.4	21.4	22.7	21.1	19.1	16.2	13.5
	10%	DB	16.0	16.7	18.1	21.0	25.1	29.8	31.9	31.9	29.8	25.9	21.2	17.8
		MCWB	11.8	12.4	13.1	15.4	18.5	20.9	22.2	23.3	21.3	18.7	15.6	13.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.1	15.0	16.2	18.5	21.1	24.3	26.1	26.4	24.8	22.6	19.5	16.4
		MCDB	17.7	18.2	19.7	23.1	25.8	29.1	30.9	31.2	30.0	26.5	23.3	19.2
	2%	WB	13.7	14.0	15.4	17.5	20.3	23.4	25.1	25.8	23.9	21.3	18.2	15.3
		MCDB	16.7	17.3	18.9	21.6	25.3	28.7	30.3	30.9	29.5	25.7	22.2	18.3
	5%	WB	12.9	13.2	14.6	16.7	19.7	22.6	24.4	25.2	23.2	20.4	17.3	14.4
		MCDB	16.3	16.7	18.1	20.8	24.7	28.1	29.9	30.6	28.9	25.1	21.1	17.7
	10%	WB	12.2	12.5	13.8	15.9	19.1	21.9	23.9	24.6	22.4	19.5	16.2	13.5
		MCDB	15.5	16.1	17.4	19.9	24.1	27.5	29.6	30.2	28.2	24.4	20.2	16.8
Mean Daily Temperature Range	5% DB	MDBR	8.6	8.8	9.9	10.3	10.6	11.1	10.7	10.5	10.9	11.1	10.6	8.9
		MCDBR	9.6	9.8	11.3	12.1	12.2	13.4	13.3	12.1	11.8	12.1	12.2	10.0
		MCWBR	6.2	6.1	6.6	6.8	6.2	5.9	6.4	6.9	7.1	7.2	7.5	6.3
	5% WB	MCDBR	8.4	9.1	10.3	10.8	10.9	11.5	10.5	10.4	11.0	11.0	10.4	8.7
		MCWBR	5.9	6.2	6.8	6.9	6.3	5.9	6.2	6.3	6.9	7.2	6.7	6.0
Clear-Sky Solar Irradiance	taub	0.349	0.378	0.415	0.449	0.435	0.401	0.401	0.420	0.393	0.391	0.365	0.351	
	taud	2.444	2.342	2.223	2.161	2.262	2.396	2.392	2.334	2.412	2.400	2.440	2.466	
	Ebn at Noon	835	849	847	837	853	880	876	853	860	825	809	807	
	Edh at Noon	86	107	132	148	136	119	119	123	108	100	86	80	
All-Sky Solar Radiation	RadAvg	2.34	3.17	4.59	5.88	6.97	7.92	7.99	7.11	5.86	4.20	2.91	2.16	
	RadStd	0.26	0.30	0.29	0.44	0.35	0.28	0.17	0.15	0.25	0.23	0.21	0.24	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-62	N/A	N/A	(46)
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-66	N/A	N/A	(47)

Nomenclature: See separate page