

ANTALYA BOLGE, Turkey

WMO: 173020

Lat: 36.8850N

Lon: 30.6829E

Elev: 47

StdP: 100.76

Time Zone: 3.00 (E03)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.1	6.1	-13.7	1.2	5.6	-11.0	1.5	8.6	15.2	15.2	12.6	15.3	3.3	350	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.6	37.5	19.6	35.4	20.5	33.5	21.3	26.9	30.4	26.4	30.0	25.8	29.6	2.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.3	29.8	25.3	20.6	29.5	24.6	19.7	29.0	85.1	30.4	82.8	30.0	80.2	29.7	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.9	4.5	3.9	DB	2.8	41.9	2.4	1.4	1.1	42.9	-0.2	43.7	-1.6	44.5	-3.3	45.5	(4)
(5)			WB	-1.7	27.8	2.0	0.6	-3.1	28.2	-4.3	28.6	-5.5	28.9	-6.9	29.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.5	11.8	13.2	14.9	18.0	21.4	25.8	29.4	29.9	26.7	22.6	18.4	13.7	(6)	
	DBStd	6.66	2.52	2.47	2.07	2.51	2.57	3.42	2.86	2.29	2.20	2.52	2.06	2.48	(7)	
	HDD10.0	23	14	4	1	0	0	0	0	0	0	0	0	4	(8)	
	HDD18.3	658	201	144	109	35	3	0	0	0	0	1	23	143	(9)	
	CDD10.0	3867	71	94	152	239	355	475	601	617	499	392	252	119	(10)	
	CDD18.3	1460	0	1	1	24	99	225	342	359	249	134	25	0	(11)	
	CDH23.3	14496	0	2	2	79	371	1974	4226	4674	2447	677	44	0	(12)	
	CDH26.7	5960	0	0	0	21	68	729	1953	2273	793	119	3	0	(13)	
(14) Wind	WSAvg	1.7	2.1	1.8	1.8	1.7	1.6	1.6	1.6	1.6	1.6	1.6	1.5	1.7	(14)	
(15) Precipitation	PrecAvg	1083	225	155	107	53	33	8	1	2	16	69	143	257	(15)	
	PrecMax	1914	798	625	399	167	120	48	19	29	79	495	907	652	(16)	
	PrecMin	553	0	4	9	0	0	0	0	0	0	0	1	15	(17)	
	PrecStd	331	159	111	77	42	30	10	4	5	22	84	161	171	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.5	21.9	23.0	29.3	31.5	39.3	40.2	39.2	35.7	32.3	26.2	21.3	(19)	
		MCWB	11.6	12.4	12.2	15.3	17.9	20.5	19.2	19.5	18.9	17.8	15.4	13.7	(20)	
	2%	DB	17.7	19.4	20.8	25.1	28.3	35.9	37.8	36.9	33.0	29.5	24.6	19.9	(21)	
		MCWB	11.7	13.7	12.4	15.8	19.1	20.0	19.6	19.6	19.8	17.3	15.7	13.7	(22)	
	5%	DB	16.6	18.0	19.6	23.2	26.6	32.7	35.2	34.9	31.2	27.6	23.5	18.7	(23)	
		MCWB	11.6	12.9	12.9	15.5	18.6	20.1	20.8	21.2	21.6	18.3	15.7	13.0	(24)	
	10%	DB	15.7	17.0	18.4	21.6	25.1	30.5	33.1	33.4	30.1	26.4	22.3	17.7	(25)	
		MCWB	11.2	12.3	12.9	15.7	18.4	20.6	21.8	22.2	22.3	18.4	15.4	12.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.5	16.7	16.2	20.3	22.5	26.2	27.3	27.8	26.5	22.3	19.0	16.3	(27)	
		MCDB	16.8	18.4	18.3	22.2	25.6	29.0	30.6	31.0	30.1	26.4	22.7	19.2	(28)	
	2%	WB	13.6	15.5	15.3	18.8	21.6	24.9	26.7	27.1	25.7	21.5	17.9	15.3	(29)	
		MCDB	15.7	17.4	18.1	21.1	24.9	28.3	30.2	30.5	29.6	25.8	22.4	18.1	(30)	
	5%	WB	12.8	14.4	14.7	17.8	20.8	24.0	26.1	26.6	24.9	20.7	17.1	14.5	(31)	
		MCDB	15.2	16.7	17.7	20.9	24.2	27.6	29.7	30.2	29.1	25.2	21.6	17.4	(32)	
	10%	WB	12.0	13.4	14.1	16.9	20.1	23.2	25.5	26.1	24.0	20.0	16.4	13.5	(33)	
		MCDB	14.6	15.9	17.2	20.6	23.7	27.2	29.3	29.9	28.5	25.0	20.9	16.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	6.7	6.7	6.3	6.0	6.7	6.9	6.6	6.6	7.2	7.0	6.8	(35)	
		MCDBR	7.6	7.8	8.3	8.6	8.1	11.1	10.8	9.5	8.2	8.2	7.9	7.8	(36)	
	5% WB	MCWBR	5.2	5.2	5.8	6.4	6.4	6.1	7.3	7.9	7.4	6.4	6.0	5.7	(37)	
		MCWBR	6.4	6.7	6.4	6.5	5.9	6.7	6.4	5.5	6.3	6.6	6.8	6.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.350	0.379	0.419	0.459	0.446	0.412	0.418	0.432	0.405	0.393	0.363	0.352	(40)	
		taud	2.411	2.314	2.192	2.110	2.212	2.347	2.333	2.282	2.359	2.367	2.413	2.432	(41)	
	Ebn at Noon		830	846	842	827	842	870	861	842	847	821	808	802	(42)	
		Edh at Noon	89	110	136	156	143	125	126	130	114	103	88	82	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.29	3.15	4.54	5.73	6.68	7.68	7.77	6.91	5.71	4.12	2.90	2.14	(44)	
	RadStd		0.29	0.31	0.30	0.41	0.36	0.35	0.19	0.15	0.28	0.24	0.23	0.27	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-72	N/A	N/A

Nomenclature: See separate page