

SILIFKE, Turkey

WMO: 173300

Lat: 36.3821N

Lon: 33.9366E

Elev: 15

StdP: 101.14

Time Zone: 3.00 (E03)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.4	4.7	-12.2	1.3	7.4	-9.5	1.7	7.7	8.0	4.4	7.4	5.4	4.3	320	0.329

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.1	35.0	23.8	33.9	24.8	33.0	25.0	27.9	32.5	27.3	32.0	26.8	31.4	2.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.3	31.4	26.0	21.4	30.8	25.4	20.6	30.3	89.7	32.5	87.0	32.3	84.3	31.3	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.4	5.5	4.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	11.1	11.8	14.8	17.8	22.2	25.8	28.6	28.8	26.3	23.5	17.4	12.6
	DBStd	6.83	2.75	3.03	2.85	2.67	2.62	2.21	1.44	1.53	1.74	2.72	3.38	2.96
	HDD10.0	54	22	16	2	0	0	0	0	0	0	0	2	12
	HDD18.3	799	224	183	116	40	1	0	0	0	0	3	54	178
	CDD10.0	3741	56	66	150	235	377	474	576	583	491	417	224	92
	CDD18.3	1445	0	0	5	25	120	224	317	324	241	162	27	0
	CDH23.3	15220	0	0	23	162	904	2324	4137	4209	2306	1079	75	0
CDH26.7	6399	0	0	2	39	254	874	1964	2038	901	321	6	0	
Wind	WSAvg	1.7	2.2	2.3	1.7	1.6	1.5	1.5	1.5	1.4	1.6	1.7	1.7	1.9
Precipitation	PrecAvg	519	93	72	43	27	28	5	2	2	10	35	77	125
	PrecMax	944	250	120	108	76	111	25	23	29	62	95	212	484
	PrecMin	296	0	3	0	1	0	0	0	0	0	0	0	0
	PrecStd	173	60	29	30	20	31	8	5	5	15	28	61	106
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.2	21.0	25.8	30.4	34.3	37.0	37.2	36.3	35.2	33.7	27.3	21.1
		MCWB	12.7	13.5	14.1	18.8	22.4	23.8	23.0	24.8	23.3	18.0	17.9	13.7
	2%	DB	17.6	19.4	23.3	27.3	31.5	33.8	34.7	34.5	32.9	31.4	25.4	19.5
		MCWB	12.3	12.9	13.7	18.3	21.1	22.2	24.2	26.0	23.2	19.5	17.3	13.1
	5%	DB	16.4	17.9	21.5	25.0	29.4	31.9	33.6	33.7	31.8	29.8	23.8	18.0
		MCWB	11.6	12.1	13.4	17.1	20.9	22.6	24.8	26.5	23.7	19.8	16.5	12.3
	10%	DB	15.1	16.6	19.8	23.0	27.7	30.5	32.7	33.0	30.8	28.4	22.1	16.5
		MCWB	10.5	11.3	13.1	16.7	20.2	22.8	25.1	26.5	23.3	19.3	15.7	11.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.4	14.7	16.7	20.3	25.0	26.6	28.3	29.0	27.7	24.3	20.0	15.5
		MCDB	17.3	19.1	21.7	26.5	31.0	31.8	33.1	33.2	32.6	29.3	25.1	18.9
	2%	WB	13.3	13.8	15.3	19.0	23.4	25.7	27.7	28.2	26.4	23.2	18.6	14.4
		MCDB	16.5	18.1	20.2	24.8	28.4	30.4	32.4	32.6	31.1	28.6	23.6	17.6
	5%	WB	12.3	12.9	14.5	18.1	22.0	25.1	27.1	27.7	25.5	22.0	17.6	13.4
		MCDB	15.2	17.0	19.6	23.8	26.9	29.5	31.7	32.1	30.1	27.5	22.3	16.3
	10%	WB	11.5	11.9	13.7	17.3	21.1	24.4	26.5	27.1	24.7	20.7	16.6	12.5
		MCDB	14.1	15.7	19.0	22.1	26.3	28.8	31.1	31.7	29.2	26.4	20.9	15.4
Mean Daily Temperature Range	5% DB	MDBR	6.5	7.2	8.2	8.8	9.1	8.6	8.2	8.1	8.9	9.1	7.9	6.6
		MCDBR	8.1	8.9	9.9	11.2	11.1	10.5	9.5	8.7	9.6	10.4	9.4	8.3
		MCWBR	5.1	5.5	5.5	6.0	6.3	6.5	6.3	6.0	6.8	6.2	5.8	5.1
	5% WB	MCDBR	7.1	8.5	9.1	9.7	10.0	8.6	8.5	8.6	8.8	9.8	8.9	7.3
		MCWBR	4.8	5.6	5.8	5.9	6.5	5.6	5.5	5.8	6.5	6.8	5.9	4.8
Clear-Sky Solar Irradiance	taub	0.371	0.396	0.434	0.489	0.473	0.434	0.448	0.456	0.418	0.417	0.385	0.369	
	taud	2.315	2.239	2.132	2.015	2.118	2.276	2.249	2.214	2.318	2.275	2.314	2.341	
	Ebn at Noon	803	828	828	801	820	851	836	821	835	795	780	779	
	Edh at Noon	99	119	145	172	157	134	137	139	119	114	98	91	
All-Sky Solar Radiation	RadAvg	2.31	3.20	4.62	5.80	6.82	7.80	7.83	7.02	5.78	4.17	2.97	2.19	
	RadStd	0.28	0.34	0.27	0.41	0.32	0.30	0.18	0.16	0.22	0.27	0.21	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	+0.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+102	N/A

Nomenclature: See separate page