

ADANA INCIRLIK, Turkey

WMO: 173500

Lat: 37.001N

Lon: 35.418E

Elev: 217

StdP: 14.58

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 33308

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.6	35.9	12.0	10.2	43.8	16.4	12.7	45.7	23.6	47.5	21.1	48.9	6.7	30	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.6	98.2	72.3	95.3	73.3	93.4	73.8	79.7	89.6	78.8	88.3	77.9	86.9	9.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.3	143.1	83.4	76.3	138.5	83.0	75.3	133.8	82.6	43.6	89.5	42.4	88.7	41.5	87.3	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.5	16.9	14.9	DB	28.4	104.5	3.4	3.3	26.0	106.8	24.0	108.8	22.1	110.6	19.7	113.0
			WB	24.7	81.5	3.3	1.9	22.3	82.8	20.3	84.0	18.5	85.0	16.0	86.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.0	49.5	51.9	56.6	63.3	71.2	78.2	83.2	84.4	79.6	72.1	61.1	52.4	(6)
	DBStd	13.10	4.71	5.48	5.25	5.56	5.12	3.88	2.54	2.40	3.67	5.51	6.08	4.98	(7)
	HDD50	151	65	40	9	1	0	0	0	0	0	0	4	32	(8)
	HDD65	1755	480	367	263	95	7	0	0	0	0	10	143	390	(9)
	CDD50	6370	50	93	214	400	656	845	1028	1065	887	687	337	108	(10)
	CDD65	2499	0	0	4	44	198	395	563	600	437	232	26	0	(11)
	CDH74	27442	0	6	53	515	1941	4093	6718	7302	4509	2043	255	7	(12)
	CDH80	12540	0	0	5	156	776	1819	3211	3652	2108	773	39	1	(13)
(14) Wind	WSAvg	6.7	7.4	7.1	6.9	6.5	6.3	6.7	6.8	6.4	6.4	6.1	6.3	7.1	(14)
(15) Precipitation	PrecAvg	27.9	4.2	3.7	2.9	2.5	2.2	1.0	0.4	0.4	1.0	1.6	2.4	4.9	(15)
	PrecMax	43.0	11.3	5.5	5.7	5.7	5.3	3.9	2.2	1.8	2.5	5.1	7.3	14.4	(16)
	PrecMin	16.0	0.6	0.2	0.2	0.7	0.6	0.2	0.0	0.0	0.0	0.2	0.0	0.4	(17)
	PrecStd	5.9	2.8	1.4	1.5	1.4	1.2	0.9	0.5	0.4	0.7	1.3	1.9	3.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.4	73.0	79.2	90.0	97.0	100.6	100.4	102.1	100.2	95.9	84.3	71.9	(19)
		MCWB	53.2	54.0	58.5	64.6	67.5	69.2	74.3	75.6	69.6	65.6	58.9	54.2	(20)
	2%	DB	63.2	68.3	74.7	84.4	92.7	95.8	96.4	97.1	95.1	91.3	80.3	67.8	(21)
		MCWB	52.1	54.2	57.4	63.3	67.3	70.5	74.9	75.3	70.7	64.7	59.0	53.4	(22)
	5%	DB	61.1	65.7	71.3	80.1	88.0	91.8	93.5	95.0	92.8	87.5	76.9	64.6	(23)
		MCWB	50.7	53.3	56.9	61.7	67.1	70.7	75.5	76.2	72.0	65.1	58.1	52.1	(24)
	10%	DB	58.9	62.6	67.8	75.5	84.1	89.1	91.7	93.2	89.9	84.2	73.2	61.6	(25)
		MCWB	49.4	51.8	56.0	61.3	66.6	71.8	75.6	76.2	72.0	64.5	57.6	51.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.9	59.1	62.3	67.9	72.9	78.3	81.4	81.5	78.1	73.8	64.8	59.1	(27)
		MCDB	62.1	66.8	71.3	82.1	86.3	89.0	91.8	93.4	89.8	83.1	74.1	65.6	(28)
	2%	WB	54.6	56.5	60.2	65.6	71.0	76.5	79.8	79.9	77.0	71.4	62.8	56.6	(29)
		MCDB	60.2	64.2	68.4	78.6	83.2	86.1	89.2	89.9	87.9	80.9	72.7	62.7	(30)
	5%	WB	52.9	54.9	58.8	64.0	69.6	75.4	78.6	79.1	75.9	69.7	61.1	55.0	(31)
		MCDB	58.3	62.8	67.0	75.4	81.4	84.5	87.7	88.7	86.3	79.9	70.8	61.2	(32)
	10%	WB	51.2	53.2	57.3	62.5	68.4	74.1	77.6	78.3	74.9	68.1	59.4	53.4	(33)
		MCDB	56.2	60.9	65.4	72.3	79.5	83.1	86.2	87.5	84.7	78.3	68.8	59.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.3	18.2	19.7	21.2	22.4	21.1	18.8	19.6	22.1	22.1	20.5	16.9	(35)
		MCDBR	20.1	22.1	24.7	28.4	29.8	26.6	21.6	22.4	25.0	26.1	25.6	21.6	(36)
	5% WB	MCWBR	11.9	11.8	12.1	12.4	11.1	9.9	7.5	7.6	9.0	10.4	11.7	11.8	(37)
		MCWBR	15.5	18.7	20.4	23.1	24.1	20.9	18.3	19.0	21.1	20.4	19.2	16.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.371	0.392	0.426	0.478	0.461	0.430	0.441	0.452	0.415	0.413	0.380	0.365	(40)
		taud	2.285	2.222	2.132	2.026	2.135	2.262	2.252	2.207	2.305	2.269	2.307	2.326	(41)
	Ebn at Noon		253	262	264	257	263	271	267	261	265	252	247	246	(42)
		Edh at Noon	32	38	46	54	49	43	43	44	38	36	31	29	(43)
(44) All-Sky Solar Radiation	RadAvg		710	999	1410	1754	2088	2403	2426	2164	1783	1287	908	667	(44)
	RadStd		97	131	82	144	110	104	82	71	76	85	69	98	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	-4.25	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page