

ADANA SAKIRPASA, Turkey

WMO: 173520

Lat: 36.982N

Lon: 35.280E

Elev: 65

StdP: 14.66

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.2	37.4	11.8	10.0	46.9	16.0	12.4	47.9	20.3	49.3	18.3	50.4	3.6	30	0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.1	97.5	72.4	95.2	73.7	93.4	74.3	79.9	89.6	79.0	88.2	78.2	87.0	8.4	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.3	142.3	83.5	76.7	139.7	83.2	75.5	133.7	82.7	43.4	89.6	42.5	88.9	41.7	86.6	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	15.0	13.5	28.8	104.3	3.4	3.3	26.3	106.7	24.3	108.7	22.4	110.5	20.0	113.0		
(5)			25.6	82.1	3.5	1.8	23.1	83.4	21.0	84.5	19.0	85.5	16.5	86.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.0	50.4	52.9	58.0	64.9	72.7	79.1	83.9	85.3	80.7	72.7	61.5	53.0		
	DBStd	13.06	4.59	5.29	5.04	5.51	5.10	3.45	2.19	2.14	3.69	5.45	5.50	4.71		
	HDD50	111	50	29	5	0	0	0	0	0	0	0	2	25		
	HDD65	1592	453	339	223	66	3	0	0	0	0	9	128	371		
	CDD50	6684	62	110	252	447	703	874	1051	1095	921	703	347	119		
	CDD65	2690	0	0	5	63	241	424	586	630	471	247	23	0		
	CDH74	28706	0	8	66	612	2077	4135	6910	7763	4790	2082	256	7		
	CDH80	13001	0	0	7	198	830	1807	3266	3858	2203	794	37	1		
(14) Wind	WSAvg	5.5	5.8	5.9	6.0	5.7	5.4	5.8	5.8	5.6	5.4	4.8	4.4	5.4		
(15) Precipitation	PrecAvg	27.4	4.5	3.4	2.8	2.2	1.9	0.9	0.2	0.2	0.5	1.7	3.1	5.4		
	PrecMax	49.8	15.5	9.3	8.1	7.6	8.3	4.9	2.2	1.9	2.2	4.6	13.5	16.4		
	PrecMin	12.6	0.4	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0		
	PrecStd	8.9	3.6	2.1	1.9	1.8	1.7	1.1	0.5	0.5	0.6	1.3	2.6	4.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.8	73.7	79.7	91.5	98.5	100.2	100.0	102.1	100.2	96.8	84.3	72.0		
		MCWB	53.7	54.4	57.9	65.4	68.5	69.8	75.2	76.0	70.9	67.3	59.7	55.3		
	2%	DB	64.5	69.6	75.3	85.7	93.0	95.0	95.2	97.0	95.2	91.3	80.3	68.1		
		MCWB	52.5	54.4	57.1	63.0	67.7	71.1	75.5	75.2	72.2	66.0	58.8	53.5		
	5%	DB	62.3	66.3	71.6	80.8	88.2	91.5	93.3	95.0	92.9	87.6	77.0	64.9		
		MCWB	51.2	53.4	56.5	61.2	67.3	71.8	75.9	76.1	72.6	65.5	58.2	52.4		
	10%	DB	59.3	63.0	68.3	76.8	84.2	88.8	91.6	93.3	90.0	84.3	73.3	62.5		
		MCWB	49.1	52.0	55.9	61.3	66.7	72.3	76.1	76.2	72.4	65.3	57.8	51.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.2	58.9	62.1	68.4	74.1	78.8	81.1	81.1	78.9	73.3	65.7	59.7		
		MCDB	63.5	67.5	71.3	84.3	88.3	89.0	91.8	91.6	89.8	84.3	76.0	66.6		
	2%	WB	55.0	56.6	60.2	65.6	71.8	77.0	79.8	80.0	77.4	71.5	63.4	57.2		
		MCDB	61.5	65.4	69.0	77.8	84.3	87.0	89.5	89.6	87.2	81.4	72.4	63.4		
	5%	WB	53.0	55.2	58.9	63.9	70.0	75.6	78.9	79.3	76.4	70.0	61.6	55.6		
		MCDB	58.7	63.7	67.4	74.9	81.4	84.9	87.7	88.4	85.7	80.2	70.2	61.6		
	10%	WB	51.5	53.4	57.4	62.5	68.8	74.4	78.0	78.6	75.4	68.7	59.9	54.1		
		MCDB	56.6	61.4	65.8	72.9	79.6	83.3	86.5	87.4	84.3	78.5	68.1	60.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.6	18.3	19.0	20.3	20.7	19.1	17.2	18.1	20.5	22.0	21.2	17.4		
		MCDBR	21.2	22.7	24.1	27.6	28.0	24.3	19.3	20.4	23.3	26.8	26.8	22.9		
		MCWBR	11.8	11.8	11.2	10.7	9.5	8.3	6.4	6.3	7.5	9.6	10.9	11.7		
		MCDBR	16.1	18.6	18.8	21.9	22.1	18.4	16.8	17.7	19.6	20.3	19.4	16.4		
	5% WB	MCWBR	10.1	10.5	10.2	9.9	8.5	7.0	5.6	5.5	6.7	8.8	10.0	9.5		
(40) Clear-Sky Solar Irradiance	taub		0.374	0.395	0.430	0.482	0.465	0.434	0.445	0.455	0.419	0.415	0.383	0.368		
	taud		2.277	2.215	2.126	2.018	2.127	2.256	2.244	2.201	2.297	2.264	2.299	2.316		
	Ebn at Noon		252	261	263	255	262	270	266	260	264	251	246	245		
	Edh at Noon		32	38	46	54	49	43	43	44	38	36	31	29		
(44) All-Sky Solar Radiation	RadAvg		713	1002	1413	1759	2089	2406	2430	2170	1787	1290	909	670		
	RadStd		96	128	81	144	110	103	81	68	76	85	70	96		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	-4.66	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	N/A	N/A	-3.46	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page