

ADANA SAKIRPASA, Turkey

WMO: 173520

Lat: 36.982N

Lon: 35.280E

Elev: 20

StdP: 101.09

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.2	3.0	-11.2	1.4	8.3	-8.9	1.8	8.8	9.1	9.6	8.2	10.2	1.6	30	0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.0	36.4	22.4	35.1	23.2	34.1	23.5	26.6	32.0	26.1	31.2	25.7	30.5	3.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.3	28.6	24.9	20.0	28.5	24.2	19.1	28.2	83.1	32.0	81.0	31.6	79.2	30.3	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.7	6.7	6.0	DB	-1.8	40.2	1.9	1.9	-3.2	41.5	-4.3	42.6	-5.3	43.6	-6.7	45.0	(4)
			WB	-3.6	27.8	1.9	1.0	-5.0	28.6	-6.1	29.2	-7.2	29.7	-8.6	30.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.0	10.2	11.6	14.4	18.3	22.6	26.2	28.8	29.6	27.0	22.6	16.4	11.7	(6)
(7)		DBStd	7.25	2.55	2.94	2.80	3.06	2.83	1.92	1.22	1.19	2.05	3.03	3.06	2.62	(7)
(8)		HDD10.0	62	28	16	3	0	0	0	0	0	0	0	1	14	(8)
(9)		HDD18.3	884	252	188	124	37	2	0	0	0	0	5	71	206	(9)
(10)		CDD10.0	3713	34	61	140	248	391	486	584	608	512	391	193	66	(10)
(11)		CDD18.3	1494	0	0	3	35	134	236	326	350	262	137	13	0	(11)
(12)		CDH23.3	15948	0	4	37	340	1154	2297	3839	4313	2661	1157	142	4	(12)
(13)		CDH26.7	7223	0	0	4	110	461	1004	1814	2143	1224	441	21	1	(13)
(14)	Wind	WSAvg	2.5	2.6	2.6	2.7	2.5	2.4	2.6	2.6	2.5	2.4	2.2	2.0	2.4	(14)
(15)	Precipitation	PrecAvg	696	114	86	72	56	48	23	6	5	12	42	78	138	(15)
(16)		PrecMax	1265	394	236	206	193	211	125	56	49	56	116	343	416	(16)
(17)		PrecMin	319	10	2	4	0	0	0	0	0	0	0	2	0	(17)
(18)		PrecStd	227	91	54	47	46	44	27	13	12	15	34	67	105	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.9	23.1	26.5	33.1	36.9	37.9	37.8	38.9	37.9	36.0	29.1	22.2	(19)
(20)			MCWB	12.0	12.5	14.4	18.6	20.3	21.0	24.0	24.4	21.6	19.6	15.4	12.9	(20)
(21)		2%	DB	18.0	20.9	24.0	29.8	33.9	35.0	35.1	36.1	35.1	33.0	26.8	20.1	(21)
(22)			MCWB	11.4	12.5	14.0	17.2	19.9	21.7	24.2	24.0	22.3	18.9	14.9	11.9	(22)
(23)		5%	DB	16.8	19.1	22.0	27.1	31.2	33.1	34.1	35.0	33.8	30.9	25.0	18.3	(23)
(24)			MCWB	10.6	11.9	13.6	16.2	19.6	22.1	24.4	24.5	22.6	18.6	14.5	11.3	(24)
(25)		10%	DB	15.1	17.2	20.2	24.9	29.0	31.5	33.1	34.0	32.2	29.0	22.9	16.9	(25)
(26)			MCWB	9.5	11.1	13.3	16.3	19.3	22.4	24.5	24.6	22.4	18.5	14.4	11.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	14.9	16.7	20.2	23.4	26.0	27.3	27.3	26.1	22.9	18.7	15.4	(27)
(28)			MCDWB	17.5	19.7	21.9	29.1	31.3	31.7	33.2	33.1	32.1	29.1	24.5	19.2	(28)
(29)		2%	WB	12.8	13.7	15.6	18.7	22.1	25.0	26.6	26.7	25.2	21.9	17.5	14.0	(29)
(30)			MCDWB	16.4	18.6	20.6	25.5	29.1	30.5	32.0	32.0	30.7	27.5	22.4	17.5	(30)
(31)		5%	WB	11.7	12.9	14.9	17.7	21.1	24.2	26.0	26.3	24.7	21.1	16.4	13.1	(31)
(32)			MCDWB	14.9	17.6	19.7	23.9	27.4	29.4	30.9	31.4	29.8	26.8	21.2	16.5	(32)
(33)		10%	WB	10.8	11.9	14.1	16.9	20.4	23.6	25.6	25.9	24.1	20.4	15.5	12.3	(33)
(34)			MCDWB	13.7	16.3	18.8	22.7	26.4	28.5	30.3	30.8	29.0	25.9	20.1	15.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.2	10.1	10.6	11.3	11.5	10.6	9.6	10.0	11.4	12.2	11.8	9.7	(35)
(36)			MCDBR	11.8	12.6	13.4	15.4	15.6	13.5	10.7	11.3	13.0	14.9	14.9	12.7	(36)
(37)			MCWBR	6.6	6.5	6.2	5.9	5.3	4.6	3.5	3.5	4.1	5.3	6.0	6.5	(37)
(38)		5% WB	MCDWB	8.9	10.4	10.5	12.2	12.3	10.2	9.4	9.8	10.9	11.3	10.8	9.1	(38)
(39)			MCWBR	5.6	5.9	5.7	5.5	4.7	3.9	3.1	3.1	3.7	4.9	5.6	5.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.374	0.395	0.430	0.482	0.465	0.434	0.445	0.455	0.419	0.415	0.383	0.368	(40)	
(41)		taud	2.277	2.215	2.126	2.018	2.127	2.256	2.244	2.201	2.297	2.264	2.299	2.316	(41)	
(42)		Ebn at Noon	793	823	829	805	826	850	837	820	831	792	776	772	(42)	
(43)		Edh at Noon	101	121	145	171	155	137	137	140	121	114	98	92	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.25	3.16	4.46	5.54	6.59	7.58	7.66	6.84	5.63	4.07	2.87	2.11	(44)	
(45)		RadStd	0.30	0.40	0.26	0.45	0.35	0.33	0.26	0.21	0.24	0.27	0.22	0.30	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	-2.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (11 neighbors)	N/A	N/A	-1.92	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page