

ISKENDERUN, Turkey

WMO: 173700

Lat: 36.5924N

Lon: 36.1582E

Elev: 13

StdP: 14.69

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	41.8	44.2	18.5	14.0	46.9	22.2	16.7	49.5	21.1	52.6	18.5	52.6	5.9	160	0.328

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	91.2	76.0	89.7	77.0	88.5	77.0	81.1	87.2	80.3	86.6	79.6	86.1	6.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.5	152.9	85.9	78.4	147.7	85.5	77.6	143.6	85.2	45.0	87.3	44.1	86.8	43.3	86.2	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.9	15.2	13.1	39.2	96.3	2.1	3.3	37.6	98.7	36.4	100.6	35.2	102.5	33.6	104.9		
			32.5	82.9	2.5	1.5	30.8	84.0	29.3	84.9	27.9	85.7	26.2	86.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	69.6	54.4	55.6	60.2	66.1	73.0	79.0	83.6	84.9	81.2	74.9	64.2	57.1	(6)
(7)		DBStd	11.64	4.68	5.10	4.86	4.99	4.32	3.06	1.94	1.97	3.36	5.13	5.36	4.74	(7)
(8)		HDD50	39	18	13	1	0	0	0	0	0	0	0	0	7	(8)
(9)		HDD65	1124	328	264	162	41	2	0	0	0	3	76	248	(9)	
(10)		CDD50	7192	155	169	318	482	712	871	1041	1083	936	773	427	225	(10)
(11)		CDD65	2803	0	1	14	73	249	421	576	618	486	311	52	2	(11)
(12)		CDH74	27398	0	0	46	280	1149	3682	6974	7910	5160	2110	86	1	(12)
(13)		CDH80	9410	0	0	4	62	216	847	2638	3501	1669	472	1	0	(13)
(14)	Wind	WSAvg	4.8	4.8	4.8	4.5	4.5	4.6	5.7	6.4	6.2	4.7	3.4	4.0	4.5	(14)
(15)	Precipitation	PrecAvg	30.2	3.6	3.3	3.7	2.6	1.8	1.4	0.3	0.6	1.3	3.2	3.0	4.2	(15)
(16)		PrecMax	52.0	9.5	7.1	7.4	5.5	5.9	5.1	1.4	3.4	4.5	7.5	7.3	17.6	(16)
(17)		PrecMin	18.9	0.3	0.1	0.5	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	8.1	2.5	1.8	1.8	1.4	1.3	1.4	0.3	0.8	1.1	1.9	2.0	3.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.9	69.2	79.3	86.2	90.3	92.1	91.8	93.5	91.8	92.2	79.1	71.1	(19)
(20)		MCWB	54.7	55.0	57.8	64.8	69.8	73.2	77.2	77.8	75.0	68.3	64.5	58.2	(20)	
(21)		2%	DB	64.4	66.8	73.8	80.9	85.0	88.0	89.9	91.2	89.3	87.3	76.4	67.7	(21)
(22)		MCWB	54.1	54.6	57.4	62.9	69.4	73.8	77.7	78.0	75.6	70.1	62.7	56.2	(22)	
(23)		5%	DB	62.8	65.0	70.1	76.9	81.9	85.9	88.7	89.7	87.8	84.4	74.3	65.6	(23)
(24)		MCWB	53.5	54.5	58.4	63.2	70.1	74.2	77.7	78.6	75.4	70.0	61.2	55.0	(24)	
(25)		10%	DB	61.1	63.1	67.3	73.4	79.4	84.3	87.6	88.6	86.3	82.3	72.1	63.9	(25)
(26)		MCWB	52.1	53.7	57.8	63.0	69.5	74.2	77.6	78.4	74.8	69.7	60.0	53.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.3	59.2	63.1	69.9	76.1	79.8	82.3	83.0	81.0	77.1	67.4	61.0	(27)
(28)		MCDWB	63.3	64.6	69.8	78.0	82.2	85.6	88.1	88.3	86.5	83.7	76.6	67.5	(28)	
(29)		2%	WB	56.6	57.3	61.2	67.4	73.8	78.3	80.8	81.6	79.4	74.7	64.7	58.5	(29)
(30)		MCDWB	62.1	63.5	68.2	75.2	80.4	84.2	86.6	87.9	85.7	82.3	73.6	64.9	(30)	
(31)		5%	WB	54.9	56.0	60.0	65.4	72.1	77.0	79.9	80.8	78.3	72.9	63.2	56.8	(31)
(32)		MCDWB	60.9	62.7	67.1	72.9	79.2	83.1	86.0	87.2	85.1	81.4	71.7	63.5	(32)	
(33)		10%	WB	53.4	54.7	58.7	63.9	70.5	75.8	79.2	80.0	77.0	71.3	61.6	55.4	(33)
(34)		MCDWB	59.4	61.6	65.9	71.2	77.7	82.5	85.6	86.7	84.7	80.3	70.0	62.5	(34)	
(35)	Mean Daily Temperature Range		MDBR	9.0	9.8	10.7	10.9	10.2	9.1	7.7	7.6	9.6	11.2	10.6	9.1	(35)
(36)		5% DB	MCDBR	10.1	11.0	14.2	16.3	14.6	11.5	9.0	8.8	10.1	13.0	12.0	10.7	(36)
(37)			MCWBR	6.6	7.5	8.0	9.0	9.3	8.9	6.7	5.9	7.1	9.1	8.4	7.2	(37)
(38)			MCDBR	9.0	9.6	11.5	12.4	11.4	9.0	7.4	7.5	8.4	10.4	10.4	9.4	(38)
(39)		5% WB	MCWBR	6.6	7.7	8.0	8.4	8.6	7.9	6.0	5.4	6.4	8.4	8.0	6.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.387	0.411	0.446	0.500	0.483	0.443	0.456	0.472	0.430	0.438	0.398	0.381	(40)	
(41)		taud	2.249	2.177	2.092	1.980	2.082	2.234	2.219	2.163	2.278	2.198	2.258	2.283	(41)	
(42)		Ebn at Noon	247	256	259	251	257	267	263	256	261	244	241	241	(42)	
(43)		Edh at Noon	33	40	48	56	52	44	45	46	39	39	33	30	(43)	
(44)	All-Sky Solar Radiation	RadAvg	698	980	1429	1807	2197	2506	2466	2199	1811	1303	916	662	(44)	
(45)		RadStd	95	142	93	140	97	69	58	57	60	84	80	104	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (11 neighbors)	N/A	N/A	-3.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page