

ISKENDERUN, Turkey

WMO: 173700

Lat: 36.5924N

Lon: 36.1582E

Elev: 4

StdP: 101.28

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.4	6.8	-7.5	2.0	8.3	-5.5	2.4	9.7	9.4	11.4	8.3	11.4	2.7	160	0.328

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.2	32.9	24.4	32.0	25.0	31.4	25.0	27.3	30.7	26.9	30.3	26.5	30.1	3.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	21.8	30.0	25.8	21.1	29.7	25.3	20.5	29.6	86.7	30.7	84.7	30.4	82.8	30.1	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	6.8	5.8	DB	4.0	35.7	1.2	1.9	3.1	37.0	2.4	38.1	1.8	39.2	0.9	40.5	(4)
(5)			WB	0.3	28.3	1.4	0.8	-0.7	28.9	-1.5	29.4	-2.3	29.9	-3.2	30.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.9	12.5	13.1	15.7	18.9	22.8	26.1	28.7	29.4	27.3	23.9	17.9	13.9	(6)	
	DBStd	6.47	2.60	2.83	2.70	2.77	2.40	1.70	1.08	1.10	1.87	2.85	2.98	2.63	(7)	
	HDD10.0	22	10	7	1	0	0	0	0	0	0	0	0	4	(8)	
	HDD18.3	624	182	147	90	23	1	0	0	0	0	2	42	138	(9)	
	CDD10.0	3996	86	94	177	268	396	484	578	602	520	429	237	125	(10)	
	CDD18.3	1557	0	1	8	41	138	234	320	343	270	173	29	1	(11)	
	CDH23.3	15221	0	0	26	156	638	2046	3874	4394	2867	1172	48	1	(12)	
(13)	CDH26.7	5228	0	0	2	34	120	471	1466	1945	927	262	1	0	(13)	
(14)	Wind	WSAvg	2.2	2.1	2.1	2.0	2.0	2.1	2.5	2.9	2.8	2.1	1.5	1.8	2.0	(14)
(15) Precipitation	PrecAvg	766	91	84	95	67	46	35	7	16	33	82	77	106	(15)	
	PrecMax	1322	242	181	187	140	149	129	35	87	114	191	186	448	(16)	
	PrecMin	480	8	2	13	2	3	0	0	0	0	1	1	0	(17)	
	PrecStd	205	63	46	46	36	34	36	8	21	27	47	51	81	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.4	20.7	26.3	30.1	32.4	33.4	33.2	34.1	33.2	33.4	26.2	21.7	(19)	
		MCWB	12.6	12.8	14.3	18.2	21.0	22.9	25.1	25.5	23.9	20.2	18.1	14.5	(20)	
	2%	DB	18.0	19.3	23.2	27.2	29.4	31.1	32.2	32.9	31.8	30.7	24.7	19.9	(21)	
		MCWB	12.3	12.6	14.1	17.1	20.8	23.2	25.4	25.5	24.2	21.2	17.0	13.4	(22)	
	5%	DB	17.1	18.3	21.2	25.0	27.7	30.0	31.5	32.1	31.0	29.1	23.5	18.6	(23)	
		MCWB	11.9	12.5	14.7	17.3	21.2	23.5	25.4	25.9	24.1	21.1	16.2	12.8	(24)	
	10%	DB	16.2	17.3	19.6	23.0	26.3	29.0	30.9	31.5	30.2	27.9	22.3	17.7	(25)	
		MCWB	11.2	12.1	14.3	17.2	20.9	23.4	25.3	25.8	23.8	20.9	15.6	12.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.6	15.1	17.3	21.1	24.5	26.6	27.9	28.3	27.2	25.1	19.7	16.1	(27)	
		MCDB	17.4	18.1	21.0	25.5	27.9	29.8	31.2	31.3	30.3	28.7	24.8	19.7	(28)	
	2%	WB	13.6	14.1	16.2	19.7	23.2	25.7	27.1	27.6	26.4	23.7	18.2	14.7	(29)	
		MCDB	16.7	17.5	20.1	24.0	26.9	29.0	30.3	31.0	29.8	28.0	23.1	18.3	(30)	
	5%	WB	12.7	13.3	15.5	18.6	22.3	25.0	26.6	27.1	25.7	22.7	17.3	13.8	(31)	
		MCDB	16.1	17.1	19.5	22.7	26.2	28.4	30.0	30.7	29.5	27.4	22.0	17.5	(32)	
	10%	WB	11.9	12.6	14.8	17.7	21.4	24.3	26.2	26.7	25.0	21.8	16.5	13.0	(33)	
		MCDB	15.2	16.4	18.9	21.8	25.4	28.0	29.8	30.4	29.3	26.9	21.1	16.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.4	6.0	6.1	5.7	5.0	4.3	4.2	5.3	6.2	5.9	5.1	(35)	
		MCDBR	5.6	6.1	7.9	9.0	8.1	6.4	5.0	4.9	5.6	7.2	6.6	6.0	(36)	
		MCWBR	3.7	4.1	4.4	5.0	5.2	4.9	3.7	3.3	3.9	5.0	4.7	4.0	(37)	
	5% WB	MCDBR	5.0	5.3	6.4	6.9	6.3	5.0	4.1	4.2	4.6	5.8	5.8	5.2	(38)	
		MCWBR	3.7	4.3	4.4	4.7	4.8	4.4	3.4	3.0	3.5	4.7	4.4	3.8	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.387	0.411	0.446	0.500	0.483	0.443	0.456	0.472	0.430	0.438	0.398	0.381	(40)	
	taud		2.249	2.177	2.092	1.980	2.082	2.234	2.219	2.163	2.278	2.198	2.258	2.283	(41)	
	Ebn at Noon		780	808	815	791	811	842	828	807	823	769	760	759	(42)	
	Edh at Noon		105	127	150	177	163	140	141	146	124	123	103	96	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.20	3.09	4.51	5.70	6.93	7.90	7.77	6.93	5.71	4.11	2.89	2.09	(44)	
	RadStd		0.30	0.45	0.29	0.44	0.31	0.22	0.18	0.18	0.19	0.26	0.25	0.33	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	N/A	N/A	-1.92	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page