

HATAY, Turkey

WMO: 173725

Lat: 36.365N

Lon: 36.284E

Elev: 79

StdP: 100.38

Time Zone: 3.00 (E03)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.0	0.9	-8.2	1.9	6.7	-5.9	2.3	7.3	11.4	5.4	10.3	6.2	1.3	160	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.5	36.1	21.3	34.9	21.9	33.9	22.9	25.7	32.4	25.1	31.7	24.7	31.1	6.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	18.9	29.6	23.1	18.1	29.0	22.9	17.8	28.8	79.1	32.6	77.0	31.5	75.2	31.6	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.3	11.3	10.4	-3.2	40.1	2.3	2.5	-4.9	41.9	-6.2	43.4	-7.5	44.8	-9.1	46.7	
			DB												
			WB	-4.1	26.6	2.4	0.6	-5.8	27.0	-7.2	27.3	-8.5	27.6	-10.2	28.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.2	8.2	10.8	14.2	17.9	22.6	26.7	29.3	29.8	26.8	20.7	14.1	9.4
	DBStd	7.95	2.62	2.77	2.26	2.71	2.68	2.13	1.25	1.06	2.34	2.88	3.23	2.74
	HDD10.0	141	67	22	2	0	0	0	0	0	0	7	43	
	HDD18.3	1113	316	211	128	40	1	0	0	0	11	129	278	
	CDD10.0	3516	9	45	133	237	390	502	598	614	503	331	130	23
	CDD18.3	1447	0	0	1	27	133	252	339	356	253	84	3	0
	CDH23.3	16363	0	3	22	343	1168	2545	4138	4475	2784	833	53	0
	CDH26.7	7206	0	0	1	98	463	1108	1952	2141	1177	266	2	0
Wind	WSAvg	4.4	2.9	2.8	3.6	4.1	5.1	7.0	7.7	7.3	5.4	2.8	1.9	2.3
Precipitation	PrecAvg	771	113	115	90	69	48	20	9	11	39	56	83	119
	PrecMax	1092	235	208	224	154	103	69	24	28	120	147	181	276
	PrecMin	510	40	46	15	22	7	0	1	0	1	7	13	17
	PrecStd	127	55	45	47	33	28	16	6	9	29	32	43	64
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.9	23.1	25.8	32.8	37.0	39.1	37.9	37.8	37.1	33.2	26.9	19.9
		MCWB	11.9	13.9	14.9	16.6	19.5	20.4	23.8	23.3	20.4	18.2	15.5	11.4
	2%	DB	15.1	20.0	23.1	29.2	34.0	35.8	35.2	35.0	34.2	31.2	25.0	17.1
		MCWB	10.7	13.1	14.0	16.3	18.9	21.0	22.3	23.2	22.5	18.8	14.1	12.0
	5%	DB	14.0	18.0	21.8	27.0	31.1	33.2	34.1	34.1	33.0	29.8	23.1	15.2
		MCWB	10.2	12.2	14.1	15.7	18.5	21.0	23.0	23.8	22.6	19.0	14.0	11.3
	10%	DB	12.2	16.2	20.0	25.0	29.0	31.8	33.1	33.2	32.0	28.0	21.2	14.1
		MCWB	9.2	11.5	13.6	15.6	18.3	21.4	23.5	24.1	22.5	18.1	13.6	11.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	15.4	16.2	19.0	21.6	24.7	26.2	26.7	25.5	22.4	17.3	14.3
		MCDB	15.7	21.2	21.9	26.7	30.0	31.6	33.2	34.0	31.9	28.6	22.9	16.2
	2%	WB	11.6	13.8	15.4	17.8	20.6	23.8	25.4	26.0	24.7	21.3	16.3	13.2
		MCDB	14.2	18.3	20.9	24.7	28.7	30.7	32.3	32.7	30.9	27.3	21.6	15.2
	5%	WB	10.7	12.9	14.7	17.1	19.8	23.2	24.9	25.4	24.2	20.7	15.4	12.6
		MCDB	13.0	16.8	19.9	24.6	27.7	29.8	31.6	32.0	30.3	26.5	20.6	14.7
	10%	WB	9.9	11.9	13.9	16.3	19.2	22.6	24.4	25.0	23.6	19.8	14.4	11.6
		MCDB	11.6	15.6	18.8	22.8	26.6	28.9	31.0	31.4	29.6	25.5	19.4	13.8
Mean Daily Temperature Range	5% DB	MDBR	7.3	10.1	10.9	12.5	12.0	10.2	8.7	8.5	11.0	14.0	13.7	8.7
		MCDBR	10.5	13.8	13.9	17.5	16.6	13.2	10.0	9.2	12.2	16.1	16.3	11.6
		MCWBR	6.4	7.6	6.8	7.3	5.8	4.5	4.2	3.9	4.9	6.7	7.6	7.2
	5% WB	MCDBR	8.8	11.5	12.0	14.0	12.9	10.2	8.9	8.6	10.3	13.2	13.1	8.6
MCWBR		5.8	6.8	6.3	6.3	5.3	4.1	3.9	3.7	4.4	6.2	7.1	5.8	
Clear-Sky Solar Irradiance	taub	0.381	0.405	0.437	0.491	0.476	0.435	0.447	0.462	0.423	0.433	0.393	0.376	
	taud	2.260	2.188	2.107	1.991	2.086	2.240	2.227	2.171	2.281	2.198	2.263	2.286	
	Ebn at Noon	789	816	824	799	818	850	836	815	830	776	768	766	
	Edh at Noon	104	125	148	176	162	139	140	145	123	123	103	96	
All-Sky Solar Radiation	RadAvg	2.20	3.09	4.52	5.73	6.98	7.94	7.78	6.95	5.73	4.13	2.90	2.09	
	RadStd	0.29	0.45	0.29	0.43	0.30	0.19	0.17	0.17	0.18	0.26	0.25	0.33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (10 neighbors)	N/A	N/A	-1.92	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page