

FINIKE, Turkey

WMO: 173750

Lat: 36.3025N

Lon: 30.1459E

Elev: 7

StdP: 14.69

Time Zone: 3.00 (E03)

Period: 98-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 41.7	(c) 43.7	(d) 13.8	(e) 11.1	(f) 46.8	(g) 20.8	(h) 15.6	(i) 49.3	(j) 12.2	(k) 56.9	(l) 10.9	(m) 56.3	(n) 4.3	(o) 350	(p) 0.318

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 17.5	(c) 98.9	(d) 71.0	(e) 96.3	(f) 71.1	(g) 93.8	(h) 71.9	(i) 80.6	(j) 89.2	(k) 79.2	(l) 88.3	(m) 78.0	(n) 87.4	(o) 5.9	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.1	145.9	87.5	76.5	138.2	86.7	74.9	130.8	85.7	44.4	89.2	42.9	88.0	41.5	87.7	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.8	(b) 9.9	(c) 8.5	(e) 37.8	(f) 104.4	(g) 4.0	(h) 2.5	(i) 34.9	(j) 106.2	(k) 32.5	(l) 107.6	(m) 30.3	(n) 109.0	(o) 27.3	(p) 110.9		
(a) 31.1	(b) 82.3	(c) 2.9	(e) 31.1	(f) 82.3	(g) 2.9	(h) 1.4	(i) 29.0	(j) 83.3	(k) 27.3	(l) 84.1	(m) 25.6	(n) 84.9	(o) 23.5	(p) 85.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.9	54.0	54.3	58.0	63.0	70.0	78.1	83.2	84.6	78.2	70.8	62.4	56.6
	DBStd	11.47	3.59	3.80	4.02	3.83	4.04	4.76	3.25	3.33	3.32	4.04	4.19	4.24
	HDD50	25	10	9	2	0	0	0	0	0	0	0	0	4
	HDD65	1312	342	299	220	81	5	0	0	0	0	6	97	262
	CDD50	6542	134	130	249	391	620	843	1030	1073	847	646	371	208
	CDD65	2353	0	0	3	22	160	393	565	608	397	186	18	1
	CDH74	25169	0	0	11	119	934	4034	7212	8098	3711	989	58	3
CDH80	11300	0	0	0	25	184	1659	3598	4256	1409	164	5	0	
Wind	WSAvg	3.2	3.0	3.3	3.3	3.3	3.2	3.3	3.3	3.3	3.3	3.0	3.0	3.2
Precipitation	PrecAvg	35.2	6.9	5.0	2.8	1.9	1.0	0.5	0.2	0.2	0.6	2.6	4.5	8.0
	PrecMax	54.4	22.1	9.7	6.3	4.4	3.9	2.6	0.9	1.3	4.8	12.4	21.2	17.9
	PrecMin	21.3	0.2	0.6	0.0	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.4	0.8
	PrecStd	9.4	4.6	2.2	1.7	1.2	0.8	0.6	0.2	0.3	1.1	2.5	3.9	4.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.3	68.7	75.6	82.7	89.7	99.4	101.6	103.2	96.4	87.1	79.6	72.0
		MCWB	56.3	55.9	58.3	61.1	65.6	68.7	72.1	71.5	69.4	66.4	63.9	58.5
	2%	DB	64.5	65.7	71.1	76.9	84.6	95.3	98.0	99.7	91.6	83.9	75.0	68.6
		MCWB	55.0	55.5	57.7	61.1	66.9	68.3	71.4	71.2	72.0	67.9	62.7	57.6
	5%	DB	62.7	63.9	68.3	73.7	81.5	92.5	95.4	97.0	89.0	81.5	72.4	66.1
		MCWB	54.1	54.9	57.6	60.5	66.3	68.8	71.8	71.8	72.6	67.7	61.7	56.4
	10%	DB	60.9	62.1	66.4	71.3	78.9	88.5	93.0	94.2	86.9	79.4	70.3	63.7
		MCWB	53.0	54.0	57.0	59.9	66.1	69.3	72.4	73.1	72.6	67.0	60.2	55.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.8	59.3	62.3	65.3	72.0	77.4	81.4	82.9	79.0	73.4	67.7	62.3
		MCDB	64.4	64.7	69.1	75.6	80.7	85.3	89.9	90.5	88.6	81.4	75.3	68.3
	2%	WB	56.8	57.5	60.4	63.8	70.5	75.9	80.0	81.4	76.9	71.5	64.8	59.5
		MCDB	62.5	63.5	67.7	72.4	78.9	84.2	88.6	89.5	86.6	79.8	72.4	65.6
	5%	WB	55.3	56.1	59.1	62.7	69.1	74.6	78.7	80.1	75.4	69.8	63.1	57.9
		MCDB	61.0	62.4	66.7	70.6	77.6	83.4	87.8	88.9	85.5	78.7	70.8	64.3
	10%	WB	53.9	54.6	57.7	61.4	67.8	73.1	77.6	78.8	73.9	68.0	61.4	56.2
		MCDB	59.2	61.0	65.2	69.4	76.5	82.4	87.0	88.2	84.6	77.2	68.5	62.3
Mean Daily Temperature Range	5% DB	MDBR	13.1	13.4	15.0	15.6	16.5	18.1	18.0	17.5	17.2	16.3	14.8	13.2
		MCDBR	15.3	15.8	17.2	19.2	19.8	22.9	22.5	21.7	20.2	18.5	17.1	16.0
		MCWBR	10.5	10.8	10.8	10.7	10.7	10.5	11.2	10.9	12.4	11.9	11.7	10.8
	5% WB	MCDBR	13.7	14.2	15.9	16.8	17.1	18.1	17.4	16.3	17.2	16.6	15.6	14.6
		MCWBR	10.1	10.7	10.9	10.6	10.8	11.7	11.7	11.7	12.3	12.1	11.2	10.6
Clear-Sky Solar Irradiance	taub	0.353	0.384	0.423	0.462	0.451	0.416	0.427	0.444	0.411	0.400	0.370	0.356	
	taud	2.415	2.303	2.185	2.104	2.200	2.346	2.320	2.262	2.350	2.354	2.400	2.427	
	Ebn at Noon	264	267	266	262	266	275	271	264	267	259	255	254	
	Edh at Noon	29	36	43	50	46	40	41	42	36	33	29	27	
All-Sky Solar Radiation	RadAvg	772	1044	1491	1899	2204	2507	2510	2236	1859	1344	954	714	
	RadStd	83	89	87	119	93	83	51	46	76	74	66	74	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	N/A	N/A	N/A	+0.67	N/A	N/A	N/A	-112	N/A	N/A

Nomenclature: See separate page