

LEFKE, Cyprus

WMO: 175010

Lat: 35.112N

Lon: 32.850E

Elev: 423

StdP: 14.47

Time Zone: 2.00 (E02)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 44.0	(c) 46.5	(d) 24.6	(e) 19.0	(f) 50.1	(g) 27.8	(h) 22.0	(i) 52.9	(j) 32.9	(k) 57.8	(l) 28.4	(m) 58.7	(n) 8.5	(o) 180	(p) 0.419

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 9.1	(c) 90.5	(d) 69.3	(e) 88.0	(f) 70.8	(g) 86.3	(h) 72.2	(i) 79.2	(j) 84.7	(k) 78.2	(l) 84.2	(m) 77.2	(n) 83.7	(o) 11.6	(p) 320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.5	145.3	84.3	76.2	138.9	83.8	75.0	133.2	83.2	43.3	84.6	42.1	84.4	41.1	83.7	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
32.8	27.2	22.9	40.1	97.7	4.2	2.2	37.1	99.3	34.7	100.6	32.3	101.8	29.3	103.5		
			35.0	81.3	3.6	1.8	32.4	82.6	30.3	83.6	28.3	84.6	25.7	86.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.3	55.6	56.2	58.9	63.4	69.5	76.3	81.2	82.2	77.8	72.3	65.9	59.0
	DBStd	10.00	4.00	3.93	3.63	3.77	4.15	4.25	3.17	2.45	2.65	3.38	3.74	4.01
	HDD50	19	10	5	1	0	0	0	0	0	0	0	0	3
	HDD65	1032	291	247	192	74	6	0	0	0	0	1	34	187
	CDD50	6685	184	178	277	403	604	790	967	997	834	692	476	283
	CDD65	2223	0	0	3	27	145	340	502	532	384	228	60	2
	CDH74	18771	0	0	15	56	373	2354	5537	6279	3194	884	78	1
	CDH80	5051	0	0	2	8	57	473	1687	2176	571	73	4	0
(14) Wind	WSAvg	8.3	7.5	7.9	8.7	8.2	8.5	10.2	9.7	9.1	8.4	7.3	6.9	6.9
(15) Precipitation	PrecAvg	21.4	4.1	3.6	2.0	1.3	1.0	0.4	0.2	0.2	0.3	1.2	2.4	4.5
	PrecMax	37.9	12.6	7.0	4.9	3.6	2.9	2.7	0.9	1.0	1.5	4.9	8.9	13.1
	PrecMin	11.9	0.6	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4
	PrecStd	5.8	2.7	1.5	1.1	0.8	0.7	0.6	0.3	0.3	0.4	1.1	1.9	3.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.9	70.0	75.8	80.7	86.4	92.3	95.8	94.7	88.0	85.5	79.2	71.8
		MCWB	56.5	57.1	57.5	59.9	64.0	65.9	67.7	67.3	68.8	65.5	62.2	58.6
	2%	DB	64.6	66.1	69.4	75.0	80.5	87.5	90.3	90.4	85.5	81.8	76.0	69.0
		MCWB	54.9	56.5	57.0	58.5	62.5	65.9	69.6	70.8	70.9	66.3	62.7	58.1
	5%	DB	63.0	64.2	66.6	71.9	77.4	84.8	87.6	88.0	84.1	79.6	74.0	67.0
		MCWB	54.0	55.4	56.5	59.4	64.2	68.3	71.3	72.7	72.0	66.8	61.7	56.8
	10%	DB	61.8	62.7	64.7	69.6	75.5	82.4	85.7	86.4	82.9	78.1	72.1	65.4
		MCWB	53.3	54.5	55.9	59.3	64.6	69.7	72.7	73.9	71.6	66.5	60.7	55.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.6	60.2	61.2	65.7	71.6	78.1	80.0	81.4	78.8	72.7	67.5	62.0
		MCDB	64.6	66.0	67.9	71.2	76.5	83.1	84.7	85.8	84.2	79.6	74.8	69.0
	2%	WB	56.6	58.3	59.8	63.8	69.8	75.6	78.9	79.8	76.6	70.9	65.2	59.7
		MCDB	63.0	64.7	66.3	69.2	74.9	81.0	84.3	85.2	82.8	78.4	73.6	66.9
	5%	WB	55.1	56.5	58.5	62.6	68.4	74.4	77.9	78.6	75.1	69.5	63.3	58.1
		MCDB	61.6	63.1	65.0	69.1	74.2	80.3	83.8	84.7	82.1	77.7	72.2	65.6
	10%	WB	53.9	55.0	57.2	61.2	66.8	73.0	77.0	77.6	73.8	68.2	61.6	56.7
		MCDB	60.7	61.9	64.0	68.1	73.2	79.5	83.3	84.3	81.6	77.0	70.9	64.2
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	10.5	11.1	11.1	10.2	9.6	8.9	9.1	9.8	10.5	11.2	10.5
		MCDBR	11.2	12.5	13.7	14.6	13.2	13.5	11.7	11.4	11.1	11.7	13.0	11.9
		MCWBR	7.7	9.3	9.9	10.9	12.0	13.4	15.3	15.6	13.8	11.6	10.5	9.0
	5% WB	MCDBR	10.7	11.9	12.2	11.2	9.9	9.4	8.1	8.6	9.1	9.9	11.6	11.2
		MCWBR	7.9	9.7	10.7	12.3	12.2	13.8	15.0	15.0	14.8	12.1	10.9	9.2
(40) Clear-Sky Solar Irradiance	taub		0.361	0.388	0.419	0.457	0.447	0.406	0.420	0.431	0.404	0.400	0.373	0.357
	taud		2.378	2.278	2.179	2.090	2.178	2.346	2.312	2.278	2.357	2.350	2.387	2.417
	Ebn at Noon		263	268	269	264	268	278	273	268	271	261	257	257
	Edh at Noon		30	37	44	51	47	40	41	42	36	34	30	27
(44) All-Sky Solar Radiation	RadAvg		793	1090	1548	1936	2244	2497	2425	2173	1851	1367	974	736
	RadStd		60	96	77	99	112	50	43	33	54	61	55	64

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-144	+292	+144

Nomenclature: See separate page