

LEFKE, Cyprus

WMO: 175010

Lat: 35.112N

Lon: 32.850E

Elev: 129

StdP: 99.78

Time Zone: 2.00 (E02)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.7	8.1	-4.1	2.7	10.1	-2.4	3.1	11.6	14.7	14.3	12.7	14.8	3.8	180	0.419

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.1	32.5	20.7	31.1	21.5	30.2	22.3	26.2	29.3	25.7	29.0	25.1	28.7	5.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.3	20.8	29.1	24.5	19.8	28.8	23.9	19.0	28.5	82.7	29.2	80.1	29.1	77.7	28.7	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.7	12.2	10.2	DB	4.5	36.5	2.3	1.2	2.8	37.4	1.5	38.1	0.2	38.8	-1.5	39.7	(4)
			WB	1.7	27.4	2.0	1.0	0.2	28.1	-0.9	28.7	-2.1	29.2	-3.5	30.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	13.1	13.4	14.9	17.5	20.8	24.6	27.3	27.9	25.4	22.4	18.8	15.0	(6)
		DBStd	5.56	2.22	2.18	2.01	2.09	2.30	2.36	1.76	1.36	1.47	1.88	2.08	2.23	(7)
		HDD10.0	11	6	3	1	0	0	0	0	0	0	0	0	2	(8)
		HDD18.3	573	162	137	107	41	3	0	0	0	0	1	19	104	(9)
		CDD10.0	3714	102	99	154	224	336	439	537	554	463	384	264	157	(10)
		CDD18.3	1235	0	0	2	15	81	189	279	296	213	127	33	1	(11)
		CDH23.3	10428	0	0	8	31	207	1308	3076	3488	1774	491	43	1	(12)
		CDH26.7	2806	0	0	1	4	32	263	937	1209	317	41	2	0	(13)
(14)	Wind	WSAvg	3.7	3.4	3.5	3.9	3.7	3.8	4.6	4.3	4.1	3.7	3.3	3.1	3.1	(14)
(15)	Precipitation	PrecAvg	543	104	91	52	32	25	11	5	8	30	62	115		(15)
		PrecMax	963	320	177	124	92	73	68	24	25	37	125	225	333	(16)
		PrecMin	302	14	23	0	1	1	0	0	0	1	0	11		(17)
		PrecStd	147	69	39	29	21	18	16	7	11	27	47	80		(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	19.4	21.1	24.3	27.0	30.2	33.5	35.4	34.8	31.1	29.7	26.2	22.1		(19)
		0.4% MCWB	13.6	14.0	14.2	15.5	17.8	18.8	19.8	19.6	20.4	18.6	16.8	14.8		(20)
		2% DB	18.1	19.0	20.8	23.9	26.9	30.8	32.4	32.4	29.7	27.7	24.5	20.6		(21)
		2% MCWB	12.7	13.6	13.9	14.7	17.0	18.8	20.9	21.6	21.6	19.1	17.0	14.5		(22)
		5% DB	17.2	17.9	19.2	22.2	25.2	29.3	30.9	31.1	28.9	26.4	23.3	19.4		(23)
		5% MCWB	12.2	13.0	13.6	15.2	17.9	20.2	21.8	22.6	22.2	19.3	16.5	13.8		(24)
		10% DB	16.5	17.1	18.2	20.9	24.2	28.0	29.8	30.2	28.3	25.6	22.3	18.5		(25)
		10% MCWB	11.8	12.5	13.3	15.2	18.1	20.9	22.6	23.3	22.0	19.2	15.9	13.2		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	14.8	15.6	16.2	18.7	22.0	25.6	26.6	27.4	26.0	22.6	19.7	16.7		(27)
		0.4% MCDB	18.1	18.9	19.9	21.8	24.7	28.4	29.3	29.9	29.0	26.4	23.8	20.5		(28)
		2% WB	13.7	14.6	15.5	17.7	21.0	24.2	26.1	26.5	24.8	21.6	18.4	15.4		(29)
		2% MCDB	17.2	18.2	19.1	20.7	23.8	27.2	29.0	29.5	28.2	25.8	23.1	19.4		(30)
		5% WB	12.9	13.6	14.7	17.0	20.2	23.6	25.5	25.9	24.0	20.9	17.4	14.5		(31)
		5% MCDB	16.5	17.3	18.4	20.6	23.4	26.8	28.8	29.3	27.8	25.4	22.3	18.7		(32)
		10% WB	12.2	12.8	14.0	16.2	19.4	22.8	25.0	25.3	23.2	20.1	16.4	13.7		(33)
		10% MCDB	16.0	16.6	17.8	20.1	22.9	26.4	28.5	29.0	27.5	25.0	21.6	17.9		(34)
(35)	Mean Daily Temperature Range	MDBR	5.6	5.8	6.2	6.1	5.7	5.4	5.0	5.1	5.4	5.8	6.2	5.8		(35)
		5% DB MCDBR	6.2	6.9	7.6	8.1	7.4	7.5	6.5	6.3	6.1	6.5	7.2	6.6		(36)
		5% WB MCWBR	4.3	5.1	5.5	6.1	6.7	7.5	8.5	8.7	7.7	6.4	5.8	5.0		(37)
		5% WB MCWBR	5.9	6.6	6.8	6.2	5.5	5.2	4.5	4.8	5.0	5.5	6.4	6.2		(38)
(40)	Clear-Sky Solar Irradiance	taub	0.361	0.388	0.419	0.457	0.447	0.406	0.420	0.431	0.404	0.400	0.373	0.357		(40)
		taud	2.378	2.278	2.179	2.090	2.178	2.346	2.312	2.278	2.357	2.350	2.387	2.417		(41)
		Ebn at Noon	829	845	848	832	844	876	861	846	854	823	809	810		(42)
		Edh at Noon	95	116	139	160	149	125	129	131	115	107	93	86		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.50	3.44	4.88	6.10	7.08	7.87	7.65	6.85	5.83	4.31	3.07	2.32		(44)
		RadStd	0.19	0.30	0.24	0.31	0.35	0.16	0.13	0.10	0.17	0.19	0.17	0.20		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-80	+162	+80

Nomenclature: See separate page