

AKDENIZ, Cyprus

WMO: 175050

Lat: 35.300N

Lon: 32.967E

Elev: 292

StdP: 14.54

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 41.2	(c) 44.1	(d) 24.1	(e) 18.4	(f) 46.8	(g) 28.0	(h) 22.1	(i) 50.4	(j) 27.3	(k) 54.9	(l) 23.4	(m) 54.2	(n) 8.8	(o) 110	(p) 0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 16.1	(c) 97.9	(d) 67.5	(e) 94.6	(f) 69.0	(g) 91.1	(h) 71.4	(i) 79.0	(j) 87.0	(k) 78.1	(l) 86.1	(m) 77.3	(n) 85.2	(o) 10.4	(p) 20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.8	141.0	84.2	75.7	135.7	83.8	74.7	131.4	83.4	42.9	86.9	42.0	86.3	41.0	85.2	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 22.9	(b) 19.8	(c) 17.1	(e) 36.6	(f) 103.4	(g) 3.9	(h) 2.5	(i) 33.8	(j) 105.2	(k) 31.5	(l) 106.7	(m) 29.3	(n) 108.1	(o) 26.4	(p) 109.9		
(a) 22.9	(b) 19.8	(c) 17.1	(e) 32.5	(f) 80.9	(g) 3.3	(h) 1.6	(i) 30.1	(j) 82.1	(k) 28.2	(l) 83.0	(m) 26.4	(n) 83.9	(o) 24.0	(p) 85.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.1	54.0	55.1	58.1	63.8	70.7	77.3	82.3	83.2	78.3	72.0	64.6	57.2
	DBStd	10.98	4.06	4.21	3.94	4.14	4.63	4.56	3.55	2.85	2.96	3.72	3.84	4.42
	HDD50	32	17	8	2	0	0	0	0	0	0	0	0	5
	HDD65	1207	342	277	217	72	4	0	0	0	0	1	51	243
	CDD50	6649	140	152	253	413	642	820	1001	1029	850	683	437	229
	CDD65	2350	0	1	3	35	182	370	536	564	400	220	38	1
	CDH74	22570	0	4	13	272	1084	3188	6159	6810	3651	1263	119	7
	CDH80	8493	0	0	1	55	330	1149	2608	2974	1122	246	7	1
(14) Wind	WSAvg	7.3	7.5	7.8	8.0	7.4	7.3	7.6	7.2	7.0	7.5	6.7	6.7	7.2
(15) Precipitation	PrecAvg	21.4	4.1	3.6	2.0	1.3	1.0	0.4	0.2	0.2	0.3	1.2	2.4	4.5
	PrecMax	37.9	12.6	7.0	4.9	3.6	2.9	2.7	0.9	1.0	1.5	4.9	8.9	13.1
	PrecMin	11.9	0.6	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4
	PrecStd	5.8	2.7	1.5	1.1	0.8	0.7	0.6	0.3	0.3	0.4	1.1	1.9	3.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.1	72.4	75.3	86.5	91.6	100.8	101.6	100.8	96.1	90.1	80.7	73.0
		MCWB	56.4	58.9	58.9	60.9	64.5	68.1	67.3	67.8	66.9	64.1	63.5	58.6
	2%	DB	63.9	67.3	71.5	81.1	87.8	95.2	97.9	97.5	90.3	85.4	77.2	68.7
		MCWB	55.2	57.5	58.4	59.7	64.4	67.2	67.2	68.2	70.6	66.1	62.7	58.9
	5%	DB	62.5	64.6	68.3	77.2	83.4	90.3	94.1	93.9	87.3	82.2	74.6	66.5
		MCWB	54.5	56.3	57.3	59.6	64.1	67.9	70.0	71.0	72.7	67.1	62.2	57.6
	10%	DB	61.0	62.7	65.9	73.5	79.8	85.7	90.3	90.0	85.4	80.1	72.5	64.7
		MCWB	53.7	55.1	56.9	60.1	64.6	70.1	73.2	75.2	72.9	66.7	61.1	56.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.8	61.0	62.1	65.7	71.1	76.8	79.7	80.8	78.3	72.8	67.8	62.7
		MCDB	63.4	68.9	70.3	74.8	80.8	83.6	87.4	88.7	86.8	82.4	76.5	69.4
	2%	WB	56.5	58.8	60.6	64.1	69.3	75.3	78.6	79.5	76.6	71.0	65.6	60.4
		MCDB	62.4	65.7	68.1	73.1	78.1	82.8	86.6	87.4	84.9	79.4	73.3	66.7
	5%	WB	55.4	57.1	59.2	62.9	68.2	74.2	77.7	78.6	75.6	70.0	64.0	58.9
		MCDB	61.3	63.3	65.9	71.1	76.7	81.8	85.7	86.5	83.8	78.6	71.8	64.7
	10%	WB	54.2	55.7	57.9	61.7	67.0	72.9	76.8	77.8	74.6	68.9	62.5	57.3
		MCDB	60.1	62.2	64.3	69.9	75.4	80.7	84.8	85.7	82.8	77.4	70.7	63.5
(35) Mean Daily Temperature Range	5% DB	MDBR	12.8	13.8	15.0	17.5	16.5	16.1	16.1	16.1	15.3	16.2	15.2	13.3
		MCDBR	14.1	16.0	18.8	24.1	22.9	23.6	22.6	22.4	18.2	19.0	17.1	15.0
		MCWBR	8.8	10.0	11.1	11.9	11.1	10.8	11.6	11.6	9.8	9.6	9.9	9.0
	5% WB	MCDBR	13.1	15.5	16.3	19.5	18.7	17.9	17.3	16.0	16.3	16.4	15.8	13.9
		MCWBR	8.6	10.0	10.7	10.9	10.4	9.8	10.1	9.6	9.7	9.3	9.9	9.2
(40) Clear-Sky Solar Irradiance	taub		0.363	0.388	0.419	0.459	0.449	0.409	0.425	0.436	0.407	0.402	0.376	0.360
	taud		2.383	2.291	2.198	2.102	2.193	2.357	2.322	2.287	2.369	2.358	2.388	2.414
	Ebn at Noon		262	268	269	263	267	277	272	267	270	260	255	255
	Edh at Noon		30	36	43	50	46	39	41	41	36	34	30	27
(44) All-Sky Solar Radiation	RadAvg		778	1074	1531	1921	2227	2486	2416	2161	1836	1350	961	720
	RadStd		62	95	80	97	111	51	45	34	55	63	57	64

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-144	+292	+144

Nomenclature: See separate page