

GIRNE, Cyprus

WMO: 175100

Lat: 35.350N

Lon: 33.333E

Elev: 33

StdP: 14.68

Time Zone: 2.00 (EUE)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	45.1	47.8	26.0	20.0	48.6	29.2	23.3	51.7	24.1	54.2	22.2	54.9	7.7	0	0.334

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.9	93.6	72.9	91.5	75.6	90.0	76.0	80.5	89.1	79.3	88.4	78.3	87.7	2.0	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.9	145.0	87.7	76.4	137.9	87.3	75.2	132.2	86.9	44.2	89.4	43.0	88.9	41.9	87.7	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.7	19.3	16.2	DB	39.9	98.4	5.1	2.1	36.2	99.9	33.3	101.2	30.4	102.4	26.7	103.9
			WB	35.8	83.4	3.3	1.9	33.4	84.8	31.4	85.9	29.5	87.0	27.1	88.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.0	56.2	57.2	60.1	64.9	71.2	78.6	83.9	85.2	80.7	74.6	67.2	59.3	(6)
	DBStd	10.68	4.18	3.65	3.10	2.98	3.54	3.67	2.71	2.01	2.55	3.09	3.50	4.01	(7)
	HDD50	16	10	3	1	0	0	0	0	0	0	0	0	2	(8)
	HDD65	877	273	218	153	36	1	0	0	0	0	0	19	177	(9)
	CDD50	7322	202	205	315	448	657	859	1052	1092	922	762	517	291	(10)
	CDD65	2709	0	0	3	34	193	409	587	627	472	297	86	1	(11)
	CDH74	26785	0	0	4	55	764	3766	7368	8263	4821	1626	118	0	(12)
	CDH80	10176	0	0	0	4	74	1084	3243	3934	1604	232	1	0	(13)
(14) Wind	WSAvg	4.6	5.0	5.3	5.5	4.4	4.3	5.3	4.6	4.1	4.9	3.4	3.6	4.8	(14)
(15) Precipitation	PrecAvg	16.0	3.0	2.5	1.4	0.9	1.1	0.4	0.2	0.1	0.3	1.0	1.9	3.3	(15)
	PrecMax	24.9	9.3	6.3	4.5	2.6	3.1	1.9	1.1	0.5	1.5	3.4	7.0	8.8	(16)
	PrecMin	7.9	0.8	0.6	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.1	0.0	0.5	(17)
	PrecStd	4.2	1.9	1.5	0.9	0.6	0.8	0.5	0.3	0.1	0.4	0.8	1.5	2.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.2	68.3	71.9	79.0	84.5	94.3	96.8	96.9	90.7	86.5	78.9	70.8	(19)
		MCWB	56.9	59.4	58.9	61.7	67.3	69.3	68.8	72.2	75.1	69.2	67.2	60.7	(20)
	2%	DB	65.1	66.3	69.0	75.4	81.9	89.9	93.8	93.7	89.1	84.1	76.9	68.8	(21)
		MCWB	56.4	58.5	59.3	63.9	67.9	72.2	71.1	74.4	75.3	70.4	66.4	59.7	(22)
	5%	DB	63.9	64.8	67.6	73.3	79.9	87.5	90.9	92.0	88.0	82.5	75.3	67.3	(23)
		MCWB	55.6	57.2	58.9	63.3	67.8	73.1	75.0	76.3	74.8	69.7	64.4	58.3	(24)
	10%	DB	62.4	63.5	66.4	71.6	78.0	85.5	89.5	90.6	86.9	81.1	73.6	65.8	(25)
		MCWB	54.4	56.1	58.0	62.2	67.3	73.0	75.9	76.9	74.0	68.9	63.0	57.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.8	61.9	63.2	68.0	72.4	79.4	80.8	82.8	79.1	75.2	70.1	62.9	(27)
		MCDB	65.5	66.7	68.8	75.2	81.0	87.5	88.9	90.2	87.9	83.4	77.6	68.9	(28)
	2%	WB	57.8	59.7	61.5	66.0	70.9	77.2	79.6	81.2	77.6	73.0	67.8	61.1	(29)
		MCDB	63.7	64.9	67.5	72.8	79.1	86.1	88.4	89.6	87.1	81.4	75.3	67.4	(30)
	5%	WB	56.5	58.2	60.2	64.6	69.7	75.8	78.6	80.1	76.4	71.6	65.8	59.5	(31)
		MCDB	62.6	63.9	66.3	71.9	77.9	84.8	87.9	89.0	86.4	80.6	73.8	66.1	(32)
	10%	WB	55.2	56.6	59.0	63.3	68.4	74.4	77.7	79.1	75.4	70.2	64.2	58.0	(33)
		MCDB	61.5	62.8	65.3	70.5	76.6	83.5	87.2	88.4	85.8	79.5	72.4	64.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	10.3	11.6	12.5	12.1	12.1	11.9	11.9	11.6	11.9	10.8	10.1	(35)
		MCDBR	11.2	11.6	13.0	14.1	13.5	14.2	13.2	12.9	12.5	13.0	11.9	11.3	(36)
	5% WB	MCWBR	7.6	8.6	9.9	12.5	11.8	12.3	12.8	12.2	11.2	10.2	9.7	7.8	(37)
		MCWBR	10.3	11.3	12.5	13.5	12.6	12.6	11.8	11.2	12.1	12.2	11.6	10.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.373	0.398	0.430	0.474	0.463	0.421	0.438	0.448	0.417	0.414	0.386	0.370	(40)
		taud	2.345	2.256	2.160	2.062	2.155	2.326	2.287	2.252	2.338	2.319	2.348	2.375	(41)
	Ebn at Noon		258	264	265	259	263	274	268	263	266	256	251	251	(42)
		Edh at Noon	31	38	45	52	48	41	42	43	37	35	31	29	(43)
(44) All-Sky Solar Radiation	RadAvg		776	1065	1517	1907	2215	2475	2409	2152	1828	1341	953	711	(44)
	RadStd		61	93	83	94	108	51	48	36	54	67	58	64	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-144	+292	+144

Nomenclature: See separate page