

GIRNE, Cyprus

WMO: 175100

Lat: 35.350N

Lon: 33.333E

Elev: 10

StdP: 101.20

Time Zone: 2.00 (EUE)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.3	8.8	-3.4	2.9	9.2	-1.5	3.3	10.9	10.8	12.3	9.9	12.7	3.4	0	0.334

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.6	34.2	22.7	33.1	24.2	32.2	24.5	26.9	31.7	26.3	31.3	25.7	31.0	0.9	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.5	20.7	30.9	24.7	19.7	30.7	24.0	18.9	30.5	84.9	31.9	82.1	31.6	79.5	30.9	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.2	8.6	7.2	4.4	36.9	2.8	1.2	2.4	37.7	0.7	38.4	-0.9	39.1	-3.0	40.0		
			2.1	28.6	1.9	1.1	0.8	29.3	-0.3	30.0	-1.4	30.6	-2.7	31.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	21.1	13.4	14.0	15.6	18.3	21.8	25.9	28.9	29.6	27.1	23.7	19.6	15.2	(6)
(7)		DBStd	5.93	2.32	2.03	1.72	1.65	1.97	2.04	1.50	1.12	1.42	1.72	1.95	2.23	(7)
(8)		HDD10.0	9	6	2	1	0	0	0	0	0	0	0	0	1	(8)
(9)		HDD18.3	487	152	121	85	20	1	0	0	0	0	0	11	98	(9)
(10)		CDD10.0	4068	112	114	175	249	365	477	584	607	512	423	287	162	(10)
(11)		CDD18.3	1505	0	0	2	19	107	227	326	348	262	165	48	1	(11)
(12)		CDH23.3	14881	0	0	2	31	424	2092	4093	4591	2678	903	66	0	(12)
(13)		CDH26.7	5653	0	0	0	2	41	602	1802	2186	891	129	1	0	(13)
(14)	Wind	WSAvg	2.1	2.2	2.4	2.4	2.0	1.9	2.4	2.1	1.8	2.2	1.5	1.6	2.2	(14)
(15)	Precipitation	PrecAvg	407	77	64	35	22	29	9	4	2	7	25	48	84	(15)
(16)		PrecMax	632	235	160	115	65	78	47	27	13	38	86	179	223	(16)
(17)		PrecMin	200	20	15	0	1	4	0	0	0	3	0	0	12	(17)
(18)		PrecStd	106	47	38	22	15	20	12	7	3	10	21	39	54	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.5	20.1	22.2	26.1	29.2	34.6	36.0	32.6	30.3	26.1	21.5	(19)	
(20)			MCWB	13.9	15.2	15.0	16.5	19.6	20.7	20.4	22.3	24.0	20.7	19.6	15.9	(20)
(21)		2%	DB	18.4	19.1	20.6	24.1	27.7	32.2	34.3	34.3	31.7	29.0	25.0	20.5	(21)
(22)			MCWB	13.6	14.7	15.2	17.7	19.9	22.3	21.7	23.5	24.0	21.3	19.1	15.4	(22)
(23)		5%	DB	17.7	18.2	19.8	23.0	26.6	30.8	32.7	33.3	31.1	28.1	24.0	19.6	(23)
(24)			MCWB	13.1	14.0	14.9	17.4	19.9	22.9	23.9	24.6	23.8	20.9	18.0	14.6	(24)
(25)		10%	DB	16.9	17.5	19.1	22.0	25.6	29.7	31.9	32.6	30.5	27.3	23.1	18.8	(25)
(26)			MCWB	12.5	13.4	14.4	16.8	19.6	22.8	24.4	24.9	23.4	20.5	17.2	14.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.4	16.6	17.3	20.0	22.4	26.3	27.1	28.2	26.2	24.0	21.2	17.2	(27)
(28)			MCD B	18.6	19.3	20.4	24.0	27.2	30.8	31.6	32.3	31.1	28.5	25.3	20.5	(28)
(29)		2%	WB	14.3	15.4	16.4	18.9	21.6	25.1	26.4	27.3	25.4	22.8	19.9	16.2	(29)
(30)			MCD B	17.6	18.3	19.7	22.7	26.2	30.1	31.4	32.0	30.6	27.4	24.1	19.7	(30)
(31)		5%	WB	13.6	14.5	15.7	18.1	20.9	24.3	25.9	26.7	24.7	22.0	18.8	15.3	(31)
(32)			MCD B	17.0	17.7	19.1	22.2	25.5	29.3	31.1	31.7	30.2	27.0	23.2	19.0	(32)
(33)		10%	WB	12.9	13.7	15.0	17.4	20.2	23.5	25.4	26.2	24.1	21.2	17.9	14.5	(33)
(34)			MCD B	16.4	17.1	18.5	21.4	24.8	28.6	30.7	31.3	29.9	26.4	22.4	18.1	(34)
(35)	Mean Daily Temperature Range	MDBR	5.5	5.7	6.4	6.9	6.7	6.7	6.6	6.6	6.5	6.6	6.0	5.6	(35)	
(36)		5% DB	MCD BR	6.2	6.5	7.2	7.9	7.5	7.9	7.3	7.2	7.0	7.2	6.6	6.3	(36)
(37)			MCWBR	4.2	4.8	5.5	6.9	6.6	6.8	7.1	6.8	6.2	5.6	5.4	4.4	(37)
(38)		5% WB	MCD BR	5.7	6.3	6.9	7.5	7.0	7.0	6.6	6.2	6.7	6.8	6.4	5.7	(38)
(39)			MCWBR	4.2	5.0	5.7	7.0	6.7	6.9	7.5	6.5	6.9	6.1	5.7	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.373	0.398	0.430	0.474	0.463	0.421	0.438	0.448	0.417	0.414	0.386	0.370	(40)	
(41)		taud	2.345	2.256	2.160	2.062	2.155	2.326	2.287	2.252	2.338	2.319	2.348	2.375	(41)	
(42)		Ebn at Noon	812	832	836	817	830	863	845	830	840	806	790	791	(42)	
(43)		Edh at Noon	98	119	142	164	152	128	132	134	118	110	97	90	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.45	3.36	4.78	6.01	6.98	7.80	7.59	6.78	5.76	4.23	3.00	2.24	(44)	
(45)		RadStd	0.19	0.29	0.26	0.29	0.34	0.16	0.15	0.12	0.17	0.21	0.18	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-80	+162	+80

Nomenclature: See separate page